

Mr. Albert Tijerina  
East Aurora School District 131  
Director of Building and Grounds  
411 Hill Avenue  
Aurora, Illinois 60505

**RE: Lead Sampling in Potable Water  
Brady Elementary School  
600 Columbia Street, Aurora, IL 60505**

Dear Mr. Tijerina:

The following letter report summarizes the laboratory results for the drinking water samples collected from the potable water sources at Brady Elementary School in Aurora, Illinois. The sampling was conducted on November 4, 2017 by Mr. Matthew Rodriguez of Weaver Consultants Group (WCG). Mr. Rodriguez conducted the sampling under the direction of Mr. David J. Kedrowski, CIH.

#### **SCOPE OF WORK**

The scope of work for this project involved collecting water samples from pre-identified water locations. The potable locations were provided to WCG by East Aurora School District 131. The collected potable water samples were then analyzed for lead by an accredited laboratory.

#### **METHODOLOGY**

WCG followed protocols set by U.S. Environmental Protection Agency (EPA) and Illinois Department of Public Health (IDPH) for testing schools for lead in drinking water. Representatives from East Aurora School District 131 confirmed the school was under normal use and ensured the water settled within the piping systems/fixtures for between eight (8) to eighteen (18) hours.

Forty-four (44) water samples from representative potable water locations were collected in 250 milliliter bottles. The water samples were collected as a “first draw” from each source to represent a lead concentration from water allowed to sit within the pipes or drinking reservoirs for at least eight (8) hours and not more than eighteen (18) hours. A second sample was collected from each location after a 30 second flush to represent water from within the building’s localized water piping system. Potable water sources generally included drinking fountains, Nurses’ Offices, Teachers’ Lounges, kitchen faucets and preschool, kindergarten, and first floor classroom sinks, etc.

At the request of the District, non-potable samples were collected at the water main to the building to establish a baseline. As this is a non-potable source, the results likely do not represent water within the building system but rather sediment at the water main valve or within the sampling connections used to draw the sample. Water samples collected at each potable fixture should instead be relied upon as representative of the drinking water within the building.

Each sample was labeled with a unique sample number identifying the school. The samples were transported to Suburban Labs Incorporated (Suburban) in Geneva, Illinois. Samples were analyzed for lead content using EPA Method 200.8 "Determination of Trace Elements in Water using Inductively Coupled Plasma (ICP)/Mass Spectrometry (MS). Suburban is accredited to analyze lead in potable drinking water under the National Environmental Laboratory Accreditation Program (NELAP).

## **RESULTS**

The results of the water sample analysis revealed that six (6) samples of the forty-four (44) collected had lead concentrations above the IDPH Action Level of 2 ppb ( $\mu\text{g/L}$ ). All sample results that exceed 5  $\mu\text{g/L}$  should be promptly reported to parents or guardians of the enrolled students as required by the Illinois Department of Public Health (IDPH).

## **CONCLUSIONS AND RECOMMENDATIONS**

- 1) Within 7 business days of receipt of test results, schools must email all results to IDPH at [DPH.LeadH20@illinois.gov](mailto:DPH.LeadH20@illinois.gov). **WCG will email these results on behalf of East Aurora School District 131.**
- 2) All sample results that exceed 5  $\mu\text{g/L}$  should be promptly reported to parents or guardians of all enrolled students in writing or electronically and include:
  - The location and source exceeding 5  $\mu\text{g/L}$ .
  - The USEPA website for information about lead in drinking water, <https://www.epa.gov/ground-water-and-drinking-water/basic-information-about-lead-drinking-water>.
- 3) Implement corrective action for fixtures greater than 2  $\mu\text{g/L}$ .
- 4) Implement best practices to minimize lead concentrations in drinking water.

## **BEST PRACTICES**

Best practices for managing elevated lead concentrations in drinking water may include implementing a water quality management plan (WQMP), establishing a routine water flushing program for potable sources daily or during periods of low occupancy or low water usage, routine maintenance to clean screens and aerators, and confirmation sampling. In addition, occupants should avoid consuming water from non-potable sources i.e. classroom or office sinks, washroom sinks, maintenance closets, etc. and hot water taps.

A summary of the sample locations and results may be found in Appendix A and the laboratory report with chain of custody sheets may be found in Appendix B. We appreciate the opportunity to assist you on this important project.

Sincerely,

**Weaver Consultants Group North Central, LLC**



David J. Kedrowski, CIH  
Senior Project Director

**APPENDIX A**

**Lead in Potable Water Sample Results**

**Brady Elementary School  
600 Columbia Street  
Aurora, IL 60505**

ISBE ID	Sample Date	Sample Time (12 HR Clock)	Sample ID Number	Sample Location Description	Fixture Type	Date of Last Use	Time of Last Use (12 HR Clock)	Sample Type	Concentration (ug/L)
310451310222007	11/04/2017	06:02 AM	BRADY-01A	1st Floor-Entrance 4-Rms. 118-114 (Left)	DF - Drinking Fountain	11/3/2017	07:00 PM	First Draw	ND
310451310222007	11/04/2017	06:02 AM	BRADY-01B	1st Floor-Entrance 4-Rms. 118-114 (Left)	DF - Drinking Fountain	11/3/2017	07:00 PM	Flush	ND
310451310222007	11/04/2017	06:02 AM	BRADY-02A	1st Floor-Entrance 4-Rms. 118-114 (Right)	DF - Drinking Fountain	11/3/2017	07:00 PM	First Draw	ND
310451310222007	11/04/2017	06:02 AM	BRADY-02B	1st Floor-Entrance 4-Rms. 118-114 (Right)	DF - Drinking Fountain	11/3/2017	07:00 PM	Flush	ND
310451310222007	11/04/2017	06:09 AM	BRADY-03A	1st Floor-Rm. 118	S - Sink	11/3/2017	07:00 PM	First Draw	8.14
310451310222007	11/04/2017	06:09 AM	BRADY-03B	1st Floor-Rm. 118	S - Sink	11/3/2017	07:00 PM	Flush	ND
310451310222007	11/04/2017	06:12 AM	BRADY-04A	1st Floor-Rm. 114	S - Sink	11/3/2017	07:00 PM	First Draw	ND
310451310222007	11/04/2017	06:12 AM	BRADY-04B	1st Floor-Rm. 114	S - Sink	11/3/2017	07:00 PM	Flush	ND
310451310222007	11/04/2017	06:15 AM	BRADY-05A	1st Floor-Kitchen	KS - Kitchen Sink	11/3/2017	07:00 PM	First Draw	6.94
310451310222007	11/04/2017	06:15 AM	BRADY-05B	1st Floor-Kitchen	KS - Kitchen Sink	11/3/2017	07:00 PM	Flush	ND
310451310222007	11/04/2017	06:18 AM	BRADY-06A	1st Floor-Rm. 106	DF - Drinking Fountain	11/3/2017	07:00 PM	First Draw	ND
310451310222007	11/04/2017	06:18 AM	BRADY-06B	1st Floor-Rm. 106	DF - Drinking Fountain	11/3/2017	07:00 PM	Flush	ND
310451310222007	11/04/2017	06:21 AM	BRADY-07A	1st Floor-Water Line-Behind Rm. 108	O - Other	11/3/2017	07:00 PM	First Draw	ND
310451310222007	11/04/2017	06:21 AM	BRADY-07B	1st Floor-Water Line-Behind Rm. 108	O - Other	11/3/2017	07:00 PM	Flush	2.33
310451310222007	11/04/2017	06:28 AM	BRADY-08A	Basement Floor-Outside of Gym By Stairs	DF - Drinking Fountain	11/3/2017	07:00 PM	First Draw	ND
310451310222007	11/04/2017	06:28 AM	BRADY-08B	Basement Floor-Outside of Gym By Stairs	DF - Drinking Fountain	11/3/2017	07:00 PM	Flush	ND
310451310222007	11/04/2017	06:32 AM	BRADY-09A	1st Floor-Rm. 102	DF - Drinking Fountain	11/3/2017	07:00 PM	First Draw	ND
310451310222007	11/04/2017	06:32 AM	BRADY-09B	1st Floor-Rm. 102	DF - Drinking Fountain	11/3/2017	07:00 PM	Flush	ND
310451310222007	11/04/2017	06:36 AM	BRADY-10A	2nd Floor-Exit 7	DF - Drinking Fountain	11/3/2017	07:00 PM	First Draw	ND
310451310222007	11/04/2017	06:36 AM	BRADY-10B	2nd Floor-Exit 7	DF - Drinking Fountain	11/3/2017	07:00 PM	Flush	ND
310451310222007	11/04/2017	06:40 AM	BRADY-11A	2nd Floor-Nurse Office	S - Sink	11/3/2017	07:00 PM	First Draw	ND
310451310222007	11/04/2017	06:40 AM	BRADY-11B	2nd Floor-Nurse Office	S - Sink	11/3/2017	07:00 PM	Flush	ND
310451310222007	11/04/2017	06:43 AM	BRADY-12A	2nd Floor-Exit 4	DF - Drinking Fountain	11/3/2017	07:00 PM	First Draw	ND
310451310222007	11/04/2017	06:43 AM	BRADY-12B	2nd Floor-Exit 4	DF - Drinking Fountain	11/3/2017	07:00 PM	Flush	ND
310451310222007	11/04/2017	06:49 AM	BRADY-13A	2nd Floor-Downstairs-Rm. 218/220 (Left)	DF - Drinking Fountain	11/3/2017	07:00 PM	First Draw	ND
310451310222007	11/04/2017	06:49 AM	BRADY-13B	2nd Floor-Downstairs-Rm. 218/220 (Left)	DF - Drinking Fountain	11/3/2017	07:00 PM	Flush	ND
310451310222007	11/04/2017	06:49 AM	BRADY-14A	2nd Floor-Downstairs-Rm. 218/220 (Right)	DF - Drinking Fountain	11/3/2017	07:00 PM	First Draw	ND
310451310222007	11/04/2017	06:49 AM	BRADY-14B	2nd Floor-Downstairs-Rm. 218/220 (Right)	DF - Drinking Fountain	11/3/2017	07:00 PM	Flush	ND
310451310222007	11/04/2017	06:55 AM	BRADY-15A	2nd Floor-Downstairs-Rm. 220	S - Sink	11/3/2017	07:00 PM	First Draw	ND
310451310222007	11/04/2017	06:55 AM	BRADY-15B	2nd Floor-Downstairs-Rm. 220	S - Sink	11/3/2017	07:00 PM	Flush	ND
310451310222007	11/04/2017	07:00 AM	BRADY-16A	2nd Floor-Downstairs-Rm. 218/220	S - Sink	11/3/2017	07:00 PM	First Draw	ND
310451310222007	11/04/2017	07:00 AM	BRADY-16B	2nd Floor-Downstairs-Rm. 218/220	S - Sink	11/3/2017	07:00 PM	Flush	3.18
310451310222007	11/04/2017	07:02 AM	BRADY-17A	2nd Floor-Downstairs-Rm. 224	S - Sink	11/3/2017	07:00 PM	First Draw	ND
310451310222007	11/04/2017	07:02 AM	BRADY-17B	2nd Floor-Downstairs-Rm. 224	S - Sink	11/3/2017	07:00 PM	Flush	ND
310451310222007	11/04/2017	07:07 AM	BRADY-18A	2nd Floor-Rm. 222	S - Sink	11/3/2017	07:00 PM	First Draw	3.97
310451310222007	11/04/2017	07:07 AM	BRADY-18B	2nd Floor-Rm. 222	S - Sink	11/3/2017	07:00 PM	Flush	3.56
310451310222007	11/04/2017	07:10 AM	BRADY-19A	3rd Floor-By Rm. 219	DF - Drinking Fountain	11/3/2017	07:00 PM	First Draw	ND
310451310222007	11/04/2017	07:10 AM	BRADY-19B	3rd Floor-By Rm. 219	DF - Drinking Fountain	11/3/2017	07:00 PM	Flush	ND
310451310222007	11/04/2017	07:12 AM	BRADY-20A	3rd Floor-Conference Room	S - Sink	11/3/2017	07:00 PM	First Draw	ND
310451310222007	11/04/2017	07:12 AM	BRADY-20B	3rd Floor-Conference Room	S - Sink	11/3/2017	07:00 PM	Flush	ND
310451310222007	11/04/2017	07:15 AM	BRADY-21A	3rd Floor-Teacher Lounge	WF - Water Cooler	11/3/2017	07:00 PM	First Draw	ND
310451310222007	11/04/2017	07:15 AM	BRADY-21B	3rd Floor-Teacher Lounge	WF - Water Cooler	11/3/2017	07:00 PM	Flush	ND
310451310222007	11/04/2017	07:20 AM	BRADY-22A	3rd Floor-Exit 7 by Rm. 302	DF - Drinking Fountain	11/3/2017	07:00 PM	First Draw	ND
310451310222007	11/04/2017	07:20 AM	BRADY-22B	3rd Floor-Exit 7 by Rm. 302	DF - Drinking Fountain	11/3/2017	07:00 PM	Flush	ND

**APPENDIX B**  
**Laboratory Results and Chain of Custody Documentation**

# SUBURBAN LABORATORIES, Inc.



1950 S. Batavia Ave., Suite 150 Geneva, Illinois 60134  
Tel. (708) 544-3260 • Toll Free (800) 783-LABS  
Fax (708) 544-8587  
www.suburbanlabs.com

November 17, 2017

Olivia Reynhout  
Weaver Consultants Group  
1316 Bond St - Suite 108  
Naperville, IL 60563

**Workorder: 1711529**

TEL: (630) 717-4848

FAX: (630) 717-4850

RE: Brady Elementary School Drinking Water Lead Analysis

Dear Olivia Reynhout:

Suburban Laboratories, Inc. received 44 sample(s) on 11/7/2017 for the analyses presented in the following report.

Customer has provided 250 mL volume sample bottles for all samples collected. Please note, all sample results that exceed 5.00 ug/L should be promptly reported to parents or guardians of all enrolled students. Results that are below 5.00 ug/L should be reported on the school website. Please refer to Public Act 099-0922 or the Illinois Department of Public Health for specific reporting requirements. Suburban Laboratories will forward all results to the IDPH within seven (7) business days from the date of this report.

This report may not be reproduced, except in full, without the prior written approval of Suburban Laboratories, Inc. If you have any questions regarding these test results, please call me at (708) 544-3260.

Sincerely,

Pat Rodriguez  
Project Manager  
708-544-3260 ext 214  
pat@suburbanlabs.com



# SUBURBAN LABORATORIES, Inc.



1950 S. Batavia Ave., Suite 150 Geneva, Illinois 60134  
 Tel. (708) 544-3260 • Toll Free (800) 783-LABS  
 Fax (708) 544-8587  
 www.suburbanlabs.com

**Client ID:** Weaver Consultants Group

**Report Date:** November 17, 2017

**Project Name:** Brady Elementary School Drinking Water Lead Analysis

**Workorder:** 1711529

**Analyte:** Lead

**Method:** EPA 200.8

**Matrix:** Drinking Water

Sample ID	Client Sample ID	Result	MRL	Units	Date & Time Water System Last Used	Date Collected	Date Analyzed
1711529-001A	BRADY-01A~1st Floor-Entrance 4-Rms. 118-114~First Draw	ND	2.00	µg/L	11/04/2017 19:00	11/4/2017	11/11/2017
1711529-002A	BRADY-01B~1st Floor-Entrance 4-Rms. 118-114~Flush	ND	2.00	µg/L	11/04/2017 19:00	11/4/2017	11/11/2017
1711529-003A	BRADY-02A~1st Floor-Entrance 4-Rms. 118-114~First Draw	ND	2.00	µg/L	11/04/2017 19:00	11/4/2017	11/11/2017
1711529-004A	BRADY-02B~1st Floor-Entrance 4-Rms. 118-114~Flush	ND	2.00	µg/L	11/04/2017 19:00	11/4/2017	11/11/2017
1711529-005A	BRADY-03A~1st Floor-Rm. 118~First Draw	8.14	2.00	µg/L	11/04/2017 19:00	11/4/2017	11/11/2017
1711529-006A	BRADY-03B~1st Floor-Rm. 118~Flush	ND	2.00	µg/L	11/04/2017 19:00	11/4/2017	11/11/2017
1711529-007A	BRADY-04A~1st Floor-Rm. 114~First Draw	ND	2.00	µg/L	11/04/2017 19:00	11/4/2017	11/11/2017
1711529-008A	BRADY-04B~1st Floor-Rm. 114~Flush	ND	2.00	µg/L	11/04/2017 19:00	11/4/2017	11/11/2017
1711529-009A	BRADY-05A~1st Floor-Kitchen~First Draw	6.94	2.00	µg/L	11/04/2017 19:00	11/4/2017	11/11/2017
1711529-010A	BRADY-05B~1st Floor-Kitchen~Flush	ND	2.00	µg/L	11/04/2017 19:00	11/4/2017	11/11/2017
1711529-011A	BRADY-06A~1st Floor-Rm. 106~First Draw	ND	2.00	µg/L	11/04/2017 19:00	11/4/2017	11/11/2017
1711529-012A	BRADY-06B~1st Floor-Rm. 106~Flush	ND	2.00	µg/L	11/04/2017 19:00	11/4/2017	11/11/2017
1711529-013A	BRADY-07A~1st Floor-Water Line-Behind Rm. 108~First Draw	ND	2.00	µg/L	11/04/2017 19:00	11/4/2017	11/11/2017
1711529-014A	BRADY-07B~1st Floor-Water Line-Behind Rm. 108~Flush	2.33	2.00	µg/L	11/04/2017 19:00	11/4/2017	11/11/2017
1711529-015A	BRADY-08A~Basement Floor-Outside of Gym By Stairs~First Draw	ND	2.00	µg/L	11/04/2017 19:00	11/4/2017	11/11/2017
1711529-016A	BRADY-08B~Basement Floor-Outside of Gym By Stairs~Flush	ND	2.00	µg/L	11/04/2017 19:00	11/4/2017	11/11/2017
1711529-017A	BRADY-09A~1st Floor-Rm. 102~First Draw	ND	2.00	µg/L	11/04/2017 19:00	11/4/2017	11/11/2017
1711529-018A	BRADY-09B~1st Floor-Rm. 102~Flush	ND	2.00	µg/L	11/04/2017 19:00	11/4/2017	11/11/2017
1711529-019A	BRADY-10A~2nd Floor-Exit 7~First Draw	ND	2.00	µg/L	11/04/2017 19:00	11/4/2017	11/11/2017
1711529-020A	BRADY-10B~2nd Floor-Exit 7~Flush	ND	2.00	µg/L	11/04/2017 19:00	11/4/2017	11/11/2017
1711529-021A	BRADY-11A~2nd Floor-Nurse Office~First Draw	ND	2.00	µg/L	11/04/2017 19:00	11/4/2017	11/11/2017

ND - Not Detected Down to the Laboratory Minimum Reporting Limit (MRL)

# SUBURBAN LABORATORIES, Inc.



1950 S. Batavia Ave., Suite 150 Geneva, Illinois 60134  
Tel. (708) 544-3260 • Toll Free (800) 783-LABS  
Fax (708) 544-8587  
www.suburbanlabs.com

**Client ID:** Weaver Consultants Group

**Report Date:** November 17, 2017

**Project Name:** Brady Elementary School Drinking Water Lead Analysis

**Workorder:** 1711529

**Analyte:** Lead

**Method:** EPA 200.8

**Matrix:** Drinking Water

Sample ID	Client Sample ID	Result	MRL	Units	Date & Time Water System Last Used	Date Collected	Date Analyzed
1711529-022A	BRADY-11B~2nd Floor-Nurse Office~Flush	ND	2.00	µg/L	11/04/2017 19:00	11/4/2017	11/11/2017
1711529-023A	BRADY-12A~2nd Floor-Exit 4~First Draw	ND	2.00	µg/L	11/04/2017 19:00	11/4/2017	11/11/2017
1711529-024A	BRADY-12B~2nd Floor-Exit 4~Flush	ND	2.00	µg/L	11/04/2017 19:00	11/4/2017	11/11/2017
1711529-025A	BRADY-13A~2nd Floor-Downstairs-Rm. 218/220~First Draw	ND	2.00	µg/L	11/04/2017 19:00	11/4/2017	11/11/2017
1711529-026A	BRADY-13B~2nd Floor-Downstairs-Rm. 218/220~Flush	ND	2.00	µg/L	11/04/2017 19:00	11/4/2017	11/11/2017
1711529-027A	BRADY-14A~2nd Floor-Downstairs-Rm. 218/220~First Draw	ND	2.00	µg/L	11/04/2017 19:00	11/4/2017	11/11/2017
1711529-028A	BRADY-14B~2nd Floor-Downstairs-Rm. 218/220~Flush	ND	2.00	µg/L	11/04/2017 19:00	11/4/2017	11/11/2017
1711529-029A	BRADY-15A~2nd Floor-Downstairs-Rm. 220~First Draw	ND	2.00	µg/L	11/04/2017 19:00	11/4/2017	11/11/2017
1711529-030A	BRADY-15B~2nd Floor-Downstairs-Rm. 220~Flush	ND	2.00	µg/L	11/04/2017 19:00	11/4/2017	11/11/2017
1711529-031A	BRADY-16A~2nd Floor-Downstairs-Rm. 218/220~First Draw	ND	2.00	µg/L	11/04/2017 19:00	11/4/2017	11/11/2017
1711529-032A	BRADY-16B~2nd Floor-Downstairs-Rm. 218/220~Flush	3.18	2.00	µg/L	11/04/2017 19:00	11/4/2017	11/11/2017
1711529-033A	BRADY-17A~2nd Floor-Downstairs-Rm. 224~First Draw	ND	2.00	µg/L	11/04/2017 19:00	11/4/2017	11/11/2017
1711529-034A	BRADY-17B~2nd Floor-Downstairs-Rm. 224~Flush	ND	2.00	µg/L	11/04/2017 19:00	11/4/2017	11/11/2017
1711529-035A	BRADY-18A~2nd Floor-Rm. 222~First Draw	3.97	2.00	µg/L	11/04/2017 19:00	11/4/2017	11/11/2017
1711529-036A	BRADY-18B~2nd Floor-Rm. 222~Flush	3.56	2.00	µg/L	11/04/2017 19:00	11/4/2017	11/11/2017
1711529-037A	BRADY-19A~3rd Floor-By Rm. 219~First Draw	ND	2.00	µg/L	11/04/2017 19:00	11/4/2017	11/11/2017
1711529-038A	BRADY-19B~3rd Floor-By Rm. 219~Flush	ND	2.00	µg/L	11/04/2017 19:00	11/4/2017	11/11/2017
1711529-039A	BRADY-20A~3rd Floor-Conference Room~First Draw	ND	2.00	µg/L	11/04/2017 19:00	11/4/2017	11/11/2017
1711529-040A	BRADY-20B~3rd Floor-Conference Room~Flush	ND	2.00	µg/L	11/04/2017 19:00	11/4/2017	11/11/2017
1711529-041A	BRADY-21A~3rd Floor-Teacher Lounge~First Draw	ND	2.00	µg/L	11/04/2017 19:00	11/4/2017	11/11/2017



# SUBURBAN LABORATORIES, Inc.



1950 S. Batavia Ave., Suite 150 Geneva, Illinois 60134  
Tel. (708) 544-3260 • Toll Free (800) 783-LABS  
Fax (708) 544-8587  
www.suburbanlabs.com

**Client ID:** Weaver Consultants Group

**Report Date:** November 17, 2017

**Project Name:** Brady Elementary School Drinking Water Lead Analysis

**Workorder:** 1711529

**Analyte:** Lead

**Method:** EPA 200.8

**Matrix:** Drinking Water

Sample ID	Client Sample ID	Result	MRL	Units	Date & Time Water System Last Used	Date Collected	Date Analyzed
1711529-042A	BRADY-21B~3rd Floor-Teacher Lounge~Flush	ND	2.00	µg/L	11/04/2017 19:00	11/4/2017	11/11/2017
1711529-043A	BRADY-22A~3rd Floor-Exit 7 by Rm. 302~First Draw	ND	2.00	µg/L	11/04/2017 19:00	11/4/2017	11/11/2017
1711529-044A	BRADY-22B~3rd Floor-Exit 7 by Rm. 302~Flush	ND	2.00	µg/L	11/04/2017 19:00	11/4/2017	11/11/2017

1711529-001A-44A

FIELD DATA FORM

School/Facility Name  
 Brady Elementary School  
 ISBE ID: (ex-01-001-0001-01-00001)  
 310451310222007

Address  
 600 Columbia St  
 Aurora, IL 60505

Sample Collector Name(s)  
 Matthew Rodriguez

Water system last used Date: MMDDYYYY 11/04/2017 Time: HH24MM 19:00

All samples must be collected in unpreserved

Bldg. ID	Bldg. Desc	Sample ID#	Sample Loc. Desc	Collection Date MMDDYYYY	Collection Time HH24MM	Fixture Type	Sample Type	Sample Vol.	Notes
0001	Main Building	D1	1st Floor Classroom	02232017	800	O - Other	First Draw	250	Description if "Other" is selected
0001	Main Building	D1A	1st Floor Classroom	02232017	800	S - Sink	Flush	250	
1	School	ERADY-01A	1st Floor-Entrance 4-Rm. 118-114	11/04/2017	6:02	DF - Drinking Fountain	First Draw	250	
2	School	ERADY-01B	1st Floor-Entrance 4-Rm. 118-114	11/04/2017	6:02	DF - Drinking Fountain	Flush	250	
3	School	ERADY-02A	1st Floor-Entrance 4-Rm. 118-114	11/04/2017	6:02	DF - Drinking Fountain	First Draw	250	
4	School	ERADY-02B	1st Floor-Entrance 4-Rm. 118-114	11/04/2017	6:02	DF - Drinking Fountain	Flush	250	
5	School	ERADY-03A	1st Floor-Rm. 118	11/04/2017	6:09	S - Sink	First Draw	250	
6	School	ERADY-03B	1st Floor-Rm. 118	11/04/2017	6:09	S - Sink	Flush	250	
7	School	ERADY-04A	1st Floor-Rm. 114	11/04/2017	6:12	S - Sink	First Draw	250	
8	School	ERADY-04B	1st Floor-Rm. 114	11/04/2017	6:12	S - Sink	Flush	250	
9	School	ERADY-05A	1st Floor-Kitchen	11/04/2017	6:15	KS - Kitchen Sink	First Draw	250	
10	School	ERADY-05B	1st Floor-Kitchen	11/04/2017	6:15	KS - Kitchen Sink	Flush	250	
11	School	ERADY-06A	1st Floor-Rm. 106	11/04/2017	6:18	DF - Drinking Fountain	First Draw	250	
12	School	ERADY-06B	1st Floor-Rm. 106	11/04/2017	6:18	DF - Drinking Fountain	Flush	250	
13	School	ERADY-07A	1st Floor-Water Line Behind Rm. 108	11/04/2017	6:21	O - Other	First Draw	250	
14	School	ERADY-07B	1st Floor-Water Line Behind Rm. 108	11/04/2017	6:21	O - Other	Flush	250	
15	School	ERADY-08A	Basement Floor-Outside of Gym By Stairs	11/04/2017	6:28	DF - Drinking Fountain	First Draw	250	
16	School	ERADY-08B	Basement Floor-Outside of Gym By Stairs	11/04/2017	6:28	DF - Drinking Fountain	Flush	250	
17	School	ERADY-09A	1st Floor-Rm. 102	11/04/2017	6:32	DF - Drinking Fountain	First Draw	250	
18	School	ERADY-09B	1st Floor-Rm. 102	11/04/2017	6:32	DF - Drinking Fountain	Flush	250	
19	School	ERADY-10A	2nd Floor-Exit 7	11/04/2017	6:36	DF - Drinking Fountain	First Draw	250	
20	School	ERADY-10B	2nd Floor-Exit 7	11/04/2017	6:36	DF - Drinking Fountain	Flush	250	
21	School	ERADY-11A	2nd Floor-Nurse Office	11/04/2017	6:40	S - Sink	First Draw	250	
22	School	ERADY-11B	2nd Floor-Nurse Office	11/04/2017	6:40	S - Sink	Flush	250	
23	School	ERADY-12A	2nd Floor-Exit 4	11/04/2017	6:43	DF - Drinking Fountain	First Draw	250	
24	School	ERADY-12B	2nd Floor-Exit 4	11/04/2017	6:43	DF - Drinking Fountain	Flush	250	
25	School	ERADY-13A	2nd Floor-Downstairs-Rm. 218/220	11/04/2017	6:49	DF - Drinking Fountain	First Draw	250	
26	School	ERADY-13B	2nd Floor-Downstairs-Rm. 218/220	11/04/2017	6:49	DF - Drinking Fountain	Flush	250	
27	School	ERADY-14A	2nd Floor-Downstairs-Rm. 218/220	11/04/2017	6:49	DF - Drinking Fountain	First Draw	250	
28	School	ERADY-14B	2nd Floor-Downstairs-Rm. 218/220	11/04/2017	6:49	DF - Drinking Fountain	Flush	250	
29	School	ERADY-15A	2nd Floor-Downstairs-Rm. 220	11/04/2017	6:55	S - Sink	First Draw	250	
30	School	ERADY-15B	2nd Floor-Downstairs-Rm. 220	11/04/2017	6:55	S - Sink	Flush	250	
31	School	ERADY-16A	2nd Floor-Downstairs-Rm. 218/220	11/04/2017	7:00	S - Sink	First Draw	250	
32	School	ERADY-16B	2nd Floor-Downstairs-Rm. 218/220	11/04/2017	7:00	S - Sink	Flush	250	
33	School	ERADY-17A	2nd Floor-Downstairs-Rm. 224	11/04/2017	7:02	S - Sink	First Draw	250	
34	School	ERADY-17B	2nd Floor-Downstairs-Rm. 224	11/04/2017	7:02	S - Sink	Flush	250	
35	School	ERADY-18A	2nd Floor-Rm. 222	11/04/2017	7:07	S - Sink	First Draw	250	
36	School	ERADY-18B	2nd Floor-Rm. 222	11/04/2017	7:07	S - Sink	Flush	250	
37	School	ERADY-19A	3rd Floor-By Rm. 219	11/04/2017	7:10	DF - Drinking Fountain	First Draw	250	
38	School	ERADY-19B	3rd Floor-By Rm. 219	11/04/2017	7:10	DF - Drinking Fountain	Flush	250	
39	School	ERADY-20A	3rd Floor-Conference Room	11/04/2017	7:12	S - Sink	First Draw	250	
40	School	ERADY-20B	3rd Floor-Conference Room	11/04/2017	7:12	S - Sink	Flush	250	
41	School	ERADY-21A	3rd Floor-Teacher Lounge	11/04/2017	7:15	WF - Water Cooler	First Draw	250	
42	School	ERADY-21B	3rd Floor-Teacher Lounge	11/04/2017	7:15	WF - Water Cooler	Flush	250	
43	School	ERADY-22A	3rd Floor-Exit 7 by Rm. 302	11/04/2017	7:20	DF - Drinking Fountain	First Draw	250	
44	School	ERADY-22B	3rd Floor-Exit 7 by Rm. 302	11/04/2017	7:20	DF - Drinking Fountain	Flush	250	
45									
46									
47									
48									
49									
50									
51									
52									
53									
54									
55									
56									
57									
58									
59									
60									
61									
62									
63									
64									
65									
66									
67									
68									
69									
70									
71									
72									
73									
74									
75									
76									
77									
78									
79									
80									

11/17 SCOP