

Mr. Albert Tijerina
East Aurora School District 131
Director of Building and Grounds
411 Hill Avenue
Aurora, Illinois 60505

**RE: Lead Sampling in Potable Water
Fred Rogers Magnet Academy
157 North Root Street, Aurora, IL 60505**

Dear Mr. Tijerina:

The following letter report summarizes the laboratory results for the drinking water samples collected from the potable water sources at Fred Rogers Magnet Academy in Aurora, Illinois. The sampling was conducted on November 4, 2017 by Mr. Matthew Rodriguez of Weaver Consultants Group (WCG). Mr. Rodriguez conducted the sampling under the direction of Mr. David J. Kedrowski, CIH.

SCOPE OF WORK

The scope of work for this project involved collecting water samples from pre-identified water locations. The potable locations were provided to WCG by East Aurora School District 131. The collected potable water samples were then analyzed for lead by an accredited laboratory.

METHODOLOGY

WCG followed protocols set by U.S. Environmental Protection Agency (EPA) and Illinois Department of Public Health (IDPH) for testing schools for lead in drinking water. Representatives from East Aurora School District 131 confirmed the school was under normal use and ensured the water settled within the piping systems/fixtures for between eight (8) to eighteen (18) hours.

Forty-three (43) water samples from representative potable water locations were collected in 250 milliliter bottles. The water samples were collected as a "first draw" from each source to represent a lead concentration from water allowed to sit within the pipes or drinking reservoirs for at least eight (8) hours and not more than eighteen (18) hours. A second sample was collected from each location after a 30 second flush to represent water from within the building's localized water piping system. Potable water sources generally included drinking fountains, Nurses' Offices, Teachers' Lounges, kitchen faucets and preschool, kindergarten, and first floor classroom sinks, etc.

At the request of the District, non-potable samples were collected at the water main to the building to establish a baseline. As this is a non-potable source, the results likely do not represent water within the building system but rather sediment at the water main valve or within the sampling connections used to draw the sample. Water samples collected at each potable fixture should instead be relied upon as representative of the drinking water within the building.

Each sample was labeled with a unique sample number identifying the school. The samples were transported to Suburban Labs Incorporated (Suburban) in Geneva, Illinois. Samples were analyzed for lead content using EPA Method 200.8 "Determination of Trace Elements in Water using Inductively Coupled Plasma (ICP)/Mass Spectrometry (MS). Suburban is accredited to analyze lead in potable drinking water under the National Environmental Laboratory Accreditation Program (NELAP)

RESULTS

The results of the water sample analysis revealed that two (2) samples of the forty-three (43) collected had lead concentrations above the IDPH Action Level of 2 ppb ($\mu\text{g/L}$). All sample results that exceed 5 $\mu\text{g/L}$ should be promptly reported to parents or guardians of the enrolled students as required by the Illinois Department of Public Health (IDPH).

CONCLUSIONS AND RECOMMENDATIONS

- 1) Within 7 business days of receipt of test results, schools must email all results to IDPH at DPH.LeadH20@illinois.gov. **WCG will email these results on behalf of East Aurora School District 131.**
- 2) All sample results that exceed 5 $\mu\text{g/L}$ should be promptly reported to parents or guardians of all enrolled students in writing or electronically and include:
 - The location and source exceeding 5 $\mu\text{g/L}$.
 - The USEPA website for information about lead in drinking water, <https://www.epa.gov/ground-water-and-drinking-water/basic-information-about-lead-drinking-water>.
- 3) Implement corrective action for fixtures greater than 2 $\mu\text{g/L}$.
- 4) Implement best practices to minimize lead concentrations in drinking water.

BEST PRACTICES

Best practices for managing elevated lead concentrations in drinking water may include implementing a water quality management plan (WQMP), establishing a routine water flushing program for potable sources daily or during periods of low occupancy or low water usage, routine maintenance to clean screens and aerators, and confirmation sampling. In addition, occupants should avoid consuming water from non-potable sources i.e. classroom or office sinks, washroom sinks, maintenance closets, etc. and hot water taps.

A summary of the sample locations and results may be found in Appendix A and the laboratory report with chain of custody sheets may be found in Appendix B. We appreciate the opportunity to assist you on this important project.

Sincerely,

Weaver Consultants Group North Central, LLC



David J. Kedrowski, CIH
Senior Project Director

APPENDIX A

Lead in Potable Water Sample Results

**Fred Rogers Magnet Academy
157 North Root Street
Aurora, IL 60505**

ISBE ID	Sample Date	Sample Time (12 HR Clock)	Sample ID Number	Sample Location Description	Fixture Type	Date of Last Use	Time of Last Use (12 HR Clock)	Sample Type	Concentration (ug/L)
310451310222016	11/04/2017	07:36 AM	FREDR-01A	4th Floor-Tropy Case (Left)	DF- Drinking Fountain	11/3/2017	03:00 PM	First Draw	ND
310451310222016	11/04/2017	07:36 AM	FREDR-01AA	4th Floor-Tropy Case (Bottle Filler)	DF - Drinking Fountain	11/3/2017	03:00 PM	First Draw	ND
310451310222016	11/04/2017	07:36 AM	FREDR-01B	4th Floor-Tropy Case (Left)	DF - Drinking Fountain	11/3/2017	03:00 PM	Flush	ND
310451310222016	11/04/2017	07:36 AM	FREDR-02A	4th Floor-Tropy Case (Right)	DF - Drinking Fountain	11/3/2017	03:00 PM	First Draw	ND
310451310222016	11/04/2017	07:36 AM	FREDR-02B	4th Floor-Tropy Case (Right)	DF - Drinking Fountain	11/3/2017	03:00 PM	Flush	ND
310451310222016	11/04/2017	07:46 AM	FREDR-03A	3rd Floor- Rm.313 (Left)	DF - Drinking Fountain	11/3/2017	03:00 PM	First Draw	ND
310451310222016	11/04/2017	07:46 AM	FREDR-03AA	3rd Floor- Rm.313 (Bottle Filler)	DF - Drinking Fountain	11/3/2017	03:00 PM	First Draw	ND
310451310222016	11/04/2017	07:46 AM	FREDR-03B	3rd Floor- Rm.313 (Left)	DF - Drinking Fountain	11/3/2017	03:00 PM	Flush	ND
310451310222016	11/04/2017	07:46 AM	FREDR-04A	3rd Floor- Rm.313 (Right)	DF - Drinking Fountain	11/3/2017	03:00 PM	First Draw	ND
310451310222016	11/04/2017	07:46 AM	FREDR-04B	3rd Floor- Rm.313 (Right)	DF - Drinking Fountain	11/3/2017	03:00 PM	Flush	ND
310451310222016	11/04/2017	07:56 AM	FREDR-05A	2nd Floor-Main Office (Left)	DF - Drinking Fountain	11/3/2017	03:00 PM	First Draw	ND
310451310222016	11/04/2017	07:56 AM	FREDR-05AA	2nd Floor-Main Office (Bottle Filler)	DF - Drinking Fountain	11/3/2017	03:00 PM	First Draw	ND
310451310222016	11/04/2017	07:56 AM	FREDR-05B	2nd Floor-Main Office (Left)	DF - Drinking Fountain	11/3/2017	03:00 PM	Flush	ND
310451310222016	11/04/2017	07:56 AM	FREDR-06A	2nd Floor-Main Office (Right)	DF - Drinking Fountain	11/3/2017	03:00 PM	First Draw	ND
310451310222016	11/04/2017	07:56 AM	FREDR-06B	2nd Floor-Main Office (Right)	DF - Drinking Fountain	11/3/2017	03:00 PM	Flush	ND
310451310222016	11/04/2017	08:00 AM	FREDR-07A	2nd Floor-Nurse Office	S- Sink	11/3/2017	03:00 PM	First Draw	ND
310451310222016	11/04/2017	08:00 AM	FREDR-07B	2nd Floor-Nurse Office	S- Sink	11/3/2017	03:00 PM	Flush	ND
310451310222016	11/04/2017	08:05 AM	FREDR-08A	2nd Floor-Main Office-Rm.202	S- Sink	11/3/2017	03:00 PM	First Draw	ND
310451310222016	11/04/2017	08:05 AM	FREDR-08B	2nd Floor-Main Office-Rm.202	S- Sink	11/3/2017	03:00 PM	Flush	ND
310451310222016	11/04/2017	08:10 AM	FREDR-09A	2nd Floor-Facility Lounge	S- Sink	11/3/2017	03:00 PM	First Draw	ND
310451310222016	11/04/2017	08:10 AM	FREDR-09B	2nd Floor-Facility Lounge	S- Sink	11/3/2017	03:00 PM	Flush	ND
310451310222016	11/04/2017	08:15 AM	FREDR-10A	2nd Floor-Boys Bathroom	DF - Drinking Fountain	11/3/2017	03:00 PM	First Draw	ND
310451310222016	11/04/2017	08:15 AM	FREDR-10AA	2nd Floor-Boys Bathroom (Bottle Filler)	DF - Drinking Fountain	11/3/2017	03:00 PM	First Draw	ND
310451310222016	11/04/2017	08:15 AM	FREDR-10B	2nd Floor-Boys Bathroom	DF - Drinking Fountain	11/3/2017	03:00 PM	Flush	ND
310451310222016	11/04/2017	08:24 AM	FREDR-11A	1st Floor-By Rm. 122	DF - Drinking Fountain	11/3/2017	03:00 PM	First Draw	ND
310451310222016	11/04/2017	08:24 AM	FREDR-11B	1st Floor-By Rm. 122	DF - Drinking Fountain	11/3/2017	03:00 PM	Flush	ND
310451310222016	11/04/2017	08:36 AM	FREDR-12A	1st Floor-By Janitor Closet 103 (Left)	DF - Drinking Fountain	11/3/2017	03:00 PM	First Draw	ND
310451310222016	11/04/2017	08:36 AM	FREDR-12AA	1st Floor-By Janitor Closet 103 (Bottle Filler)	DF - Drinking Fountain	11/3/2017	03:00 PM	First Draw	ND
310451310222016	11/04/2017	08:36 AM	FREDR-12B	1st Floor-By Janitor Closet 103 (Left)	DF - Drinking Fountain	11/3/2017	03:00 PM	Flush	ND
310451310222016	11/04/2017	08:36 AM	FREDR-13A	1st Floor-By Janitor Closet 103 (Right)	DF - Drinking Fountain	11/3/2017	03:00 PM	First Draw	ND
310451310222016	11/04/2017	08:36 AM	FREDR-13B	1st Floor-By Janitor Closet 103 (Right)	DF - Drinking Fountain	11/3/2017	03:00 PM	Flush	ND
310451310222016	11/04/2017	08:34 AM	FREDR-14A	1st Floor-Water Line	O - Other	11/3/2017	03:00 PM	First Draw	10.5
310451310222016	11/04/2017	08:34 AM	FREDR-14B	1st Floor-Water Line	O - Other	11/3/2017	03:00 PM	Flush	6.01
310451310222016	11/04/2017	08:37 AM	FREDR-15A	1st Floor-Kitchen -2 Spout (Left)	KS - Kitchen Sink	11/3/2017	03:00 PM	First Draw	ND
310451310222016	11/04/2017	08:37 AM	FREDR-15B	1st Floor-Kitchen -2 Spout (Left)	KS - Kitchen Sink	11/3/2017	03:00 PM	Flush	ND
310451310222016	11/04/2017	08:37 AM	FREDR-16A	1st Floor-Kitchen -2 Spout (Right)	KS - Kitchen Sink	11/3/2017	03:00 PM	First Draw	ND
310451310222016	11/04/2017	08:37 AM	FREDR-16B	1st Floor-Kitchen -2 Spout (Right)	KS - Kitchen Sink	11/3/2017	03:00 PM	Flush	ND
310451310222016	11/04/2017	08:40 AM	FREDR-17A	1st Floor-Kitchen Side Sink	S- Sink	11/3/2017	03:00 PM	First Draw	ND
310451310222016	11/04/2017	08:40 AM	FREDR-17B	1st Floor-Kitchen Side Sink	S- Sink	11/3/2017	03:00 PM	Flush	ND
310451310222016	11/04/2017	08:45 AM	FREDR-18A	1st Floor-Kitchen Hand Sink	S- Sink	11/3/2017	03:00 PM	First Draw	ND
310451310222016	11/04/2017	08:45 AM	FREDR-18B	1st Floor-Kitchen Hand Sink	S- Sink	11/3/2017	03:00 PM	Flush	ND
310451310222016	11/04/2017	08:46 AM	FREDR-19A	1st Floor-Entrance 7	DF - Drinking Fountain	11/3/2017	03:00 PM	First Draw	ND
310451310222016	11/04/2017	08:46 AM	FREDR-19B	1st Floor-Entrance 7	DF - Drinking Fountain	11/3/2017	03:00 PM	Flush	ND

APPENDIX B
Laboratory Results and Chain of Custody Documentation

SUBURBAN LABORATORIES, Inc.



1950 S. Batavia Ave., Suite 150 Geneva, Illinois 60134
Tel. (708) 544-3260 • Toll Free (800) 783-LABS
Fax (708) 544-8587
www.suburbanlabs.com

November 20, 2017

Olivia Reynhout
Weaver Consultants Group
1316 Bond St - Suite 108
Naperville, IL 60563

Workorder: 1711531

TEL: (630) 717-4848

FAX: (630) 717-4850

RE: Fred Rogers Magnet Academy Drinking Water Lead Analysis

Dear Olivia Reynhout:

Suburban Laboratories, Inc. received 43 sample(s) on 11/7/2017 for the analyses presented in the following report.

Customer has provided 250 mL volume sample bottles for all samples collected. Please note, all sample results that exceed 5.00 ug/L should be promptly reported to parents or guardians of all enrolled students. Results that are below 5.00 ug/L should be reported on the school website. Please refer to Public Act 099-0922 or the Illinois Department of Public Health for specific reporting requirements. Suburban Laboratories will forward all results to the IDPH within seven (7) business days from the date of this report.

This report may not be reproduced, except in full, without the prior written approval of Suburban Laboratories, Inc. If you have any questions regarding these test results, please call me at (708) 544-3260.

Sincerely,



Pat Rodriguez
Project Manager
708-544-3260 ext 214
pat@suburbanlabs.com



SUBURBAN LABORATORIES, Inc.



1950 S. Batavia Ave., Suite 150 Geneva, Illinois 60134
Tel. (708) 544-3260 • Toll Free (800) 783-LABS
Fax (708) 544-8587
www.suburbanlabs.com

Client ID: Weaver Consultants Group

Report Date: November 20, 2017

Project Name: Fred Rogers Magnet Academy Drinking Water Lead Anal

Workorder: 1711531

Analyte: Lead

Method: EPA 200.8

Matrix: Drinking Water

Sample ID	Client Sample ID	Result	MRL	Units	Date & Time Water System Last Used	Date Collected	Date Analyzed
1711531-001A	FREDR-01A~4th Floor-Tropy Case (Left)~First Draw	ND	2.00	µg/L	11/04/2017 15:00	11/4/2017	11/11/2017
1711531-002A	FREDR-01AA~4th Floor-Tropy Case (Bottle Filler) (Left)~First Draw	ND	2.00	µg/L	11/04/2017 15:00	11/4/2017	11/11/2017
1711531-003A	FREDR-01B~4th Floor-Tropy Case (Left)~Flush	ND	2.00	µg/L	11/04/2017 15:00	11/4/2017	11/11/2017
1711531-004A	FREDR-02A~4th Floor-Tropy Case (Right)~First Draw	ND	2.00	µg/L	11/04/2017 15:00	11/4/2017	11/11/2017
1711531-005A	FREDR-02B~4th Floor-Tropy Case (Right)~Flush	ND	2.00	µg/L	11/04/2017 15:00	11/4/2017	11/11/2017
1711531-006A	FREDR-03A~3rd Floor-Rm.313 (Left)~First Draw	ND	2.00	µg/L	11/04/2017 15:00	11/4/2017	11/11/2017
1711531-007A	FREDR-03AA~3rd Floor-Rm.313 (Bottle Filler) (Left)~First Draw	ND	2.00	µg/L	11/04/2017 15:00	11/4/2017	11/11/2017
1711531-008A	FREDR-03B~3rd Floor-Rm.313 (Left)~Flush	ND	2.00	µg/L	11/04/2017 15:00	11/4/2017	11/11/2017
1711531-009A	FREDR-04A~3rd Floor-Rm.313 (Right)~First Draw	ND	2.00	µg/L	11/04/2017 15:00	11/4/2017	11/11/2017
1711531-010A	FREDR-04B~3rd Floor-Rm.313 (Right)~Flush	ND	2.00	µg/L	11/04/2017 15:00	11/4/2017	11/11/2017
1711531-011A	FREDR-05A~2nd Floor-Main Office (Left)~First Draw	ND	2.00	µg/L	11/04/2017 15:00	11/4/2017	11/11/2017
1711531-012A	FREDR-05AA~2nd Floor-Main Office (Bottle Filler) (Left)~First Draw	ND	2.00	µg/L	11/04/2017 15:00	11/4/2017	11/11/2017
1711531-013A	FREDR-05B~2nd Floor-Main Office (Left)~Flush	ND	2.00	µg/L	11/04/2017 15:00	11/4/2017	11/11/2017
1711531-014A	FREDR-06A~2nd Floor-Main Office (Right)~First Draw	ND	2.00	µg/L	11/04/2017 15:00	11/4/2017	11/11/2017
1711531-015A	FREDR-06B~2nd Floor-Main Office (Right)~Flush	ND	2.00	µg/L	11/04/2017 15:00	11/4/2017	11/11/2017
1711531-016A	FREDR-07A~2nd Floor-Nurse Office~First Draw	ND	2.00	µg/L	11/04/2017 15:00	11/4/2017	11/11/2017
1711531-017A	FREDR-07B~2nd Floor-Nurse Office~Flush	ND	2.00	µg/L	11/04/2017 15:00	11/4/2017	11/11/2017
1711531-018A	FREDR-08A~2nd Floor-Main Office-Rm.202~First Draw	ND	2.00	µg/L	11/04/2017 15:00	11/4/2017	11/11/2017
1711531-019A	FREDR-08B~2nd Floor-Main Office-Rm.202~Flush	ND	2.00	µg/L	11/04/2017 15:00	11/4/2017	11/11/2017
1711531-020A	FREDR-09A~2nd Floor-Facility Lounge~First Draw	ND	2.00	µg/L	11/04/2017 15:00	11/4/2017	11/11/2017
1711531-021A	FREDR-09B~2nd Floor-Facility Lounge~Flush	ND	2.00	µg/L	11/04/2017 15:00	11/4/2017	11/11/2017

ND - Not Detected Down to the Laboratory Minimum Reporting Limit (MRL)

SUBURBAN LABORATORIES, Inc.



1950 S. Batavia Ave., Suite 150 Geneva, Illinois 60134
 Tel. (708) 544-3260 • Toll Free (800) 783-LABS
 Fax (708) 544-8587
 www.suburbanlabs.com

Client ID: Weaver Consultants Group

Report Date: November 20, 2017

Project Name: Fred Rogers Magnet Academy Drinking Water Lead Anal

Workorder: 1711531

Analyte: Lead

Method: EPA 200.8

Matrix: Drinking Water

Sample ID	Client Sample ID	Result	MRL	Units	Date & Time Water System Last Used	Date Collected	Date Analyzed
1711531-022A	FREDR-10A~2nd Floor-Boys Bathroom~First Draw	ND	2.00	µg/L	11/04/2017 15:00	11/4/2017	11/11/2017
1711531-023A	FREDR-10AA~2nd Floor-Boys Bathroom (Bottle Filler)~First Draw	ND	2.00	µg/L	11/04/2017 15:00	11/4/2017	11/11/2017
1711531-024A	FREDR-10B~2nd Floor-Boys Bathroom~Flush	ND	2.00	µg/L	11/04/2017 15:00	11/4/2017	11/11/2017
1711531-025A	FREDR-11A~1st Floor-By Rm. 122~First Draw	ND	2.00	µg/L	11/04/2017 15:00	11/4/2017	11/11/2017
1711531-026A	FREDR-11B~1st Floor-By Rm. 122~Flush	ND	2.00	µg/L	11/04/2017 15:00	11/4/2017	11/11/2017
1711531-027A	FREDR-12A~1st Floor-By janitor Closet 103 (Left)~First Draw	ND	2.00	µg/L	11/04/2017 15:00	11/4/2017	11/11/2017
1711531-028A	FREDR-12AA~1st Floor-By janitor Closet 103 (Bottle Filler) (Left)~First Draw	ND	2.00	µg/L	11/04/2017 15:00	11/4/2017	11/11/2017
1711531-029A	FREDR-12B~1st Floor-By janitor Closet 103 (Left)~Flush	ND	2.00	µg/L	11/04/2017 15:00	11/4/2017	11/11/2017
1711531-030A	FREDR-13A~1st Floor-By janitor Closet 103 (Right)~First Draw	ND	2.00	µg/L	11/04/2017 15:00	11/4/2017	11/11/2017
1711531-031A	FREDR-13B~1st Floor-By janitor Closet 103 (Right)~Flush	ND	2.00	µg/L	11/04/2017 15:00	11/4/2017	11/11/2017
1711531-032A	FREDR-14A~1st Floor-Water Line~First Draw	10.5	2.00	µg/L	11/04/2017 15:00	11/4/2017	11/11/2017
1711531-033A	FREDR-14B~1st Floor-Water Line~Flush	6.01	2.00	µg/L	11/04/2017 15:00	11/4/2017	11/11/2017
1711531-034A	FREDR-15A~1st Floor-Kitchen (2 Spout) (Left)~First Draw	ND	2.00	µg/L	11/04/2017 15:00	11/4/2017	11/11/2017
1711531-035A	FREDR-15B~1st Floor-Kitchen (Left)~Flush	ND	2.00	µg/L	11/04/2017 15:00	11/4/2017	11/11/2017
1711531-036A	FREDR-16A~1st Floor-Kitchen (Right)~First Draw	ND	2.00	µg/L	11/04/2017 15:00	11/4/2017	11/11/2017
1711531-037A	FREDR-16B~1st Floor-Kitchen (Right)~Flush	ND	2.00	µg/L	11/04/2017 15:00	11/4/2017	11/11/2017
1711531-038A	FREDR-17A~1st Floor-Kitchen Side Sink~First Draw	ND	2.00	µg/L	11/04/2017 15:00	11/4/2017	11/11/2017
1711531-039A	FREDR-17B~1st Floor-Kitchen Side Sink~Flush	ND	2.00	µg/L	11/04/2017 15:00	11/4/2017	11/11/2017
1711531-040A	FREDR-18A~1st Floor-Kitchen Hand Sink~First Draw	ND	2.00	µg/L	11/04/2017 15:00	11/4/2017	11/11/2017
1711531-041A	FREDR-18B~1st Floor-Kitchen Hand Sink~Flush	ND	2.00	µg/L	11/04/2017 15:00	11/4/2017	11/11/2017

ND - Not Detected Down to the Laboratory Minimum Reporting Limit (MRL)

SUBURBAN LABORATORIES, Inc.



1950 S. Batavia Ave., Suite 150 Geneva, Illinois 60134
Tel. (708) 544-3260 • Toll Free (800) 783-LABS
Fax (708) 544-8587
www.suburbanlabs.com

Client ID: Weaver Consultants Group

Report Date: November 20, 2017

Project Name: Fred Rogers Magnet Academy Drinking Water Lead Anal

Workorder: 1711531

Analyte: Lead

Method: EPA 200.8

Matrix: Drinking Water

Sample ID	Client Sample ID	Result	MRL	Units	Date & Time Water System Last Used	Date Collected	Date Analyzed
1711531-042A	FREDR-19A~1st Floor-Entrance 7~First Draw	ND	2.00	µg/L	11/04/2017 15:00	11/4/2017	11/11/2017
1711531-043A	FREDR-19B~1st Floor-Entrance 7~Flush	ND	2.00	µg/L	11/04/2017 15:00	11/4/2017	11/11/2017

1711531-001A-43A

FIELD DATA FORM

School/Facility Name
Fred Rogers Magnet Academy
ISBE ID: (ex:01-001-001-01-00001)
310451310222016

Address
157 N Root St
Aurora, IL 60505

Sample Collector Name(s)
Matthew Rodriguez

MMDYY 11/04/2017 Time: HH24MM 15:00

Water system last used Date:

All samples must be collected in unpreserved

Bldg. ID	Bldg. Desc	Sample ID#	Sample Loc. Desc	Collection Date MMDDYYYY	Collection Time HH24MM	Fixture Type	Sample Type	Sample Vol.	Notes
0001	Main Building	01	1st Floor Classroom	02232017	800	O - Other	First Draw	250	Description If "Other" Is Selected
0001	Main Building	01A	1st Floor Classroom	02232017	800	S - Sink	Flush	250	
1	School	FREDR-01A	4th Floor-Tropy Case (Left)	11/04/2017	7:35	DF - Drinking Fountain	First Draw	250	
1	School	FREDR-01AA	4th Floor-Tropy Case (Bottle Filler) (Left)	11/04/2017	7:35	DF - Drinking Fountain	First Draw	250	
2	School	FREDR-01B	4th Floor-Tropy Case (Left)	11/04/2017	7:35	DF - Drinking Fountain	Flush	250	
3	School	FREDR-02A	4th Floor-Tropy Case (Right)	11/04/2017	7:35	DF - Drinking Fountain	First Draw	250	
4	School	FREDR-02B	4th Floor-Tropy Case (Right)	11/04/2017	7:35	DF - Drinking Fountain	Flush	250	
5	School	FREDR-03A	3rd Floor-Rm.313 (Left)	11/04/2017	7:45	DF - Drinking Fountain	First Draw	250	
5	School	FREDR-03AA	3rd Floor-Rm.313 (Bottle Filler) (Left)	11/04/2017	7:45	DF - Drinking Fountain	First Draw	250	
6	School	FREDR-03B	3rd Floor-Rm.313 (Left)	11/04/2017	7:45	DF - Drinking Fountain	Flush	250	
7	School	FREDR-04A	3rd Floor-Rm.313 (Right)	11/04/2017	7:45	DF - Drinking Fountain	First Draw	250	
8	School	FREDR-04B	3rd Floor-Rm.313 (Right)	11/04/2017	7:45	DF - Drinking Fountain	Flush	250	
9	School	FREDR-05A	2nd Floor-Main Office (Left)	11/04/2017	7:55	DF - Drinking Fountain	First Draw	250	
10	School	FREDR-05AA	2nd Floor-Main Office (Bottle Filler) (Left)	11/04/2017	7:55	DF - Drinking Fountain	First Draw	250	
11	School	FREDR-05B	2nd Floor-Main Office (Left)	11/04/2017	7:55	DF - Drinking Fountain	Flush	250	
11	School	FREDR-06A	2nd Floor-Main Office (Right)	11/04/2017	7:55	DF - Drinking Fountain	First Draw	250	
12	School	FREDR-06B	2nd Floor-Main Office (Right)	11/04/2017	7:55	DF - Drinking Fountain	Flush	250	
13	School	FREDR-07A	2nd Floor-Nurse Office	11/04/2017	8:00	S - Sink	First Draw	250	
14	School	FREDR-07B	2nd Floor-Nurse Office	11/04/2017	8:00	S - Sink	Flush	250	
15	School	FREDR-08A	2nd Floor-Main Office-Rm.202	11/04/2017	8:05	S - Sink	First Draw	250	
16	School	FREDR-08B	2nd Floor-Main Office-Rm.202	11/04/2017	8:05	S - Sink	Flush	250	
17	School	FREDR-09A	2nd Floor-Faculty Lounge	11/04/2017	8:10	S - Sink	First Draw	250	
18	School	FREDR-09B	2nd Floor-Faculty Lounge	11/04/2017	8:10	S - Sink	Flush	250	
19	School	FREDR-10A	2nd Floor-Boys Bathroom	11/04/2017	8:15	DF - Drinking Fountain	First Draw	250	
20	School	FREDR-10AA	2nd Floor-Boys Bathroom (Bottle Filler)	11/04/2017	8:15	DF - Drinking Fountain	First Draw	250	
21	School	FREDR-10B	2nd Floor-Boys Bathroom	11/04/2017	8:15	DF - Drinking Fountain	Flush	250	
22	School	FREDR-11A	1st Floor-By Rm. 122	11/04/2017	8:24	DF - Drinking Fountain	First Draw	250	
23	School	FREDR-11B	1st Floor-By Rm. 122	11/04/2017	8:24	DF - Drinking Fountain	Flush	250	
24	School	FREDR-12A	1st Floor-By Janitor Closet 103 (Left)	11/04/2017	8:36	DF - Drinking Fountain	First Draw	250	
25	School	FREDR-12AA	1st Floor-By Janitor Closet 103 (Bottle Filler) (Left)	11/04/2017	8:36	DF - Drinking Fountain	First Draw	250	
26	School	FREDR-12B	1st Floor-By Janitor Closet 103 (Left)	11/04/2017	8:36	DF - Drinking Fountain	Flush	250	
27	School	FREDR-13A	1st Floor-By Janitor Closet 103 (Right)	11/04/2017	8:36	DF - Drinking Fountain	First Draw	250	
28	School	FREDR-13B	1st Floor-By Janitor Closet 103 (Right)	11/04/2017	8:36	DF - Drinking Fountain	Flush	250	
29	School	FREDR-14A	1st Floor-Water Line	11/04/2017	8:34	O - Other	First Draw	250	
30	School	FREDR-14B	1st Floor-Water Line	11/04/2017	8:34	O - Other	Flush	250	
31	School	FREDR-15A	1st Floor-Kitchen (2 Spout) (Left)	11/04/2017	8:37	KS - Kitchen Sink	First Draw	250	
32	School	FREDR-15B	1st Floor-Kitchen (Left)	11/04/2017	8:37	KS - Kitchen Sink	Flush	250	
33	School	FREDR-16A	1st Floor-Kitchen (Right)	11/04/2017	8:37	KS - Kitchen Sink	First Draw	250	
34	School	FREDR-16B	1st Floor-Kitchen (Right)	11/04/2017	8:37	KS - Kitchen Sink	Flush	250	
35	School	FREDR-17A	1st Floor-Kitchen Side Sink	11/04/2017	8:40	S - Sink	First Draw	250	
36	School	FREDR-17B	1st Floor-Kitchen Side Sink	11/04/2017	8:40	S - Sink	Flush	250	
37	School	FREDR-18A	1st Floor-Kitchen Hand Sink	11/04/2017	8:45	S - Sink	First Draw	250	
38	School	FREDR-18B	1st Floor-Kitchen Hand Sink	11/04/2017	8:45	S - Sink	Flush	250	
39	School	FREDR-19A	1st Floor-Entrance 7	11/04/2017	8:45	DF - Drinking Fountain	First Draw	250	
40	School	FREDR-19B	1st Floor-Entrance 7	11/04/2017	8:45	DF - Drinking Fountain	Flush	250	
41									
42									
43									
44									
45									
46									
47									
48									
49									
50									
51									
52									
53									
54									
55									
56									
57									
58									
59									
60									
61									
62									
63									
64									
65									
66									
67									
68									
69									
70									
71									
72									
73									
74									
75									
76									
77									
78									
79									
80									
81									
82									

11/7/17 5:00P