

Mr. Albert Tijerina
East Aurora School District 131
Director of Building and Grounds
411 Hill Avenue
Aurora, Illinois 60505

**RE: Lead Sampling in Potable Water
Hermes Elementary School
1000 Jungles Ave, Aurora, IL 60505**

Dear Mr. Tijerina:

The following letter report summarizes the laboratory results for the drinking water samples collected from the potable water sources at Hermes Elementary School in Aurora, Illinois. The sampling was conducted on November 4, 2017 by Mr. Alade Ogunbiyi of Weaver Consultants Group (WCG). Mr. Ogunbiyi conducted the sampling under the direction of Mr. David J. Kedrowski, CIH.

SCOPE OF WORK

The scope of work for this project involved collecting water samples from pre-identified water locations. The potable locations were provided to WCG by East Aurora School District 131. The collected potable water samples were then analyzed for lead by an accredited laboratory.

METHODOLOGY

WCG followed protocols set by U.S. Environmental Protection Agency (EPA) and Illinois Department of Public Health (IDPH) for testing schools for lead in drinking water. Representatives from East Aurora School District 131 confirmed the school was under normal use and ensured the water settled within the piping systems/fixtures for between eight (8) to eighteen (18) hours.

One hundred and four (104) water samples from representative potable water locations were collected in 250 milliliter bottles. The water samples were collected as a “first draw” from each source to represent a lead concentration from water allowed to sit within the pipes or drinking reservoirs for at least eight (8) hours and not more than eighteen (18) hours. A second sample was collected from each location after a 30 second flush to represent water from within the building’s localized water piping system. Potable water sources generally included drinking fountains, Nurses’ Offices, Teachers’ Lounges, kitchen faucets and preschool, kindergarten, and first floor classroom sinks, etc.

At the request of the District, non-potable samples were collected at the water main to the building to establish a baseline. As this is a non-potable source, the results likely do not represent water within the building system but rather sediment at the water main valve or within the sampling connections used to draw the sample. Water samples collected at each potable fixture should instead be relied upon as representative of the drinking water within the building.

Each sample was labeled with a unique sample number identifying the school. The samples were transported to Suburban Labs Incorporated (Suburban) in Geneva, Illinois. Samples were analyzed for lead content using EPA Method 200.8 "Determination of Trace Elements in Water using Inductively Coupled Plasma (ICP)/Mass Spectrometry (MS). Suburban is accredited to analyze lead in potable drinking water under the National Environmental Laboratory Accreditation Program (NELAP).

RESULTS

The results of the water sample analysis revealed that forty-three (43) samples of the one hundred and four (104) collected had lead concentrations above the IDPH Action Level of 2 ppb ($\mu\text{g/L}$). All sample results that exceed 5 $\mu\text{g/L}$ should be promptly reported to parents or guardians of the enrolled students as required by the Illinois Department of Public Health (IDPH).

CONCLUSIONS AND RECOMMENDATIONS

- 1) Within 7 business days of receipt of test results, schools must email all results to IDPH at DPH.LeadH20@illinois.gov. **WCG will email these results on behalf of East Aurora School District 131.**
- 2) All sample results that exceed 5 $\mu\text{g/L}$ should be promptly reported to parents or guardians of all enrolled students in writing or electronically and include:
 - The location and source exceeding 5 $\mu\text{g/L}$.
 - The USEPA website for information about lead in drinking water, <https://www.epa.gov/ground-water-and-drinking-water/basic-information-about-lead-drinking-water>.
- 3) Implement corrective action for fixtures greater than 2 $\mu\text{g/L}$.
- 4) Implement best practices to minimize lead concentrations in drinking water.

BEST PRACTICES

Best practices for managing elevated lead concentrations in drinking water may include implementing a water quality management plan (WQMP), establishing a routine water flushing program for potable sources daily or during periods of low occupancy or low water usage, routine maintenance to clean screens and aerators, and confirmation sampling. In addition, occupants should avoid consuming water from non-potable sources i.e. classroom or office sinks, washroom sinks, maintenance closets, etc. and hot water taps.

A summary of the sample locations and results may be found in Appendix A and the laboratory report with chain of custody sheets may be found in Appendix B. We appreciate the opportunity to assist you on this important project.

Sincerely,

Weaver Consultants Group North Central, LLC



David J. Kedrowski, CIH
Senior Project Director

APPENDIX A
Lead in Potable Water Sample Results

Hermes Elementary School
1000 Jungles Ave
Aurora, IL 60505

ISBE ID	Sample Date	Sample Time (12 HR Clock)	Sample ID Number	Sample Location Description	Fixture Type	Date of Last Use	Time of Last Use (12 HR Clock)	Sample Type	Concentration (ug/L)
310451310222010	11/04/2017	06:35 AM	HER-01A	Classroom 101 (Stainless Steel)	S - Sink	11/03/2017	09:00 PM	First Draw	2.73
310451310222010	11/04/2017	06:35 AM	HER-01B	Classroom 101 (Stainless Steel)	S - Sink	11/03/2017	09:00 PM	Flush	ND
310451310222010	11/04/2017	06:35 AM	HER-02A	Classroom 101 (Porcelain)	S - Sink	11/03/2017	09:00 PM	First Draw	4.5
310451310222010	11/04/2017	06:35 AM	HER-02B	Classroom 101 (Porcelain)	S - Sink	11/03/2017	09:00 PM	Flush	2.04
310451310222010	11/04/2017	06:40 AM	HER-03A	Classroom 102	S - Sink	11/03/2017	09:00 PM	First Draw	2.47
310451310222010	11/04/2017	06:40 AM	HER-03B	Classroom 102	S - Sink	11/03/2017	09:00 PM	Flush	ND
310451310222010	11/04/2017	06:43 AM	HER-04A	Classroom 104	S - Sink	11/03/2017	09:00 PM	First Draw	3.39
310451310222010	11/04/2017	06:43 AM	HER-04B	Classroom 104	S - Sink	11/03/2017	09:00 PM	Flush	ND
310451310222010	11/04/2017	06:45 AM	HER-05A	Classroom 106	S - Sink	11/03/2017	09:00 PM	First Draw	3.77
310451310222010	11/04/2017	06:45 AM	HER-05B	Classroom 106	S - Sink	11/03/2017	09:00 PM	Flush	ND
310451310222010	11/04/2017	06:47 AM	HER-06A	Classroom 105	S - Sink	11/03/2017	09:00 PM	First Draw	4.59
310451310222010	11/04/2017	06:47 AM	HER-06B	Classroom 105	S - Sink	11/03/2017	09:00 PM	Flush	ND
310451310222010	11/04/2017	06:48 AM	HER-07A	Classroom 105 - Main Line	O - Other	11/03/2017	09:00 PM	First Draw	192
310451310222010	11/04/2017	06:48 AM	HER-07B	Classroom 105 - Main Line	O - Other	11/03/2017	09:00 PM	Flush	67.7
310451310222010	11/04/2017	06:51 AM	HER-08A	Classroom 108	S - Sink	11/03/2017	09:00 PM	First Draw	4.37
310451310222010	11/04/2017	06:51 AM	HER-08B	Classroom 108	S - Sink	11/03/2017	09:00 PM	Flush	ND
310451310222010	11/04/2017	06:53 AM	HER-09A	Corridor by Room 108	DF - Drinking Fountain	11/03/2017	09:00 PM	First Draw	4.49
310451310222010	11/04/2017	06:53 AM	HER-09B	Corridor by Room 108	DF - Drinking Fountain	11/03/2017	09:00 PM	Flush	10.8
310451310222010	11/04/2017	06:55 AM	HER-10A	Corridor by Office	DF - Drinking Fountain	11/03/2017	09:00 PM	First Draw	ND
310451310222010	11/04/2017	06:55 AM	HER-10B	Corridor by Office	DF - Drinking Fountain	11/03/2017	09:00 PM	Flush	ND
310451310222010	11/04/2017	06:57 AM	HER-11A	Main Office Storage	S - Sink	11/03/2017	09:00 PM	First Draw	7.06
310451310222010	11/04/2017	06:57 AM	HER-11B	Main Office Storage	S - Sink	11/03/2017	09:00 PM	Flush	ND
310451310222010	11/04/2017	06:59 AM	HER-12A	Classroom 112	S - Sink	11/03/2017	09:00 PM	First Draw	10.3
310451310222010	11/04/2017	06:59 AM	HER-12B	Classroom 112	S - Sink	11/03/2017	09:00 PM	Flush	9.06
310451310222010	11/04/2017	07:03 AM	HER-13A	Classroom 113	S - Sink	11/03/2017	09:00 PM	First Draw	32.8
310451310222010	11/04/2017	07:03 AM	HER-13B	Classroom 113	S - Sink	11/03/2017	09:00 PM	Flush	ND
310451310222010	11/04/2017	07:05 AM	HER-14A	Classroom 114	S - Sink	11/03/2017	09:00 PM	First Draw	10.9
310451310222010	11/04/2017	07:05 AM	HER-14B	Classroom 114	S - Sink	11/03/2017	09:00 PM	Flush	ND
310451310222010	11/04/2017	07:07 AM	HER-15A	Corridor by (2028) Girl's Bathroom	DF - Drinking Fountain	11/03/2017	09:00 PM	First Draw	ND
310451310222010	11/04/2017	07:07 AM	HER-15B	Corridor by (2028) Girl's Bathroom	DF - Drinking Fountain	11/03/2017	09:00 PM	Flush	ND
310451310222010	11/04/2017	07:09 AM	HER-16A	Room 204A - Nurse's Office	S - Sink	11/03/2017	09:00 PM	First Draw	16.7
310451310222010	11/04/2017	07:09 AM	HER-16B	Room 204A - Nurse's Office	S - Sink	11/03/2017	09:00 PM	Flush	ND
310451310222010	11/04/2017	07:10 AM	HER-17A	Room 206	S - Sink	11/03/2017	09:00 PM	First Draw	11.3
310451310222010	11/04/2017	07:10 AM	HER-17B	Room 206	S - Sink	11/03/2017	09:00 PM	Flush	ND
310451310222010	11/04/2017	07:12 AM	HER-18A	Room 203	S - Sink	11/03/2017	09:00 PM	First Draw	6.18
310451310222010	11/04/2017	07:12 AM	HER-18B	Room 203	S - Sink	11/03/2017	09:00 PM	Flush	ND
310451310222010	11/04/2017	07:13 AM	HER-19A	Room 208	S - Sink	11/03/2017	09:00 PM	First Draw	7.57
310451310222010	11/04/2017	07:13 AM	HER-19B	Room 208	S - Sink	11/03/2017	09:00 PM	Flush	2.66
310451310222010	11/04/2017	07:15 AM	HER-20A	Room 205	S - Sink	11/03/2017	09:00 PM	First Draw	5.65
310451310222010	11/04/2017	07:15 AM	HER-20B	Room 205	S - Sink	11/03/2017	09:00 PM	Flush	ND
310451310222010	11/04/2017	07:16 AM	HER-21A	Corridor by Mechanical Room	DF - Drinking Fountain	11/03/2017	09:00 PM	First Draw	ND
310451310222010	11/04/2017	07:16 AM	HER-21B	Corridor by Mechanical Room	DF - Drinking Fountain	11/03/2017	09:00 PM	Flush	4.44
310451310222010	11/04/2017	07:17 AM	HER-22A	Room 308	S - Sink	11/03/2017	09:00 PM	First Draw	173
310451310222010	11/04/2017	07:17 AM	HER-22B	Room 308	S - Sink	11/03/2017	09:00 PM	Flush	ND
310451310222010	11/04/2017	07:19 AM	HER-23A	Room 309	S - Sink	11/03/2017	09:00 PM	First Draw	32
310451310222010	11/04/2017	07:19 AM	HER-23B	Room 309	S - Sink	11/03/2017	09:00 PM	Flush	5.17
310451310222010	11/04/2017	07:21 AM	HER-24A	Room 310	S - Sink	11/03/2017	09:00 PM	First Draw	61.1
310451310222010	11/04/2017	07:21 AM	HER-24B	Room 310	S - Sink	11/03/2017	09:00 PM	Flush	30.3
310451310222010	11/04/2017	07:24 AM	HER-25A	Classroom 311	S - Sink	11/03/2017	09:00 PM	First Draw	66.6

ISBE ID	Sample Date	Sample Time (12 HR Clock)	Sample ID Number	Sample Location Description	Fixture Type	Date of Last Use	Time of Last Use (12 HR Clock)	Sample Type	Concentration (ug/L)
310451310222010	11/04/2017	07:24 AM	HER-25B	Classroom 311	S - Sink	11/03/2017	09:00 PM	Flush	56.5
310451310222010	11/04/2017	07:26 AM	HER-26A	Corridor by Room 312	DF - Drinking Fountain	11/03/2017	09:00 PM	First Draw	ND
310451310222010	11/04/2017	07:26 AM	HER-26B	Corridor by Room 312	DF - Drinking Fountain	11/03/2017	09:00 PM	Flush	ND
310451310222010	11/04/2017	07:28 AM	HER-27A	Classroom 312	S - Sink	11/03/2017	09:00 PM	First Draw	56.8
310451310222010	11/04/2017	07:28 AM	HER-27B	Classroom 312	S - Sink	11/03/2017	09:00 PM	Flush	34.7
310451310222010	11/04/2017	07:29 AM	HER-28A	Corridor by (503A) Boy's Bathroom (Stainless Steel)	DF - Drinking Fountain	11/03/2017	09:00 PM	First Draw	ND
310451310222010	11/04/2017	07:29 AM	HER-28B	Corridor by (503A) Boy's Bathroom (Stainless Steel)	DF - Drinking Fountain	11/03/2017	09:00 PM	Flush	ND
310451310222010	11/04/2017	07:29 AM	HER-29A	Corridor by (503A) Boy's Bathroom (Painted Face)	DF - Drinking Fountain	11/03/2017	09:00 PM	First Draw	ND
310451310222010	11/04/2017	07:29 AM	HER-29B	Corridor by (503A) Boy's Bathroom (Painted Face)	DF - Drinking Fountain	11/03/2017	09:00 PM	Flush	ND
310451310222010	11/04/2017	07:33 AM	HER-30A	Room 504 - Staff Lounge	S - Sink	11/03/2017	09:00 PM	First Draw	ND
310451310222010	11/04/2017	07:33 AM	HER-30B	Room 504 - Staff Lounge	S - Sink	11/03/2017	09:00 PM	Flush	ND
310451310222010	11/04/2017	07:35 AM	HER-31A	Classroom 506	S - Sink	11/03/2017	09:00 PM	First Draw	ND
310451310222010	11/04/2017	07:35 AM	HER-31B	Classroom 506	S - Sink	11/03/2017	09:00 PM	Flush	ND
310451310222010	11/04/2017	07:37 AM	HER-32A	Classroom 505	S - Sink	11/03/2017	09:00 PM	First Draw	ND
310451310222010	11/04/2017	07:37 AM	HER-32B	Classroom 505	S - Sink	11/03/2017	09:00 PM	Flush	ND
310451310222010	11/04/2017	07:38 AM	HER-33A	Classroom 507	S - Sink	11/03/2017	09:00 PM	First Draw	29.2
310451310222010	11/04/2017	07:38 AM	HER-33B	Classroom 507	S - Sink	11/03/2017	09:00 PM	Flush	ND
310451310222010	11/04/2017	07:39 AM	HER-34A	Classroom 508	S - Sink	11/03/2017	09:00 PM	First Draw	ND
310451310222010	11/04/2017	07:39 AM	HER-34B	Classroom 508	S - Sink	11/03/2017	09:00 PM	Flush	ND
310451310222010	11/04/2017	07:41 AM	HER-35A	Classroom 509	S - Sink	11/03/2017	09:00 PM	First Draw	9.23
310451310222010	11/04/2017	07:41 AM	HER-35B	Classroom 509	S - Sink	11/03/2017	09:00 PM	Flush	5.76
310451310222010	11/04/2017	07:44 AM	HER-36A	Classroom 510	S - Sink	11/03/2017	09:00 PM	First Draw	4.56
310451310222010	11/04/2017	07:44 AM	HER-36B	Classroom 510	S - Sink	11/03/2017	09:00 PM	Flush	2.24
310451310222010	11/04/2017	07:47 AM	HER-37A	Classroom 306	S - Sink	11/03/2017	09:00 PM	First Draw	28.8
310451310222010	11/04/2017	07:47 AM	HER-37B	Classroom 306	S - Sink	11/03/2017	09:00 PM	Flush	3.22
310451310222010	11/04/2017	07:49 AM	HER-38A	Classroom 304	S - Sink	11/03/2017	09:00 PM	First Draw	7.63
310451310222010	11/04/2017	07:49 AM	HER-38B	Classroom 304	S - Sink	11/03/2017	09:00 PM	Flush	ND
310451310222010	11/04/2017	07:51 AM	HER-39A	Corridor by Rooms 302B/302C (Higher)	DF - Drinking Fountain	11/03/2017	09:00 PM	First Draw	ND
310451310222010	11/04/2017	07:51 AM	HER-39B	Corridor by Rooms 302B/302C (Higher)	DF - Drinking Fountain	11/03/2017	09:00 PM	Flush	ND
310451310222010	11/04/2017	07:51 AM	HER-40A	Corridor by Rooms 302B/302C (Lower)	DF - Drinking Fountain	11/03/2017	09:00 PM	First Draw	ND
310451310222010	11/04/2017	07:51 AM	HER-40B	Corridor by Rooms 302B/302C (Lower)	DF - Drinking Fountain	11/03/2017	09:00 PM	Flush	ND
310451310222010	11/04/2017	07:55 AM	HER-41A	Room 301 - Gymnasium (Higher)	DF - Drinking Fountain	11/03/2017	09:00 PM	First Draw	ND
310451310222010	11/04/2017	07:55 AM	HER-41B	Room 301 - Gymnasium (Higher)	DF - Drinking Fountain	11/03/2017	09:00 PM	Flush	ND
310451310222010	11/04/2017	07:55 AM	HER-42A	Room 301 - Gymnasium (Lower)	DF - Drinking Fountain	11/03/2017	09:00 PM	First Draw	ND
310451310222010	11/04/2017	07:55 AM	HER-42B	Room 301 - Gymnasium (Lower)	DF - Drinking Fountain	11/03/2017	09:00 PM	Flush	ND
310451310222010	11/04/2017	08:01 AM	HER-43A	Room 301A - Kitchen (Right Faucet)	KS - Kitchen Sink	11/03/2017	09:00 PM	First Draw	ND
310451310222010	11/04/2017	08:01 AM	HER-43AA	Room 301A - Kitchen (Right Faucet)	KS - Kitchen Sink	11/03/2017	09:00 PM	Flush	ND
310451310222010	11/04/2017	08:01 AM	HER-43B	Room 301A - Kitchen (Left Faucet)	KS - Kitchen Sink	11/03/2017	09:00 PM	First Draw	2.51
310451310222010	11/04/2017	08:01 AM	HER-43BB	Room 301A - Kitchen (Left Faucet)	KS - Kitchen Sink	11/03/2017	09:00 PM	Flush	2.3
310451310222010	11/04/2017	08:04 AM	HER-44A	Classroom 401	S - Sink	11/03/2017	09:00 PM	First Draw	ND
310451310222010	11/04/2017	08:04 AM	HER-44B	Classroom 401	S - Sink	11/03/2017	09:00 PM	Flush	ND
310451310222010	11/04/2017	08:06 AM	HER-45A	Classroom 402	S - Sink	11/03/2017	09:00 PM	First Draw	ND
310451310222010	11/04/2017	08:06 AM	HER-45B	Classroom 402	S - Sink	11/03/2017	09:00 PM	Flush	ND
310451310222010	11/04/2017	08:07 AM	HER-46A	Classroom 403	S - Sink	11/03/2017	09:00 PM	First Draw	ND
310451310222010	11/04/2017	08:07 AM	HER-46B	Classroom 403	S - Sink	11/03/2017	09:00 PM	Flush	ND
310451310222010	11/04/2017	08:09 AM	HER-47A	Classroom 404	S - Sink	11/03/2017	09:00 PM	First Draw	ND
310451310222010	11/04/2017	08:09 AM	HER-47B	Classroom 404	S - Sink	11/03/2017	09:00 PM	Flush	ND
310451310222010	11/04/2017	08:11 AM	HER-48A	Classroom 405	S - Sink	11/03/2017	09:00 PM	First Draw	ND
310451310222010	11/04/2017	08:11 AM	HER-48B	Classroom 405	S - Sink	11/03/2017	09:00 PM	Flush	ND

ISBE ID	Sample Date	Sample Time (12 HR Clock)	Sample ID Number	Sample Location Description	Fixture Type	Date of Last Use	Time of Last Use (12 HR Clock)	Sample Type	Concentration (ug/L)
310451310222010	11/04/2017	08:15 AM	HER-49A	Classroom 406	S - Sink	11/03/2017	09:00 PM	First Draw	ND
310451310222010	11/04/2017	08:15 AM	HER-49B	Classroom 406	S - Sink	11/03/2017	09:00 PM	Flush	ND
310451310222010	11/04/2017	08:17 AM	HER-50A	Classroom 407	S - Sink	11/03/2017	09:00 PM	First Draw	ND
310451310222010	11/04/2017	08:17 AM	HER-50B	Classroom 407	S - Sink	11/03/2017	09:00 PM	Flush	ND
310451310222010	11/04/2017	08:24 AM	HER-51A	Classroom 408	S - Sink	11/03/2017	09:00 PM	First Draw	ND
310451310222010	11/04/2017	08:24 AM	HER-51B	Classroom 408	S - Sink	11/03/2017	09:00 PM	Flush	ND

APPENDIX B
Laboratory Results and Chain of Custody Documentation

SUBURBAN LABORATORIES, Inc.



1950 S. Batavia Ave., Suite 150 Geneva, Illinois 60134
Tel. (708) 544-3260 • Toll Free (800) 783-LABS
Fax (708) 544-8587
www.suburbanlabs.com

November 21, 2017

Olivia Reynhout
Weaver Consultants Group
1316 Bond St - Suite 108
Naperville, IL 60563

Workorder: 1711532

TEL: (630) 717-4848

FAX: (630) 717-4850

RE: Hermes Elementary School School Drinking Water Lead Analysis

Dear Olivia Reynhout:

Suburban Laboratories, Inc. received 104 sample(s) on 11/7/2017 for the analyses presented in the following report.

Customer has provided 250 mL volume sample bottles for all samples collected. Please note, all sample results that exceed 5.00 ug/L should be promptly reported to parents or guardians of all enrolled students. Results that are below 5.00 ug/L should be reported on the school website. Please refer to Public Act 099-0922 or the Illinois Department of Public Health for specific reporting requirements. Suburban Laboratories will forward all results to the IDPH within seven (7) business days from the date of this report.

This report may not be reproduced, except in full, without the prior written approval of Suburban Laboratories, Inc. If you have any questions regarding these test results, please call me at (708) 544-3260.

Sincerely,

Pat Rodriguez
Project Manager
708-544-3260 ext 214
pat@suburbanlabs.com



SUBURBAN LABORATORIES, Inc.



1950 S. Batavia Ave., Suite 150 Geneva, Illinois 60134

Tel. (708) 544-3260 • Toll Free (800) 783-LABS

Fax (708) 544-8587

www.suburbanlabs.com

Client ID: Weaver Consultants Group

Report Date: November 21, 2017

Project Name: Hermes Elementary School School Drinking Water Lead

Workorder: 1711532

Analyte: Lead

Method: EPA 200.8

Matrix: Drinking Water

Sample ID	Client Sample ID	Result	MRL	Units	Date & Time Water System Last Used	Date Collected	Date Analyzed
1711532-001A	HER-01A~Classroom 101 (Stainless Steel)~First Draw	2.73	2.00	µg/L	11/03/2017 21:00	11/4/2017	11/11/2017
1711532-002A	HER-01B~Classroom 101 (Stainless Steel)~Flush	ND	2.00	µg/L	11/03/2017 21:00	11/4/2017	11/11/2017
1711532-003A	HER-02A~Classroom 101 (Porcelain)~First Draw	4.50	2.00	µg/L	11/03/2017 21:00	11/4/2017	11/11/2017
1711532-004A	HER-02B~Classroom 101 (Porcelain)~Flush	2.04	2.00	µg/L	11/03/2017 21:00	11/4/2017	11/11/2017
1711532-005A	HER-03A~Classroom 102~First Draw	2.47	2.00	µg/L	11/03/2017 21:00	11/4/2017	11/11/2017
1711532-006A	HER-03B~Classroom 102~Flush	ND	2.00	µg/L	11/03/2017 21:00	11/4/2017	11/11/2017
1711532-007A	HER-04A~Classroom 104~First Draw	3.39	2.00	µg/L	11/03/2017 21:00	11/4/2017	11/11/2017
1711532-008A	HER-04B~Classroom 104~Flush	ND	2.00	µg/L	11/03/2017 21:00	11/4/2017	11/11/2017
1711532-009A	HER-05A~Classroom 106~First Draw	3.77	2.00	µg/L	11/03/2017 21:00	11/4/2017	11/11/2017
1711532-010A	HER-05B~Classroom 106~Flush	ND	2.00	µg/L	11/03/2017 21:00	11/4/2017	11/11/2017
1711532-011A	HER-06A~Classroom 105~First Draw	4.59	2.00	µg/L	11/03/2017 21:00	11/4/2017	11/11/2017
1711532-012A	HER-06B~Classroom 105~Flush	ND	2.00	µg/L	11/03/2017 21:00	11/4/2017	11/11/2017
1711532-013A	HER-07A~Classroom 105 - Main Line~First Draw	192	2.00	µg/L	11/03/2017 21:00	11/4/2017	11/14/2017
1711532-014A	HER-07B~Classroom 105 - Main Line~Flush	67.7	2.00	µg/L	11/03/2017 21:00	11/4/2017	11/14/2017
1711532-015A	HER-08A~Classroom 108~First Draw	4.37	2.00	µg/L	11/03/2017 21:00	11/4/2017	11/11/2017
1711532-016A	HER-08B~Classroom 108~Flush	ND	2.00	µg/L	11/03/2017 21:00	11/4/2017	11/11/2017
1711532-017A	HER-09A~Corridor by Room 108 ~First Draw	4.49	2.00	µg/L	11/03/2017 21:00	11/4/2017	11/11/2017
1711532-018A	HER-09B~Corridor by Room 108 ~Flush	10.8	2.00	µg/L	11/03/2017 21:00	11/4/2017	11/11/2017
1711532-019A	HER-10A~Corridor by Office~First Draw	ND	2.00	µg/L	11/03/2017 21:00	11/4/2017	11/11/2017
1711532-020A	HER-10B~Corridor by Office~Flush	ND	2.00	µg/L	11/03/2017 21:00	11/4/2017	11/11/2017
1711532-021A	HER-11A~Main Office Storage~First Draw	7.06	2.00	µg/L	11/03/2017 21:00	11/4/2017	11/11/2017
1711532-022A	HER-11B~Main Office Storage~Flush	ND	2.00	µg/L	11/03/2017 21:00	11/4/2017	11/11/2017
1711532-023A	HER-12A~Classroom 112~First Draw	10.3	2.00	µg/L	11/03/2017 21:00	11/4/2017	11/11/2017
1711532-024A	HER-12B~Classroom 112~Flush	9.06	2.00	µg/L	11/03/2017 21:00	11/4/2017	11/11/2017

SUBURBAN LABORATORIES, Inc.



1950 S. Batavia Ave., Suite 150 Geneva, Illinois 60134

Tel. (708) 544-3260 • Toll Free (800) 783-LABS

Fax (708) 544-8587

www.suburbanlabs.com

Client ID: Weaver Consultants Group

Report Date: November 21, 2017

Project Name: Hermes Elementary School School Drinking Water Lead

Workorder: 1711532

Analyte: Lead

Method: EPA 200.8

Matrix: Drinking Water

Sample ID	Client Sample ID	Result	MRL	Units	Date & Time Water System Last Used	Date Collected	Date Analyzed
1711532-025A	HER-13A~Classroom 113~First Draw	32.8	2.00	µg/L	11/03/2017 21:00	11/4/2017	11/11/2017
1711532-026A	HER-13B~Classroom 113~Flush	ND	2.00	µg/L	11/03/2017 21:00	11/4/2017	11/11/2017
1711532-027A	HER-14A~Classroom 114~First Draw	10.9	2.00	µg/L	11/03/2017 21:00	11/4/2017	11/11/2017
1711532-028A	HER-14B~Classroom 114~Flush	ND	2.00	µg/L	11/03/2017 21:00	11/4/2017	11/11/2017
1711532-029A	HER-15A~Corridor by (2028) Girl's Bathroom~First Draw	ND	2.00	µg/L	11/03/2017 21:00	11/4/2017	11/11/2017
1711532-030A	HER-15B~Corridor by (2028) Girl's Bathroom~Flush	ND	2.00	µg/L	11/03/2017 21:00	11/4/2017	11/11/2017
1711532-031A	HER-16A~Room 204A - Nurse's Office~First Draw	16.7	2.00	µg/L	11/03/2017 21:00	11/4/2017	11/11/2017
1711532-032A	HER-16B~Room 204A - Nurse's Office~Flush	ND	2.00	µg/L	11/03/2017 21:00	11/4/2017	11/11/2017
1711532-033A	HER-17A~Room 206~First Draw	11.3	2.00	µg/L	11/03/2017 21:00	11/4/2017	11/11/2017
1711532-034A	HER-17B~Room 206~Flush	ND	2.00	µg/L	11/03/2017 21:00	11/4/2017	11/11/2017
1711532-035A	HER-18A~Room 203~First Draw	6.18	2.00	µg/L	11/03/2017 21:00	11/4/2017	11/11/2017
1711532-036A	HER-18B~Room 203~Flush	ND	2.00	µg/L	11/03/2017 21:00	11/4/2017	11/11/2017
1711532-037A	HER-19A~Room 208~First Draw	7.57	2.00	µg/L	11/03/2017 21:00	11/4/2017	11/11/2017
1711532-038A	HER-19B~Room 208~Flush	2.66	2.00	µg/L	11/03/2017 21:00	11/4/2017	11/11/2017
1711532-039A	HER-20A~Room 205~First Draw	5.65	2.00	µg/L	11/03/2017 21:00	11/4/2017	11/11/2017
1711532-040A	HER-20B~Room 205~Flush	ND	2.00	µg/L	11/03/2017 21:00	11/4/2017	11/11/2017
1711532-041A	HER-21A~Corridor by Mechanical Room~First Draw	ND	2.00	µg/L	11/03/2017 21:00	11/4/2017	11/11/2017
1711532-042A	HER-21B~Corridor by Mechanical Room~Flush	4.44	2.00	µg/L	11/03/2017 21:00	11/4/2017	11/11/2017
1711532-043A	HER-22A~Room 308~First Draw	173	2.00	µg/L	11/03/2017 21:00	11/4/2017	11/14/2017
1711532-044A	HER-22B~Room 308~Flush	ND	2.00	µg/L	11/03/2017 21:00	11/4/2017	11/11/2017
1711532-045A	HER-23A~Room 309~First Draw	32.0	2.00	µg/L	11/03/2017 21:00	11/4/2017	11/11/2017
1711532-046A	HER-23B~Room 309~Flush	5.17	2.00	µg/L	11/03/2017 21:00	11/4/2017	11/11/2017
1711532-047A	HER-24A~Room 310~First Draw	61.1	2.00	µg/L	11/03/2017 21:00	11/4/2017	11/11/2017

SUBURBAN LABORATORIES, Inc.



1950 S. Batavia Ave., Suite 150 Geneva, Illinois 60134
Tel. (708) 544-3260 • Toll Free (800) 783-LABS
Fax (708) 544-8587
www.suburbanlabs.com

Client ID: Weaver Consultants Group

Report Date: November 21, 2017

Project Name: Hermes Elementary School School Drinking Water Lead

Workorder: 1711532

Analyte: Lead

Method: EPA 200.8

Matrix: Drinking Water

Sample ID	Client Sample ID	Result	MRL	Units	Date & Time Water System Last Used	Date Collected	Date Analyzed
1711532-048A	HER-24B~Room 310~Flush	30.3	2.00	µg/L	11/03/2017 21:00	11/4/2017	11/11/2017
1711532-049A	HER-25A~Classroom 311~First Draw	66.6	2.00	µg/L	11/03/2017 21:00	11/4/2017	11/11/2017
1711532-050A	HER-25B~Classroom 311~Flush	56.5	2.00	µg/L	11/03/2017 21:00	11/4/2017	11/11/2017
1711532-051A	HER-26A~Corridor by Room 312~First Draw	ND	2.00	µg/L	11/03/2017 21:00	11/4/2017	11/11/2017
1711532-052A	HER-26B~Corridor by Room 312~Flush	ND	2.00	µg/L	11/03/2017 21:00	11/4/2017	11/11/2017
1711532-053A	HER-27A~Classroom 312~First Draw	56.8	2.00	µg/L	11/03/2017 21:00	11/4/2017	11/14/2017
1711532-054A	HER-27B~Classroom 312~Flush	34.7	2.00	µg/L	11/03/2017 21:00	11/4/2017	11/11/2017
1711532-055A	HER-28A~Corridor by (503A) Boy's Bathroom (Stainless Steel)~First Draw	ND	2.00	µg/L	11/03/2017 21:00	11/4/2017	11/11/2017
1711532-056A	HER-28B~Corridor by (503A) Boy's Bathroom (Stainless Steel)~Flush	ND	2.00	µg/L	11/03/2017 21:00	11/4/2017	11/11/2017
1711532-057A	HER-29A~Corridor by (503A) Boy's Bathroom (Painted Face)~First Draw	ND	2.00	µg/L	11/03/2017 21:00	11/4/2017	11/11/2017
1711532-058A	HER-29B~Corridor by (503A) Boy's Bathroom (Painted Face)~Flush	ND	2.00	µg/L	11/03/2017 21:00	11/4/2017	11/11/2017
1711532-059A	HER-30A~Room 504 - Staff Lounge~First Draw	ND	2.00	µg/L	11/03/2017 21:00	11/4/2017	11/11/2017
1711532-060A	HER-30B~Room 504 - Staff Lounge~Flush	ND	2.00	µg/L	11/03/2017 21:00	11/4/2017	11/11/2017
1711532-061A	HER-31A~Classroom 506~First Draw	ND	2.00	µg/L	11/03/2017 21:00	11/4/2017	11/11/2017
1711532-062A	HER-31B~Classroom 506~Flush	ND	2.00	µg/L	11/03/2017 21:00	11/4/2017	11/11/2017
1711532-063A	HER-32A~Classroom 505~First Draw	ND	2.00	µg/L	11/03/2017 21:00	11/4/2017	11/11/2017
1711532-064A	HER-32B~Classroom 505~Flush	ND	2.00	µg/L	11/03/2017 21:00	11/4/2017	11/11/2017
1711532-065A	HER-33A~Classroom 507~First Draw	29.2	2.00	µg/L	11/03/2017 21:00	11/4/2017	11/11/2017
1711532-066A	HER-33B~Classroom 507~Flush	ND	2.00	µg/L	11/03/2017 21:00	11/4/2017	11/11/2017
1711532-067A	HER-34A~Classroom 508 ~First Draw	ND	2.00	µg/L	11/03/2017 21:00	11/4/2017	11/11/2017
1711532-068A	HER-34B~Classroom 508 ~Flush	ND	2.00	µg/L	11/03/2017 21:00	11/4/2017	11/11/2017
1711532-069A	HER-35A~Classroom 509~First Draw	9.23	2.00	µg/L	11/03/2017 21:00	11/4/2017	11/11/2017

SUBURBAN LABORATORIES, Inc.



1950 S. Batavia Ave., Suite 150 Geneva, Illinois 60134
Tel. (708) 544-3260 • Toll Free (800) 783-LABS
Fax (708) 544-8587
www.suburbanlabs.com

Client ID: Weaver Consultants Group

Report Date: November 21, 2017

Project Name: Hermes Elementary School School Drinking Water Lead

Workorder: 1711532

Analyte: Lead

Method: EPA 200.8

Matrix: Drinking Water

Sample ID	Client Sample ID	Result	MRL	Units	Date & Time Water System Last Used	Date Collected	Date Analyzed
1711532-070A	HER-35B~Classroom 509~Flush	5.76	2.00	µg/L	11/03/2017 21:00	11/4/2017	11/11/2017
1711532-071A	HER-36A~Classroom 510~First Draw	4.56	2.00	µg/L	11/03/2017 21:00	11/4/2017	11/11/2017
1711532-072A	HER-36B~Classroom 510~Flush	2.24	2.00	µg/L	11/03/2017 21:00	11/4/2017	11/11/2017
1711532-073A	HER-37A~Classroom 306~First Draw	28.8	2.00	µg/L	11/03/2017 21:00	11/4/2017	11/11/2017
1711532-074A	HER-37B~Classroom 306~Flush	3.22	2.00	µg/L	11/03/2017 21:00	11/4/2017	11/11/2017
1711532-075A	HER-38A~Classroom 304~First Draw	7.63	2.00	µg/L	11/03/2017 21:00	11/4/2017	11/11/2017
1711532-076A	HER-38B~Classroom 304~Flush	ND	2.00	µg/L	11/03/2017 21:00	11/4/2017	11/11/2017
1711532-077A	HER-39A~Corridor by Rooms 302B/302C (Higher)~First Draw	ND	2.00	µg/L	11/03/2017 21:00	11/4/2017	11/11/2017
1711532-078A	HER-39B~Corridor by Rooms 302B/302C (Higher)~Flush	ND	2.00	µg/L	11/03/2017 21:00	11/4/2017	11/11/2017
1711532-079A	HER-40A~Corridor by Rooms 302B/302C (Lower)~First Draw	ND	2.00	µg/L	11/03/2017 21:00	11/4/2017	11/11/2017
1711532-080A	HER-40B~Corridor by Rooms 302B/302C (Lower)~Flush	ND	2.00	µg/L	11/03/2017 21:00	11/4/2017	11/11/2017
1711532-081A	HER-41A~Room 301 - Gymnasium (Higher)~First Draw	ND	2.00	µg/L	11/03/2017 21:00	11/4/2017	11/11/2017
1711532-082A	HER-41B~Room 301 - Gymnasium (Higher)~Flush	ND	2.00	µg/L	11/03/2017 21:00	11/4/2017	11/11/2017
1711532-083A	HER-42A~Room 301 - Gymnasium (Lower)~First Draw	ND	2.00	µg/L	11/03/2017 21:00	11/4/2017	11/11/2017
1711532-084A	HER-42B~Room 301 - Gymnasium (Lower)~Flush	ND	2.00	µg/L	11/03/2017 21:00	11/4/2017	11/11/2017
1711532-085A	HER-43A~Room 301A - Kitchen (Right Faucet)~First Draw	ND	2.00	µg/L	11/03/2017 21:00	11/4/2017	11/11/2017
1711532-086A	HER-43AA~Room 301A - Kitchen (Right Faucet)~Flush	ND	2.00	µg/L	11/03/2017 21:00	11/4/2017	11/11/2017
1711532-087A	HER-43B~Room 301A - Kitchen (Left Faucet)~First Draw	2.51	2.00	µg/L	11/03/2017 21:00	11/4/2017	11/11/2017
1711532-088A	HER-43BB~Room 301A - Kitchen (Left Faucet)~Flush	2.30	2.00	µg/L	11/03/2017 21:00	11/4/2017	11/11/2017
1711532-089A	HER-44A~Classroom 401~First Draw	ND	2.00	µg/L	11/03/2017 21:00	11/4/2017	11/11/2017

ND - Not Detected Down to the Laboratory Minimum Reporting Limit (MRL)

SUBURBAN LABORATORIES, Inc.



1950 S. Batavia Ave., Suite 150 Geneva, Illinois 60134

Tel. (708) 544-3260 • Toll Free (800) 783-LABS

Fax (708) 544-8587

www.suburbanlabs.com

Client ID: Weaver Consultants Group

Report Date: November 21, 2017

Project Name: Hermes Elementary School School Drinking Water Lead

Workorder: 1711532

Analyte: Lead

Method: EPA 200.8

Matrix: Drinking Water

Sample ID	Client Sample ID	Result	MRL	Units	Date & Time Water System Last Used	Date Collected	Date Analyzed
1711532-090A	HER-44B~Classroom 401~Flush	ND	2.00	µg/L	11/03/2017 21:00	11/4/2017	11/11/2017
1711532-091A	HER-45A~Classroom 402~First Draw	ND	2.00	µg/L	11/03/2017 21:00	11/4/2017	11/11/2017
1711532-092A	HER-45B~Classroom 402~Flush	ND	2.00	µg/L	11/03/2017 21:00	11/4/2017	11/11/2017
1711532-093A	HER-46A~Classroom 403~First Draw	ND	2.00	µg/L	11/03/2017 21:00	11/4/2017	11/11/2017
1711532-094A	HER-46B~Classroom 403~Flush	ND	2.00	µg/L	11/03/2017 21:00	11/4/2017	11/11/2017
1711532-095A	HER-47A~Classroom 404~First Draw	ND	2.00	µg/L	11/03/2017 21:00	11/4/2017	11/11/2017
1711532-096A	HER-47B~Classroom 404~Flush	ND	2.00	µg/L	11/03/2017 21:00	11/4/2017	11/11/2017
1711532-097A	HER-48A~Classroom 405~First Draw	ND	2.00	µg/L	11/03/2017 21:00	11/4/2017	11/11/2017
1711532-098A	HER-48B~Classroom 405~Flush	ND	2.00	µg/L	11/03/2017 21:00	11/4/2017	11/11/2017
1711532-099A	HER-49A~Classroom 406~First Draw	ND	2.00	µg/L	11/03/2017 21:00	11/4/2017	11/11/2017
1711532-100A	HER-49B~Classroom 406~Flush	ND	2.00	µg/L	11/03/2017 21:00	11/4/2017	11/11/2017
1711532-101A	HER-50A~Classroom 407~First Draw	ND	2.00	µg/L	11/03/2017 21:00	11/4/2017	11/11/2017
1711532-102A	HER-50B~Classroom 407~Flush	ND	2.00	µg/L	11/03/2017 21:00	11/4/2017	11/11/2017
1711532-103A	HER-51A~Classroom 408~First Draw	ND	2.00	µg/L	11/03/2017 21:00	11/4/2017	11/11/2017
1711532-104A	HER-51B~Classroom 408~Flush	ND	2.00	µg/L	11/03/2017 21:00	11/4/2017	11/11/2017

1711532-001A-84A

FIELD DATA FORM

School/Facility Name
Nicholas A. Hermes Elementary School
ISBE ID: (ex:01-001-0001-01-00001)
310451310222010

Address
1000 Jungles Avenue
Aurora, IL
MMDDYYYY
11/03/2017

Sample Collector Name(s)
A. Ogunbiyi

Water system last used Date: 11/03/2017 Time: 21:00

All samples must be collected in unpreserved

Bldg. ID	Bldg. Desc	Sample ID#	Sample Loc. Desc	Collection Date MMDDYYYY	Collection Time HHZ4MM	Fixture Type	Sample Type	Sample Vol.	Notes
0001	Main Building	01	1st Floor Classroom	02232017	800	O - Other	First Draw	250	Description if "Other" is selected
0001	Main Building	01A	1st Floor Classroom	02232017	800	S - Sink	Flush	250	
1	310451310222010	School	HER-01A Classroom 101 (Stainless Steel)	11/04/2017	6:35	S - Sink	First Draw	250	
2	310451310222010	School	HER-01B Classroom 101 (Stainless Steel)	11/04/2017	6:35	S - Sink	Flush	250	
3	310451310222010	School	HER-02A Classroom 101 (Porcelain)	11/04/2017	6:35	S - Sink	First Draw	250	
4	310451310222010	School	HER-02B Classroom 101 (Porcelain)	11/04/2017	6:35	S - Sink	Flush	250	
5	310451310222010	School	HER-03A Classroom 102	11/04/2017	6:40	S - Sink	First Draw	250	
6	310451310222010	School	HER-03B Classroom 102	11/04/2017	6:40	S - Sink	Flush	250	
7	310451310222010	School	HER-04A Classroom 104	11/04/2017	6:43	S - Sink	First Draw	250	
8	310451310222010	School	HER-04B Classroom 104	11/04/2017	6:43	S - Sink	Flush	250	
9	310451310222010	School	HER-05A Classroom 105	11/04/2017	6:45	S - Sink	First Draw	250	
10	310451310222010	School	HER-05B Classroom 105	11/04/2017	6:45	S - Sink	Flush	250	
11	310451310222010	School	HER-06A Classroom 105 - Main Line	11/04/2017	6:47	S - Sink	First Draw	250	
12	310451310222010	School	HER-06B Classroom 105 - Main Line	11/04/2017	6:47	S - Sink	Flush	250	
13	310451310222010	School	HER-07A Classroom 108	11/04/2017	6:51	O - Other	First Draw	250	
14	310451310222010	School	HER-07B Classroom 108	11/04/2017	6:51	O - Other	Flush	250	
15	310451310222010	School	HER-08A Classroom 108	11/04/2017	6:51	S - Sink	First Draw	250	
16	310451310222010	School	HER-08B Classroom 108	11/04/2017	6:51	S - Sink	Flush	250	
17	310451310222010	School	HER-09A Corridor by Room 108	11/04/2017	6:53	DF - Drinking Fountain	First Draw	250	
18	310451310222010	School	HER-09B Corridor by Room 108	11/04/2017	6:53	DF - Drinking Fountain	Flush	250	
19	310451310222010	School	HER-10A Corridor by Office	11/04/2017	6:55	DF - Drinking Fountain	First Draw	250	
20	310451310222010	School	HER-10B Corridor by Office	11/04/2017	6:55	DF - Drinking Fountain	Flush	250	
21	310451310222010	School	HER-11A Main Office Storage	11/04/2017	6:57	S - Sink	First Draw	250	
22	310451310222010	School	HER-11B Main Office Storage	11/04/2017	6:57	S - Sink	Flush	250	
23	310451310222010	School	HER-12A Classroom 112	11/04/2017	6:59	S - Sink	First Draw	250	
24	310451310222010	School	HER-12B Classroom 112	11/04/2017	6:59	S - Sink	Flush	250	
25	310451310222010	School	HER-13A Classroom 113	11/04/2017	7:08	S - Sink	First Draw	250	
26	310451310222010	School	HER-13B Classroom 113	11/04/2017	7:08	S - Sink	Flush	250	
27	310451310222010	School	HER-14A Classroom 114	11/04/2017	7:05	S - Sink	First Draw	250	
28	310451310222010	School	HER-14B Classroom 114	11/04/2017	7:05	S - Sink	Flush	250	
29	310451310222010	School	HER-15A Corridor by (202A) Girls Bathroom	11/04/2017	7:07	DF - Drinking Fountain	First Draw	250	
30	310451310222010	School	HER-15B Corridor by (202A) Girls Bathroom	11/04/2017	7:07	DF - Drinking Fountain	Flush	250	
31	310451310222010	School	HER-16A Room 204A - Nurse's Office	11/04/2017	7:09	S - Sink	First Draw	250	
32	310451310222010	School	HER-16B Room 204A - Nurse's Office	11/04/2017	7:09	S - Sink	Flush	250	
33	310451310222010	School	HER-17A Room 206	11/04/2017	7:10	S - Sink	First Draw	250	
34	310451310222010	School	HER-17B Room 206	11/04/2017	7:10	S - Sink	Flush	250	
35	310451310222010	School	HER-18A Room 208	11/04/2017	7:12	S - Sink	First Draw	250	
36	310451310222010	School	HER-18B Room 208	11/04/2017	7:12	S - Sink	Flush	250	
37	310451310222010	School	HER-19A Room 208	11/04/2017	7:13	S - Sink	First Draw	250	
38	310451310222010	School	HER-19B Room 208	11/04/2017	7:13	S - Sink	Flush	250	
39	310451310222010	School	HER-20A Room 205	11/04/2017	7:15	S - Sink	First Draw	250	
40	310451310222010	School	HER-20B Room 205	11/04/2017	7:15	S - Sink	Flush	250	
41	310451310222010	School	HER-21A Corridor by Mechanical Room	11/04/2017	7:16	DF - Drinking Fountain	First Draw	250	
42	310451310222010	School	HER-21B Corridor by Mechanical Room	11/04/2017	7:16	DF - Drinking Fountain	Flush	250	
43	310451310222010	School	HER-22A Room 308	11/04/2017	7:17	S - Sink	First Draw	250	
44	310451310222010	School	HER-22B Room 308	11/04/2017	7:17	S - Sink	Flush	250	
45	310451310222010	School	HER-23A Room 309	11/04/2017	7:19	S - Sink	First Draw	250	
46	310451310222010	School	HER-23B Room 309	11/04/2017	7:19	S - Sink	Flush	250	
47	310451310222010	School	HER-24A Room 310	11/04/2017	7:21	S - Sink	First Draw	250	
48	310451310222010	School	HER-24B Room 310	11/04/2017	7:21	S - Sink	Flush	250	
49	310451310222010	School	HER-25A Classroom 311	11/04/2017	7:24	S - Sink	First Draw	250	
50	310451310222010	School	HER-25B Classroom 311	11/04/2017	7:24	S - Sink	Flush	250	
51	310451310222010	School	HER-26A Corridor by Room 312	11/04/2017	7:26	DF - Drinking Fountain	First Draw	250	
52	310451310222010	School	HER-26B Corridor by Room 312	11/04/2017	7:26	DF - Drinking Fountain	Flush	250	
53	310451310222010	School	HER-27A Classroom 312	11/04/2017	7:28	S - Sink	First Draw	250	
54	310451310222010	School	HER-27B Classroom 312	11/04/2017	7:28	S - Sink	Flush	250	
55	310451310222010	School	HER-28A Corridor by (503A) Boy's Bathroom (Stainless Steel)	11/04/2017	7:29	DF - Drinking Fountain	First Draw	250	
56	310451310222010	School	HER-28B Corridor by (503A) Boy's Bathroom (Stainless Steel)	11/04/2017	7:29	DF - Drinking Fountain	Flush	250	
57	310451310222010	School	HER-29A Corridor by (503A) Boy's Bathroom (Painted Face)	11/04/2017	7:29	DF - Drinking Fountain	First Draw	250	
58	310451310222010	School	HER-29B Corridor by (503A) Boy's Bathroom (Painted Face)	11/04/2017	7:29	DF - Drinking Fountain	Flush	250	
59	310451310222010	School	HER-30A Room 504 - Staff Lounge	11/04/2017	7:33	S - Sink	First Draw	250	
60	310451310222010	School	HER-30B Room 504 - Staff Lounge	11/04/2017	7:33	S - Sink	Flush	250	
61	310451310222010	School	HER-31A Classroom 506	11/04/2017	7:35	S - Sink	First Draw	250	
62	310451310222010	School	HER-31B Classroom 506	11/04/2017	7:35	S - Sink	Flush	250	
63	310451310222010	School	HER-32A Classroom 505	11/04/2017	7:37	S - Sink	First Draw	250	
64	310451310222010	School	HER-32B Classroom 505	11/04/2017	7:37	S - Sink	Flush	250	
65	310451310222010	School	HER-33A Classroom 507	11/04/2017	7:38	S - Sink	First Draw	250	
66	310451310222010	School	HER-33B Classroom 507	11/04/2017	7:38	S - Sink	Flush	250	
67	310451310222010	School	HER-34A Classroom 508	11/04/2017	7:39	S - Sink	First Draw	250	
68	310451310222010	School	HER-34B Classroom 508	11/04/2017	7:39	S - Sink	Flush	250	
69	310451310222010	School	HER-35A Classroom 509	11/04/2017	7:41	S - Sink	First Draw	250	
70	310451310222010	School	HER-35B Classroom 509	11/04/2017	7:41	S - Sink	Flush	250	
71	310451310222010	School	HER-36A Classroom 510	11/04/2017	7:44	S - Sink	First Draw	250	
72	310451310222010	School	HER-36B Classroom 510	11/04/2017	7:44	S - Sink	Flush	250	
73	310451310222010	School	HER-37A Classroom 506	11/04/2017	7:47	S - Sink	First Draw	250	
74	310451310222010	School	HER-37B Classroom 506	11/04/2017	7:47	S - Sink	Flush	250	
75	310451310222010	School	HER-38A Classroom 304	11/04/2017	7:49	S - Sink	First Draw	250	
76	310451310222010	School	HER-38B Classroom 304	11/04/2017	7:49	S - Sink	Flush	250	
77	310451310222010	School	HER-39A Corridor by Rooms 302B/302C (Higher)	11/04/2017	7:51	DF - Drinking Fountain	First Draw	250	
78	310451310222010	School	HER-39B Corridor by Rooms 302B/302C (Higher)	11/04/2017	7:51	DF - Drinking Fountain	Flush	250	
79	310451310222010	School	HER-40A Corridor by Rooms 302B/302C (Lower)	11/04/2017	7:51	DF - Drinking Fountain	First Draw	250	
80	310451310222010	School	HER-40B Corridor by Rooms 302B/302C (Lower)	11/04/2017	7:51	DF - Drinking Fountain	Flush	250	
81	310451310222010	School	HER-41A Room 301 - Gymnasium (Higher)	11/04/2017	7:55	DF - Drinking Fountain	First Draw	250	
82	310451310222010	School	HER-41B Room 301 - Gymnasium (Higher)	11/04/2017	7:55	DF - Drinking Fountain	Flush	250	
83	310451310222010	School	HER-42A Room 301 - Gymnasium (Lower)	11/04/2017	7:55	DF - Drinking Fountain	First Draw	250	
84	310451310222010	School	HER-42B Room 301 - Gymnasium (Lower)	11/04/2017	7:55	DF - Drinking Fountain	Flush	250	

11/7/17 5:00p

1711532-085A-104A

82	310451310222010	School	HER-43A	Room 301A- Kitchen (Right Faucet)	11/04/2017	8:01	KS - Kitchen Sink	First Draw	250	
83	310451310222010	School	HER-43AA	Room 301A- Kitchen (Right Faucet)	11/04/2017	8:01	KS - Kitchen Sink	Flush	250	
84	310451310222010	School	HER-43B	Room 301A- Kitchen (Left Faucet)	11/04/2017	8:01	KS - Kitchen Sink	First Draw	250	
85	310451310222010	School	HER-43B	Room 301A- Kitchen (Left Faucet)	11/04/2017	8:01	KS - Kitchen Sink	Flush	250	
86	310451310222010	School	HER-44A	Classroom 401	11/04/2017	8:04	S - Sink	First Draw	250	
87	310451310222010	School	HER-44B	Classroom 401	11/04/2017	8:04	S - Sink	Flush	250	
88	310451310222010	School	HER-45A	Classroom 402	11/04/2017	8:06	S - Sink	First Draw	250	
89	310451310222010	School	HER-45B	Classroom 402	11/04/2017	8:06	S - Sink	Flush	250	
90	310451310222010	School	HER-46A	Classroom 403	11/04/2017	8:07	S - Sink	First Draw	250	
91	310451310222010	School	HER-46B	Classroom 403	11/04/2017	8:07	S - Sink	Flush	250	
92	310451310222010	School	HER-47A	Classroom 404	11/04/2017	8:09	S - Sink	First Draw	250	
93	310451310222010	School	HER-47B	Classroom 404	11/04/2017	8:09	S - Sink	Flush	250	
94	310451310222010	School	HER-48A	Classroom 405	11/04/2017	8:11	S - Sink	First Draw	250	
95	310451310222010	School	HER-48B	Classroom 405	11/04/2017	8:11	S - Sink	Flush	250	
96	310451310222010	School	HER-49A	Classroom 406	11/04/2017	8:15	S - Sink	First Draw	250	
97	310451310222010	School	HER-49B	Classroom 406	11/04/2017	8:15	S - Sink	Flush	250	
98	310451310222010	School	HER-50A	Classroom 407	11/04/2017	8:17	S - Sink	First Draw	250	
99	310451310222010	School	HER-50B	Classroom 407	11/04/2017	8:17	S - Sink	Flush	250	
100	310451310222010	School	HER-51A	Classroom 408	11/04/2017	8:24	S - Sink	First Draw	250	
101	310451310222010	School	HER-51B	Classroom 408	11/04/2017	8:24	S - Sink	Flush	250	
102										
103										
104										
105										
106										
107										
108										
109										
110										
111										
112										
113										
114										
115										
116										
117										
118										
119										
120										
121										
122										
123										
124										
125										
126										
127										
128										
129										
130										
131										
132										
133										
134										
135										
136										
137										
138										
139										
140										
141										
142										
143										
144										
145										
146										
147										
148										
149										
150										
151										
152										
153										
154										
155										
156										
157										
158										
159										
160										
161										
162										
163										
164										
165										
166										
167										
168										
169										
170										
171										
172										
173										
174										
175										
176										
177										

11/7/17 5:00p