



December 14, 2017
WCG Project No. 4528-300-58-01

Mr. Albert Tijerina
East Aurora School District 131
Director of Building and Grounds
411 Hill Avenue
Aurora, Illinois 60505

**RE: Lead Sampling in Potable Water
Waldo Middle School
56 Jackson Street, Aurora, IL 60505**

Dear Mr. Tijerina:

The following letter report summarizes the laboratory results for the drinking water samples collected from the potable water sources at Waldo Middle School in Aurora, Illinois. The sampling was conducted on November 11, 2017 by Mr. David J. Kedrowski (CIH) of Weaver Consultants Group (WCG).

SCOPE OF WORK

The scope of work for this project involved collecting water samples from pre-identified water locations. The potable locations were provided to WCG by East Aurora School District 131. The collected potable water samples were then analyzed for lead by an accredited laboratory.

METHODOLOGY

WCG followed protocols set by U.S. Environmental Protection Agency (EPA) and Illinois Department of Public Health (IDPH) for testing schools for lead in drinking water. Representatives from East Aurora School District 131 confirmed the school was under normal use and ensured the water settled within the piping systems/fixtures for between eight (8) to eighteen (18) hours.

Fifty-one (51) water samples from representative potable water locations were collected in 250 milliliter bottles. The water samples were collected as a "first draw" from each source to represent a lead concentration from water allowed to sit within the pipes or drinking reservoirs for at least eight (8) hours and not more than eighteen (18) hours. A second sample was collected from each location after a 30 second flush to represent water from within the building's localized water piping system. Potable water sources generally included drinking fountains, Nurses' Offices, Teachers' Lounges, kitchen faucets and preschool, kindergarten, and first floor classroom sinks, etc.

At the request of the District, non-potable samples were collected at the water main to the building to establish a baseline. As this is a non-potable source, the results likely do not represent water within the building system but rather sediment at the water main valve or within the sampling connections used to draw the sample. Water samples collected at each potable fixture should instead be relied upon as representative of the drinking water within the building.

Each sample was labeled with a unique sample number identifying the school. The samples were transported to Suburban Labs Incorporated (Suburban) in Geneva, Illinois. Samples were analyzed for lead content using EPA Method 200.8 "Determination of Trace Elements in Water using Inductively Coupled Plasma (ICP)/Mass Spectrometry (MS). Suburban is accredited to analyze lead in potable drinking water under the National Environmental Laboratory Accreditation Program (NELAP).

RESULTS

The results of the water sample analysis revealed that three (3) samples of the fifty-one (51) collected had lead concentrations above the IDPH Action Level of 2 ppb ($\mu\text{g}/\text{L}$). All sample results that exceed $5 \mu\text{g}/\text{L}$ should be promptly reported to parents or guardians of the enrolled students as required by the Illinois Department of Public Health (IDPH).

CONCLUSIONS AND RECOMMENDATIONS

- 1) Within 7 business days of receipt of test results, schools must email all results to IDPH at DPH.LeadH20@illinois.gov. **WCG will email these results on behalf of East Aurora School District 131.**
- 2) All sample results that exceed $5 \mu\text{g}/\text{L}$ should be promptly reported to parents or guardians of all enrolled students in writing or electronically and include:
 - The location and source exceeding $5 \mu\text{g}/\text{L}$.
 - The USEPA website for information about lead in drinking water, <https://www.epa.gov/ground-water-and-drinking-water/basic-information-about-lead-drinking-water>.
- 3) Implement corrective action for fixtures greater than $2 \mu\text{g}/\text{L}$.
- 4) Implement best practices to minimize lead concentrations in drinking water.

BEST PRACTICES

Best practices for managing elevated lead concentrations in drinking water may include implementing a water quality management plan (WQMP), establishing a routine water flushing program for potable sources daily or during periods of low occupancy or low water usage, routine maintenance to clean screens and aerators, and confirmation sampling. In addition, occupants should avoid consuming water from non-potable sources i.e. classroom or office sinks, washroom sinks, maintenance closets, etc. and hot water taps.

A summary of the sample locations and results may be found in Appendix A and the laboratory report with chain of custody sheets may be found in Appendix B. We appreciate the opportunity to assist you on this important project.

Sincerely,

Weaver Consultants Group North Central, LLC



David J. Kedrowski, CIH
Senior Project Director

APPENDIX A
Lead in Potable Water Sample Results

**Waldo Middle School
56 Jackson Street
Aurora, IL 60505**

Waldo Middle School
56 Jackson Street
Aurora, IL 60505

ISBE ID	Sample Date	Sample Time (12 HR Clock)	Sample ID Number	Sample Location Description	Fixture Type	Date of Last Use	Time of Last Use (12 HR Clock)	Sample Type	Concentration (ug/L)
310451310221003	11/11/2017	06:05 AM	WALD-01A	Lunchroom	DF - Drinking Fountain	11/10/2017	07:30 PM	First Draw	ND
310451310221003	11/11/2017	06:05 AM	WALD-01B	Lunchroom	DF - Drinking Fountain	11/10/2017	07:30 PM	Flush	ND
310451310221003	11/11/2017	06:07 AM	WALD-02A	Kitchen - At Smoothie Station	KS - Kitchen Sink	11/10/2017	07:30 PM	First Draw	ND
310451310221003	11/11/2017	06:07 AM	WALD-02B	Kitchen - At Smoothie Station	KS - Kitchen Sink	11/10/2017	07:30 PM	Flush	ND
310451310221003	11/11/2017	06:10 AM	WALD-03A	Kitchen - Near Office	KS - Kitchen Sink	11/10/2017	07:30 PM	First Draw	ND
310451310221003	11/11/2017	06:10 AM	WALD-03B	Kitchen - Near Office	KS - Kitchen Sink	11/10/2017	07:30 PM	Flush	ND
310451310221003	11/11/2017	06:13 AM	WALD-04A	Kitchen - Prep Area	KS - Kitchen Sink	11/10/2017	07:30 PM	First Draw	2.38
310451310221003	11/11/2017	06:13 AM	WALD-04B	Kitchen - Prep Area	KS - Kitchen Sink	11/10/2017	07:30 PM	Flush	ND
310451310221003	11/11/2017	06:19 AM	WALD-05A	Kitchen - Dish Washing Sink (Left Spout)	KS - Kitchen Sink	11/10/2017	07:30 PM	First Draw	ND
310451310221003	11/11/2017	06:19 AM	WALD-05B	Kitchen - Dish Washing Sink (Left Spout)	KS - Kitchen Sink	11/10/2017	07:30 PM	Flush	ND
310451310221003	11/11/2017	06:20 AM	WALD-06A	Kitchen - Dish Washing Sink (Right Spout)	S - Sink	11/10/2017	07:30 PM	First Draw	ND
310451310221003	11/11/2017	06:22 AM	WALD-07A	Teachers' Lounge	O - Other	11/10/2017	07:30 PM	First Draw	ND
310451310221003	11/11/2017	06:22 AM	WALD-07B	Teachers' Lounge	O - Other	11/10/2017	07:30 PM	Flush	ND
310451310221003	11/11/2017	06:29 AM	WALD-08A	Room 115A - Sink 1	S - Sink	11/10/2017	07:30 PM	First Draw	ND
310451310221003	11/11/2017	06:29 AM	WALD-08B	Room 115A - Sink 1	S - Sink	11/10/2017	07:30 PM	Flush	ND
310451310221003	11/11/2017	06:30 AM	WALD-09A	Room 115A - Sink 2	S - Sink	11/10/2017	07:30 PM	First Draw	ND
310451310221003	11/11/2017	06:30 AM	WALD-09B	Room 115A - Sink 2	S - Sink	11/10/2017	07:30 PM	Flush	ND
310451310221003	11/11/2017	06:31 AM	WALD-10A	Room 115A - Sink 3	S - Sink	11/10/2017	07:30 PM	First Draw	ND
310451310221003	11/11/2017	06:31 AM	WALD-10B	Room 115A - Sink 3	S - Sink	11/10/2017	07:30 PM	Flush	ND
310451310221003	11/11/2017	06:33 AM	WALD-11A	Room 115A - Sink 4	S - Sink	11/10/2017	07:30 PM	First Draw	ND
310451310221003	11/11/2017	06:33 AM	WALD-11B	Room 115A - Sink 4	S - Sink	11/10/2017	07:30 PM	Flush	ND
310451310221003	11/11/2017	06:35 AM	WALD-12A	Room 115A - Sink 5	S - Sink	11/10/2017	07:30 PM	First Draw	ND
310451310221003	11/11/2017	06:35 AM	WALD-12B	Room 115A - Sink 5	S - Sink	11/10/2017	07:30 PM	Flush	ND
310451310221003	11/11/2017	06:37 AM	WALD-13A	Room 115A - Sink 6	S - Sink	11/10/2017	07:30 PM	First Draw	ND
310451310221003	11/11/2017	06:37 AM	WALD-13B	Room 115A - Sink 6	S - Sink	11/10/2017	07:30 PM	Flush	ND
310451310221003	11/11/2017	06:43 AM	WALD-14A	Room 115A - Sink 7	S - Sink	11/10/2017	07:30 PM	First Draw	ND
310451310221003	11/11/2017	06:43 AM	WALD-14B	Room 115A - Sink 7	S - Sink	11/10/2017	07:30 PM	Flush	ND
310451310221003	11/11/2017	06:45 AM	WALD-15A	Room 115A - Sink 8	S - Sink	11/10/2017	07:30 PM	First Draw	ND
310451310221003	11/11/2017	06:45 AM	WALD-15B	Room 115A - Sink 8	S - Sink	11/10/2017	07:30 PM	Flush	ND
310451310221003	11/11/2017	06:49 AM	WALD-16A	Hallway Near Room 110	DF - Drinking Fountain	11/10/2017	07:30 PM	First Draw	ND
310451310221003	11/11/2017	06:49 AM	WALD-16B	Hallway Near Room 110	DF - Drinking Fountain	11/10/2017	07:30 PM	Flush	ND
310451310221003	11/11/2017	06:50 AM	WALD-17A	Hallway Near Room 104	DF - Drinking Fountain	11/10/2017	07:30 PM	First Draw	ND
310451310221003	11/11/2017	06:50 AM	WALD-17B	Hallway Near Room 104	DF - Drinking Fountain	11/10/2017	07:30 PM	Flush	ND
310451310221003	11/11/2017	06:58 AM	WALD-18A	Band Room 401	DF - Drinking Fountain	11/10/2017	07:30 PM	First Draw	ND
310451310221003	11/11/2017	06:58 AM	WALD-18B	Band Room 401	DF - Drinking Fountain	11/10/2017	07:30 PM	Flush	ND
310451310221003	11/11/2017	07:02 AM	WALD-19A	Hallway Near Room 312	DF - Drinking Fountain	11/10/2017	07:30 PM	First Draw	ND
310451310221003	11/11/2017	07:02 AM	WALD-19B	Hallway Near Room 312	DF - Drinking Fountain	11/10/2017	07:30 PM	Flush	ND
310451310221003	11/11/2017	07:04 AM	WALD-20A	Hallway Near Room 306	DF - Drinking Fountain	11/10/2017	07:30 PM	First Draw	ND
310451310221003	11/11/2017	07:04 AM	WALD-20B	Hallway Near Room 306	DF - Drinking Fountain	11/10/2017	07:30 PM	Flush	ND
310451310221003	11/11/2017	07:11 AM	WALD-21A	Hallway Near Room 214	DF - Drinking Fountain	11/10/2017	07:30 PM	First Draw	ND
310451310221003	11/11/2017	07:11 AM	WALD-21B	Hallway Near Room 214	DF - Drinking Fountain	11/10/2017	07:30 PM	Flush	ND
310451310221003	11/11/2017	07:16 AM	WALD-22A	Hallway Near Room 205	DF - Drinking Fountain	11/10/2017	07:30 PM	First Draw	ND
310451310221003	11/11/2017	07:16 AM	WALD-22B	Hallway Near Room 205	DF - Drinking Fountain	11/10/2017	07:30 PM	Flush	ND
310451310221003	11/11/2017	07:20 AM	WALD-23A	Room 204K - Nurse's Office	S - Sink	11/10/2017	07:30 PM	First Draw	ND
310451310221003	11/11/2017	07:20 AM	WALD-23B	Room 204K - Nurse's Office	S - Sink	11/10/2017	07:30 PM	Flush	3.59
310451310221003	11/11/2017	07:21 AM	WALD-24A	Room 204L - Nurse's Office	S - Sink	11/10/2017	07:30 PM	First Draw	ND
310451310221003	11/11/2017	07:21 AM	WALD-24B	Room 204L - Nurse's Office	S - Sink	11/10/2017	07:30 PM	Flush	ND
310451310221003	11/11/2017	07:26 AM	WALD-25A	Electrical Room	O - Other	11/10/2017	07:30 PM	First Draw	153
310451310221003	11/11/2017	07:26 AM	WALD-25B	Electrical Room	O - Other	11/10/2017	07:30 PM	Flush	ND
310451310221003	11/11/2017	07:32 AM	WALD-26A	Boy's Locker Room	DF - Drinking Fountain	11/10/2017	07:30 PM	First Draw	ND
310451310221003	11/11/2017	07:32 AM	WALD-26B	Boy's Locker Room	DF - Drinking Fountain	11/10/2017	07:30 PM	Flush	ND

APPENDIX B
Laboratory Results and Chain of Custody Documentation

SUBURBAN LABORATORIES, Inc.



1950 S. Batavia Ave., Suite 150 Geneva, Illinois 60134
Tel. (708) 544-3260 • Toll Free (800) 783-LABS
Fax (708) 544-8587
www.suburbanlabs.com

December 05, 2017

Olivia Reynhout
Weaver Consultants Group
1316 Bond St - Suite 108
Naperville, IL 60563

Workorder: 1711B25

TEL: (630) 717-4848
FAX: (630) 717-4850
RE: Waldo Middle School Drinking Water Lead Analysis

Dear Olivia Reynhout:

Suburban Laboratories, Inc. received 51 sample(s) on 11/15/2017 for the analyses presented in the following report.

Customer has provided 250 mL volume sample bottles for all samples collected. Please note, all sample results that exceed 5.00 ug/L should be promptly reported to parents or guardians of all enrolled students. Results that are below 5.00 ug/L should be reported on the school website. Please refer to Public Act 099-0922 or the Illinois Department of Public Health for specific reporting requirements. Suburban Laboratories will forward all results to the IDPH within seven (7) business days from the date of this report.

This report may not be reproduced, except in full, without the prior written approval of Suburban Laboratories, Inc. If you have any questions regarding these test results, please call me at (708) 544-3260.

Sincerely,

A handwritten signature in black ink that reads "Pat Rodriguez".

Pat Rodriguez
Project Manager
708-544-3260 ext 214
pat@suburbanlabs.com

SUBURBAN LABORATORIES, Inc.



1950 S. Batavia Ave., Suite 150 Geneva, Illinois 60134
 Tel. (708) 544-3260 • Toll Free (800) 783-LABS
 Fax (708) 544-8587
www.suburbanlabs.com

Client ID: Weaver Consultants Group

Project Name: Waldo Middle School Drinking Water Lead Analysis

Report Date: December 05, 2017

Workorder: 1711B25

Analyte: Lead		Method: EPA 200.8			Matrix: Drinking Water		
Sample ID	Client Sample ID	Result	MRL	Units	Date & Time Water System Last Used	Date Collected	Date Analyzed
1711B25-001A	WALD-01A~Lunchroom~First Draw	ND	2.00	µg/L	11/10/2017 19:30	11/11/2017	11/27/2017
1711B25-002A	WALD-01B~Lunchroom~Flush	ND	2.00	µg/L	11/10/2017 19:30	11/11/2017	11/27/2017
1711B25-003A	WALD-02A~Kitchen - At Smoothie Station~First Draw	ND	2.00	µg/L	11/10/2017 19:30	11/11/2017	11/27/2017
1711B25-004A	WALD-02B~Kitchen - At Smoothie Station~Flush	ND	2.00	µg/L	11/10/2017 19:30	11/11/2017	11/27/2017
1711B25-005A	WALD-03A~Kitchen - Near Office~First Draw	ND	2.00	µg/L	11/10/2017 19:30	11/11/2017	11/27/2017
1711B25-006A	WALD-03B~Kitchen - Near Office~Flush	ND	2.00	µg/L	11/10/2017 19:30	11/11/2017	11/27/2017
1711B25-007A	WALD-04A~Kitchen - Prep Area~First Draw	2.38	2.00	µg/L	11/10/2017 19:30	11/11/2017	11/27/2017
1711B25-008A	WALD-04B~Kitchen - Prep Area~Flush	ND	2.00	µg/L	11/10/2017 19:30	11/11/2017	11/27/2017
1711B25-009A	WALD-05A~Kitchen - Dish Washing Sink (Left Spout)~First Draw	ND	2.00	µg/L	11/10/2017 19:30	11/11/2017	11/27/2017
1711B25-010A	WALD-05B~Kitchen - Dish Washing Sink (Left Spout)~Flush	ND	2.00	µg/L	11/10/2017 19:30	11/11/2017	11/27/2017
1711B25-011A	WALD-06A~Kitchen - Dish Washing Sink (Right Spout)~First Draw	ND	2.00	µg/L	11/10/2017 19:30	11/11/2017	11/27/2017
1711B25-012A	WALD-07A~Teachers' Lounge~First Draw	ND	2.00	µg/L	11/10/2017 19:30	11/11/2017	11/27/2017
1711B25-013A	WALD-07B~Teachers' Lounge~Flush	ND	2.00	µg/L	11/10/2017 19:30	11/11/2017	11/27/2017
1711B25-014A	WALD-08A~Room 115A - Sink 1~First Draw	ND	2.00	µg/L	11/10/2017 19:30	11/11/2017	11/27/2017
1711B25-015A	WALD-08B~Room 115A - Sink 1~Flush	ND	2.00	µg/L	11/10/2017 19:30	11/11/2017	11/27/2017
1711B25-016A	WALD-09A~Room 115A - Sink 2~First Draw	ND	2.00	µg/L	11/10/2017 19:30	11/11/2017	11/27/2017
1711B25-017A	WALD-09B~Room 115A - Sink 2~Flush	ND	2.00	µg/L	11/10/2017 19:30	11/11/2017	11/27/2017
1711B25-018A	WALD-10A~Room 115A - Sink 3~First Draw	ND	2.00	µg/L	11/10/2017 19:30	11/11/2017	11/27/2017
1711B25-019A	WALD-10B~Room 115A - Sink 3~Flush	ND	2.00	µg/L	11/10/2017 19:30	11/11/2017	11/27/2017
1711B25-020A	WALD-11A~Room 115A - Sink 4~First Draw	ND	2.00	µg/L	11/10/2017 19:30	11/11/2017	11/27/2017
1711B25-021A	WALD-11B~Room 115A - Sink 4~Flush	ND	2.00	µg/L	11/10/2017 19:30	11/11/2017	11/27/2017
1711B25-022A	WALD-12A~Room 115A - Sink 5~First Draw	ND	2.00	µg/L	11/10/2017 19:30	11/11/2017	11/27/2017

SUBURBAN LABORATORIES, Inc.



1950 S. Batavia Ave., Suite 150 Geneva, Illinois 60134
 Tel. (708) 544-3260 • Toll Free (800) 783-LABS
 Fax (708) 544-8587
www.suburbanlabs.com

Client ID: Weaver Consultants Group

Project Name: Waldo Middle School Drinking Water Lead Analysis

Report Date: December 05, 2017

Workorder: 1711B25

Analyte: Lead		Method: EPA 200.8			Matrix: Drinking Water		
Sample ID	Client Sample ID	Result	MRL	Units	Date & Time Water System Last Used	Date Collected	Date Analyzed
1711B25-023A	WALD-12B~Room 115A - Sink 5~Flush	ND	2.00	µg/L	11/10/2017 19:30	11/11/2017	11/27/2017
1711B25-024A	WALD-13A~Room 115A - Sink 6~First Draw	ND	2.00	µg/L	11/10/2017 19:30	11/11/2017	11/27/2017
1711B25-025A	WALD-13B~Room 115A - Sink 6~Flush	ND	2.00	µg/L	11/10/2017 19:30	11/11/2017	11/27/2017
1711B25-026A	WALD-14A~Room 115A - Sink 7~First Draw	ND	2.00	µg/L	11/10/2017 19:30	11/11/2017	11/27/2017
1711B25-027A	WALD-14B~Room 115A - Sink 7~Flush	ND	2.00	µg/L	11/10/2017 19:30	11/11/2017	11/27/2017
1711B25-028A	WALD-15A~Room 115A - Sink 8~First Draw	ND	2.00	µg/L	11/10/2017 19:30	11/11/2017	11/27/2017
1711B25-029A	WALD-15B~Room 115A - Sink 8~Flush	ND	2.00	µg/L	11/10/2017 19:30	11/11/2017	11/27/2017
1711B25-030A	WALD-16A~Hallway Near Room 110~First Draw	ND	2.00	µg/L	11/10/2017 19:30	11/11/2017	11/27/2017
1711B25-031A	WALD-16B~Hallway Near Room 110~Flush	ND	2.00	µg/L	11/10/2017 19:30	11/11/2017	11/27/2017
1711B25-032A	WALD-17A~Hallway Near Room 104~First Draw	ND	2.00	µg/L	11/10/2017 19:30	11/11/2017	11/27/2017
1711B25-033A	WALD-17B~Hallway Near Room 104~Flush	ND	2.00	µg/L	11/10/2017 19:30	11/11/2017	11/27/2017
1711B25-034A	WALD-18A~Band Room 401~First Draw	ND	2.00	µg/L	11/10/2017 19:30	11/11/2017	11/27/2017
1711B25-035A	WALD-18B~Band Room 401~Flush	ND	2.00	µg/L	11/10/2017 19:30	11/11/2017	11/27/2017
1711B25-036A	WALD-19A~Hallway Near Room 312~First Draw	ND	2.00	µg/L	11/10/2017 19:30	11/11/2017	11/27/2017
1711B25-037A	WALD-19B~Hallway Near Room 312~Flush	ND	2.00	µg/L	11/10/2017 19:30	11/11/2017	11/27/2017
1711B25-038A	WALD-20A~Hallway Near Room 306~First Draw	ND	2.00	µg/L	11/10/2017 19:30	11/11/2017	11/27/2017
1711B25-039A	WALD-20B~Hallway Near Room 306~Flush	ND	2.00	µg/L	11/10/2017 19:30	11/11/2017	11/27/2017
1711B25-040A	WALD-21A~Hallway Near Room 214~First Draw	ND	2.00	µg/L	11/10/2017 19:30	11/11/2017	11/27/2017
1711B25-041A	WALD-21B~Hallway Near Room 214~Flush	ND	2.00	µg/L	11/10/2017 19:30	11/11/2017	11/27/2017
1711B25-042A	WALD-22A~Hallway Near Room 205~First Draw	ND	2.00	µg/L	11/10/2017 19:30	11/11/2017	11/27/2017
1711B25-043A	WALD-22B~Hallway Near Room 205~Flush	ND	2.00	µg/L	11/10/2017 19:30	11/11/2017	11/27/2017
1711B25-044A	WALD-23A~Room 204K - Nurse's Office~First Draw	ND	2.00	µg/L	11/10/2017 19:30	11/11/2017	11/27/2017
1711B25-045A	WALD-23B~Room 204K - Nurse's Office~Flush	ND	2.00	µg/L	11/10/2017 19:30	11/11/2017	11/27/2017
1711B25-046A	WALD-24A~Room 204L - Nurse's Office~First Draw	ND	2.00	µg/L	11/10/2017 19:30	11/11/2017	11/27/2017

SUBURBAN LABORATORIES, Inc.



1950 S. Batavia Ave., Suite 150 Geneva, Illinois 60134
Tel. (708) 544-3260 • Toll Free (800) 783-LABS
Fax (708) 544-8587
www.suburbanlabs.com

Client ID: Weaver Consultants Group

Project Name: Waldo Middle School Drinking Water Lead Analysis

Report Date: December 05, 2017

Workorder: 1711B25

Analyte: Lead

Method: EPA 200.8

Matrix: Drinking Water

Sample ID	Client Sample ID	Result	MRL	Units	Date & Time Water System Last Used	Date Collected	Date Analyzed
1711B25-047A	WALD-24B~Room 204L - Nurse's Office-Flush	ND	2.00	µg/L	11/10/2017 19:30	11/11/2017	11/27/2017
1711B25-048A	WALD-25A~Electrical Room~First Draw	153	2.00	µg/L	11/10/2017 19:30	11/11/2017	11/27/2017
1711B25-049A	WALD-25B~Electrical Room~Flush	3.59	2.00	µg/L	11/10/2017 19:30	11/11/2017	11/27/2017
1711B25-050A	WALD-26A~Boy's Locker Room~First Draw	ND	2.00	µg/L	11/10/2017 19:30	11/11/2017	11/27/2017
1711B25-051A	WALD-26B~Boy's Locker Room~Flush	ND	2.00	µg/L	11/10/2017 19:30	11/11/2017	11/27/2017

1711B2S - 001A - 3SA

FIELD DATA FORM

School/Facility Name
Waldo Middle School
ISBE ID: (ex:01-001-0001-01-00001)
310451310221003

Address
56 Jackson Street
Aurora, IL 60505

Sample Collector Name(s)
D. Kedrowski

MMDDYY

HH24MM

All samples must be collected in unpreserved 250 ml plastic bottles

Water system last used Date:

11/10/2017

Time : 19:30

	Bldg. ID	Bldg. Desc	Sample ID#	Sample Loc. Desc	Collection Date MMDDYYYY	Collection Time HH24MM	Fixture Type	Sample Type	Sample Vol.	Notes
Ex1:	0001	Main Building	01	1st Floor Classroom	02232017	800	O - Other	First Draw	250	Description if "Other" Is selected
Ex2:	0001	Main Building	01A	1st Floor Classroom	02232017	800	S - Sink	Flush	250	
1	310451310221003	School	WALD-01A	Lunchroom	11/11/2017	6:05	DF - Drinking Fountain	First Draw	250	
2	310451310221003	School	WALD-01B	Lunchroom	11/11/2017	6:05	DF - Drinking Fountain	Flush	250	
3	310451310221003	School	WALD-02A	Kitchen - At Smoothie Station	11/11/2017	6:07	KS - Kitchen Sink	First Draw	250	
4	310451310221003	School	WALD-02B	Kitchen - At Smoothie Station	11/11/2017	6:07	KS - Kitchen Sink	Flush	250	
5	310451310221003	School	WALD-03A	Kitchen - Near Office	11/11/2017	6:10	KS - Kitchen Sink	First Draw	250	
6	310451310221003	School	WALD-03B	Kitchen - Near Office	11/11/2017	6:10	KS - Kitchen Sink	Flush	250	
7	310451310221003	School	WALD-04A	Kitchen - Prep Area	11/11/2017	6:13	KS - Kitchen Sink	First Draw	250	
8	310451310221003	School	WALD-04B	Kitchen - Prep Area	11/11/2017	6:13	KS - Kitchen Sink	Flush	250	
9	310451310221003	School	WALD-05A	Dish Washing Sink (Le)	11/11/2017	6:19	KS - Kitchen Sink	First Draw	250	
10	310451310221003	School	WALD-05B	Dish Washing Sink (Le)	11/11/2017	6:19	KS - Kitchen Sink	Flush	250	
11	310451310221003	School	WALD-06A	Dish Washing Sink (Rig)	11/11/2017	6:20	S - Sink	First Draw	250	
12	310451310221003	School	WALD-07A	Teacher's Lounge	11/11/2017	6:22	O - Other	First Draw	250	Water Tap
13	310451310221003	School	WALD-07B	Teacher's Lounge	11/11/2017	6:22	O - Other	Flush	250	Water Tap
14	310451310221003	School	WALD-08A	Room 115A - Sink 1	11/11/2017	6:29	S - Sink	First Draw	250	
15	310451310221003	School	WALD-08B	Room 115A - Sink 1	11/11/2017	6:29	S - Sink	Flush	250	
16	310451310221003	School	WALD-09A	Room 115A - Sink 2	11/11/2017	6:30	S - Sink	First Draw	250	
17	310451310221003	School	WALD-09B	Room 115A - Sink 2	11/11/2017	6:30	S - Sink	Flush	250	
18	310451310221003	School	WALD-10A	Room 115A - Sink 3	11/11/2017	6:31	S - Sink	First Draw	250	
19	310451310221003	School	WALD-10B	Room 115A - Sink 3	11/11/2017	6:31	S - Sink	Flush	250	
20	310451310221003	School	WALD-11A	Room 115A - Sink 4	11/11/2017	6:33	S - Sink	First Draw	250	
21	310451310221003	School	WALD-11B	Room 115A - Sink 4	11/11/2017	6:33	S - Sink	Flush	250	
22	310451310221003	School	WALD-12A	Room 115A - Sink 5	11/11/2017	6:35	S - Sink	First Draw	250	
23	310451310221003	School	WALD-12B	Room 115A - Sink 5	11/11/2017	6:35	S - Sink	Flush	250	
24	310451310221003	School	WALD-13A	Room 115A - Sink 6	11/11/2017	6:37	S - Sink	First Draw	250	
25	310451310221003	School	WALD-13B	Room 115A - Sink 6	11/11/2017	6:37	S - Sink	Flush	250	
26	310451310221003	School	WALD-14A	Room 115A - Sink 7	11/11/2017	6:43	S - Sink	First Draw	250	
27	310451310221003	School	WALD-14B	Room 115A - Sink 7	11/11/2017	6:43	S - Sink	Flush	250	
28	310451310221003	School	WALD-15A	Room 115A - Sink 8	11/11/2017	6:45	S - Sink	First Draw	250	
29	310451310221003	School	WALD-15B	Room 115A - Sink 8	11/11/2017	6:45	S - Sink	Flush	250	
30	310451310221003	School	WALD-16A	Hallway Near Room 110	11/11/2017	6:49	DF - Drinking Fountain	First Draw	250	
31	310451310221003	School	WALD-16B	Hallway Near Room 110	11/11/2017	6:49	DF - Drinking Fountain	Flush	250	
32	310451310221003	School	WALD-17A	Hallway Near Room 104	11/11/2017	6:50	DF - Drinking Fountain	First Draw	250	
33	310451310221003	School	WALD-17B	Hallway Near Room 104	11/11/2017	6:50	DF - Drinking Fountain	Flush	250	
34	310451310221003	School	WALD-18A	Band Room 401	11/11/2017	6:58	DF - Drinking Fountain	First Draw	250	
35	310451310221003	School	WALD-18B	Band Room 401	11/11/2017	6:58	DF - Drinking Fountain	Flush	250	

11/11/17 8:44a

36	310451310221003	School	WALD-19A	Hallway Near Room 312	11/11/2017	7:02	DF - Drinking Fountain	First Draw	250	
37	310451310221003	School	WALD-19B	Hallway Near Room 312	11/11/2017	7:02	DF - Drinking Fountain	Flush	250	
38	310451310221003	School	WALD-20A	Hallway Near Room 306	11/11/2017	7:04	DF - Drinking Fountain	First Draw	250	
39	310451310221003	School	WALD-20B	Hallway Near Room 306	11/11/2017	7:04	DF - Drinking Fountain	Flush	250	
40	310451310221003	School	WALD-21A	Hallway Near Room 214	11/11/2017	7:11	DF - Drinking Fountain	First Draw	250	
41	310451310221003	School	WALD-21B	Hallway Near Room 214	11/11/2017	7:11	DF - Drinking Fountain	Flush	250	
42	310451310221003	School	WALD-22A	Hallway Near Room 205	11/11/2017	7:16	DF - Drinking Fountain	First Draw	250	
43	310451310221003	School	WALD-22B	Hallway Near Room 205	11/11/2017	7:16	DF - Drinking Fountain	Flush	250	
44	310451310221003	School	WALD-23A	bom 204K - Nurse's Offi	11/11/2017	7:20	S - Sink	First Draw	250	
45	310451310221003	School	WALD-23B	bom 204K - Nurse's Offi	11/11/2017	7:20	S - Sink	Flush	250	
46	310451310221003	School	WALD-24A	bom 204L - Nurse's Offi	11/11/2017	7:21	S - Sink	First Draw	250	
47	310451310221003	School	WALD-24B	bom 204L - Nurse's Offi	11/11/2017	7:21	S - Sink	Flush	250	
48	310451310221003	School	WALD-25A	Electrical Room	11/11/2017	7:26	O - Other	First Draw	250	Spigot to Main Line
49	310451310221003	School	WALD-25B	Electrical Room	11/11/2017	7:26	O - Other	Flush	250	Spigot to Main Line
50	310451310221003	School	WALD-26A	Boy's Locker Room	11/11/2017	7:32	DF - Drinking Fountain	First Draw	250	
51	310451310221003	School	WALD-26B	Boy's Locker Room	11/11/2017	7:32	DF - Drinking Fountain	Flush	250	
52										
53										
54										
55										
56										
57										
58										
59										
60										
61										
62										
63										
64										
65										
66										
67										
68										
69										
70										
71										
72										
73										
74										
75										
76										
77										
78										
79										
80										
81										
82										
83										
84										
85										
86										