

Administrative Service Center
231 East Indian Trail

Sample Location Description	Sample Type	Concentration (ug/L)
1st Floor - Lounge Room with Soda Machine	First Draw	ND
1st Floor - Lounge Room with Soda Machine	Flush	ND
1st Floor by Mechanical Room (Left)	First Draw	ND
1st Floor by Mechanical Room (Left)	Flush	ND
1st Floor by Mechanical Room (Right)	First Draw	ND
1st Floor by Mechanical Room (Right)	Flush	ND
1st Floor - Conference Room	First Draw	3.84
1st Floor - Conference Room	Flush	ND

IDPH requires school districts to notify parents of any water source that tests at 5 parts per billion (ppb) or above.

ND - None Detected

First Draw - First Sample Collected Before Use

Flush - Second Sample Collected After Flushing