

Allen Elementary School  
700 South Farnsworth Avenue  
Aurora, IL 60505

Sample Location Description	Sample Type	Concentration (ug/L)
1st Floor - PTO Kitchen (Left Sink)	First Draw	5.27
1st Floor - PTO Kitchen (Left Sink)	Flush	ND
1st Floor - PTO Kitchen (Right Sink)	First Draw	2.61
1st Floor - PTO Kitchen (Right Sink)	Flush	3.01
1st Floor - Room 169 - Music Room	First Draw	12.2
1st Floor - Room 169 - Music Room	Flush	ND
1st Floor - Between Boy's (165A) and Girl's (165 B) Bathrooms (Left)	First Draw	ND
1st Floor - Between Boy's (165A) and Girl's (165 B) Bathrooms (Left)	Flush	ND
1st Floor - Between Boy's (165A) and Girl's (165 B) Bathrooms (Right)	First Draw	ND
1st Floor - Between Boy's (165A) and Girl's (165 B) Bathrooms (Right)	Flush	ND
1st Floor - Outside Room 163 (Left)	First Draw	ND
1st Floor - Outside Room 163 (Left)	Flush	ND
1st Floor - Outside Room 163 (Right)	First Draw	ND
1st Floor - Outside Room 163 (Bottle Filler)	First Draw	ND
1st Floor - Outside Room 163 (Right)	Flush	ND
1st Floor - Room 163 - Nurse's Office Bathroom	First Draw	ND
1st Floor - Room 163 - Nurse's Office Bathroom	Flush	ND
1st Floor - Teachers' Lounge	First Draw	ND
1st Floor - Teachers' Lounge	Flush	ND
1st Floor - Room 102 - Kindergarten	First Draw	ND
1st Floor - Room 102 - Kindergarten	Flush	ND
1st Floor - Room 104 - 2nd Grade	First Draw	4.3
1st Floor - Room 104 - 2nd Grade	Flush	ND
1st Floor - Room 106	First Draw	40.1
1st Floor - Room 106	Flush	ND
1st Floor - Room 105	First Draw	5.05
1st Floor - Room 105	Flush	ND
1st Floor - Room 107	First Draw	3.39
1st Floor - Room 107	Flush	ND
1st Floor - Room 108	First Draw	3.28
1st Floor - Room 108	Flush	ND
1st Floor - Room 110 - Sprinkler Room (Non-Potable Source)	First Draw	22.7
1st Floor - Room 110 - Sprinkler Room (Non-Potable Source)	Flush	10.4
1st Floor - Across from Room 111 (Left)	First Draw	ND
1st Floor - Across from Room 111 (Left)	Flush	ND
1st Floor - Across from Room 111 (Right)	First Draw	ND
1st Floor - Across from Room 111 (Right)	Flush	ND
1st Floor - Room 111 - 2nd Grade	First Draw	ND
1st Floor - Room 111 - 2nd Grade	Flush	ND
1st Floor - Room 110 - 1st Grade	First Draw	ND
1st Floor - Room 110 - 1st Grade	Flush	ND
1st Floor - Room 112 - Kindergarten	First Draw	ND
1st Floor - Room 112 - Kindergarten	Flush	ND

Allen Elementary School  
700 South Farnsworth Avenue  
Aurora, IL 60505

Sample Location Description	Sample Type	Concentration (ug/L)
1st Floor - Room 113 - 2nd Grade	First Draw	ND
1st Floor - Room 113 - 2nd Grade	Flush	ND
1st Floor - Room 117 - 2nd Grade	First Draw	ND
1st Floor - Room 117 - 2nd Grade	Flush	ND
1st Floor - Room 119 - 4th Grade	First Draw	3.14
1st Floor - Room 119 - 4th Grade	Flush	ND
1st Floor - Room 121 - 4th Grade	First Draw	2.01
1st Floor - Room 121 - 4th Grade	Flush	ND
1st Floor - Room 123 - 4th Grade	First Draw	ND
1st Floor - Room 123 - 4th Grade	Flush	ND
1st Floor - Room 125	First Draw	2.77
1st Floor - Room 125	Flush	ND
1st Floor - Room 124	First Draw	ND
1st Floor - Room 124	Flush	ND
1st Floor - Room 122	First Draw	ND
1st Floor - Room 122	Flush	ND
1st Floor - Room 120 - Kindergarten	First Draw	2.04
1st Floor - Room 120 - Kindergarten	Flush	ND
1st Floor - Room 118 -Kindergarten	First Draw	ND
1st Floor - Room 118 - Kindergarten	Flush	ND
1st Floor - Outside Boy's (118 A) Bathroom (Left)	First Draw	ND
1st Floor - Outside Boy's (118 A) Bathroom (Left)	Flush	ND
1st Floor - Outside Boy's (118 A) Bathroom (Right)	First Draw	ND
1st Floor - Outside Boy's (118 A) Bathroom (Right)	Flush	ND
1st Floor - Outside Girl's (118 D) Bathroom (Left)	First Draw	ND
1st Floor - Outside Girl's (118 D) Bathroom (Left)	Flush	ND
1st Floor - Outside Girl's (118 D) Bathroom (Right)	First Draw	ND
1st Floor - Outside Girl's (118 D) Bathroom (Right)	Flush	ND
1st Floor - Room 130	First Draw	ND
1st Floor - Room 130	Flush	ND
1st Floor - Room 131 - 1st Grade	First Draw	ND
1st Floor - Room 131 - 1st Grade	Flush	ND
1st Floor - Room 132 - 1st Grade	First Draw	ND
1st Floor - Room 132 - 1st Grade	Flush	ND
1st Floor - Room 133 - Kindergarten	First Draw	ND
1st Floor - Room 133 - Kindergarten	Flush	ND
1st Floor - Room 134 - 3rd Grade	First Draw	2.78
1st Floor - Room 134 - 3rd Grade	Flush	ND
1st Floor - Room 136 - 5th Grade	First Draw	ND
1st Floor - Room 136 - 5th Grade	Flush	ND
1st Floor - Room 135 - 5th Grade	First Draw	ND
1st Floor - Room 135 - 5th Grade	Flush	ND
1st Floor - Room 137 - 5th Grade	First Draw	ND
1st Floor - Room 137 - 5th Grade	Flush	ND

Allen Elementary School  
700 South Farnsworth Avenue  
Aurora, IL 60505

Sample Location Description	Sample Type	Concentration (ug/L)
1st Floor - Room 138	First Draw	ND
1st Floor - Room 138	Flush	ND
1st Floor - Outside Bathroom 141 A and Door Entrance 6 (Left	First Draw	ND
1st Floor - Outside Bathroom 141 A and Door Entrance 6 (Left	Flush	ND
1st Floor - Outside Bathroom 141 A and Door Entrance 6 (Right)	First Draw	ND
1st Floor - Outside Bathroom 141 A and Door Entrance 6 (Right)	Flush	ND
1st Floor - Cafeteria by Fire Extinguisher (Left)	First Draw	ND
1st Floor - Cafeteria by Fire Extinguisher (Left)	Flush	ND
1st Floor - Cafeteria by Fire Extinguisher (Right)	First Draw	ND
1st Floor - Cafeteria by Fire Extinguisher (Right)	Flush	ND
1st Floor - Kitchen (Hand Sink)	First Draw	ND
1st Floor - Kitchen (Hand Sink)	Flush	ND
1st Floor - Kitchen (Left Spout)	First Draw	ND
1st Floor - Kitchen (Left Spout)	Flush	ND
1st Floor - Kitchen (Right Spout)	First Draw	ND
1st Floor - Kitchen (Right Spout)	Flush	ND
1st Floor - Room 145 - 5th Grade	First Draw	ND
1st Floor - Room 145 - 5th Grade	Flush	ND
1st Floor - Room 149 - 3rd Grade	First Draw	ND
1st Floor - Room 149 - 3rd Grade	Flush	ND
1st Floor - Room 148 - 3rd Grade	First Draw	ND
1st Floor - Room 148 - 3rd Grade	Flush	ND
1st Floor - Room 150 - 3rd Grade	First Draw	3.11
1st Floor - Room 150 - 3rd Grade	Flush	ND
1st Floor - Room 151 - 5th Grade	First Draw	3.94
1st Floor - Room 151 - 5th Grade	Flush	ND
1st Floor - Outside of Room 150B (Left)	First Draw	ND
1st Floor - Outside of Room 150B (Left)	Flush	ND
1st Floor - Outside of Room 150B (Right)	First Draw	ND
1st Floor - Outside of Room 150B (Right)	Flush	ND
1st Floor - Across from Room 155	First Draw	ND
1st Floor - Across from Room 155	Flush	3.61

IDPH requires school districts to notify parents of any water source that tests at 5 parts per billion (ppb) or above.

ND - None Detected

First Draw - First Sample Collected Before Use

Flush - Second Sample Collected After Flushing