

Bardwell Elementary School
550 South Lincoln Avenue
Aurora, IL 60505

Sample Location Description	Sample Type	Concentration (ug/L)
Hallway by Door 6 (Left)	First Draw	ND
Hallway by Door 6 (Left)	Flush	ND
Hallway by Door 6 (Right)	First Draw	ND
Hallway by Door 6 (Right)	Flush	ND
Lunchroom	First Draw	ND
Lunchroom	Flush	ND
Kitchen	First Draw	ND
Kitchen	Flush	ND
Classroom 12	First Draw	ND
Classroom 12	Flush	ND
Classroom 10	First Draw	14.3
Classroom 10	Flush	2.55
Staff Lounge	First Draw	ND
Staff Lounge	Flush	ND
Room 11B - Nurse's Office Bathroom	First Draw	ND
Room 11B - Nurse's Office Bathroom	Flush	ND
Hallway by Classroom 8 (Left)	First Draw	ND
Hallway by Classroom 8 (Left)	Flush	ND
Hallway by Classroom 8 (Right)	First Draw	ND
Hallway by Classroom 8 (Right)	Flush	ND
Classroom 8	First Draw	ND
Classroom 8	Flush	ND
Principal's Office	First Draw	3.34
Principal's Office	Flush	ND
Classroom 2	First Draw	ND
Classroom 2	Flush	ND
Classroom 4	First Draw	ND
Classroom 4	Flush	ND
Hallway by Classroom 35 (Left)	First Draw	ND
Hallway by Classroom 35 (Left)	Flush	ND
Hallway by Classroom 35 (Right)	First Draw	ND
Hallway by Classroom 35 (Right)	Flush	ND
Hallway by Classroom 21 (Left)	First Draw	ND
Hallway by Classroom 21 (Left)	Flush	ND
Hallway by Classroom 21 (Right)	First Draw	ND
Hallway by Classroom 21 (Right)	Flush	ND
Hallway by Classroom 46A (Left)	First Draw	ND
Hallway by Classroom 46A (Left)	Flush	ND
Hallway by Classroom 46A (Right)	First Draw	ND
Hallway by Classroom 46A (Right)	Flush	ND
Main Line (Non-Potable Source)	First Draw	309

IDPH requires school districts to notify parents of any water source that tests at 5 parts per billion (ppb) or above.

ND - None Detected

First Draw - First Sample Collected Before Use

Flush - Second Sample Collected After Flushing