

Beaupre Elementary School  
954 East Benton Street  
Aurora, IL 60505

Sample Location Description	Sample Type	Concentration (ug/L)
Basement Floor-Fire Room	First Draw	ND
Basement Floor-Fire Room	Flush	ND
Water Main-Electrical Room (Non-Potable Source)	First Draw	ND
Water Main-Electrical Room (Non-Potable Source)	Flush	ND
Sub-Basement Floor-Kitchen	First Draw	ND
Sub-Basement Floor-Kitchen	Flush	ND
Basement Floor-Girls Bathroom	First Draw	ND
Basement Floor-Girls Bathroom	Flush	ND
2nd Floor-Outside Main Office	First Draw	ND
2nd Floor-Outside Main Office	Flush	ND
2nd Floor- Nurse Office Rm.205	First Draw	ND
2nd Floor- Nurse Office Rm.205	Flush	ND
2nd Floor-Rm. 207	First Draw	ND
2nd Floor-Rm. 207	Flush	ND
2nd Floor-Rm. 201	First Draw	ND
2nd Floor-Rm. 201	Flush	ND
3rd Floor-Rm. 304	First Draw	ND
3rd Floor-Rm. 304	Flush	ND
3rd Floor-Rm. 313	First Draw	ND
3rd Floor-Rm. 313	Flush	ND
3rd Floor-Rm. 309	First Draw	ND
3rd Floor-Rm. 309	Flush	ND
3rd Floor-Rm. 310	First Draw	ND
3rd Floor-Rm. 310	Flush	ND
1st Floor-Rm. 210	First Draw	2.32
1st Floor-Rm. 210	Flush	ND
1st Floor-Rm. 209	First Draw	6.38
1st Floor-Rm. 209	Flush	ND
2nd Floor-Teacher Lounge	First Draw	ND
2nd Floor-Teacher Lounge	Flush	ND

IDPH requires school districts to notify parents of any water source that tests at 5 parts per billion (ppb) or above.

ND - None Detected

First Draw - First Sample Collected Before Use

Flush - Second Sample Collected After Flushing