

Benavides Kindergarten Center  
250 Indian Trail  
Aurora, IL 60505

Sample Location Description	Sample Type	Concentration (ug/L)
1st Floor - Corner By Hall Bathrooms (Left)	First Draw	ND
1st Floor - Corner By Hall Bathrooms (Left)	Flush	ND
1st Floor - Corner By Hall Bathrooms (Right)	First Draw	ND
1st Floor - Corner By Hall Bathrooms (Bottle Filler)	First Draw	ND
1st Floor - Corner By Hall Bathrooms (Right)	Flush	ND
1st Floor - Hallway by Room 158 (Left Sink)	First Draw	ND
1st Floor - Hallway by Room 158 (Left Sink)	Flush	ND
1st Floor - Hallway by Room 158 (Right Sink)	First Draw	ND
1st Floor - Hallway by Room 158 (Right Sink)	Flush	ND
1st Floor - Room 136 - Staff Lounge	First Draw	ND
1st Floor - Room 136 - Staff Lounge	Flush	ND
1st Floor - Room 129 - Kitchen	First Draw	ND
1st Floor - Room 129 - Kitchen	Flush	ND
1st Floor - Room 129 - Kitchen (Hand Sink)	First Draw	ND
1st Floor - Room 129 - Kitchen (Hand Sink)	Flush	ND
1st Floor - By Bathrooms Outside of Gym (Left)	First Draw	ND
1st Floor - By Bathrooms Outside of Gym (Left)	Flush	ND
1st Floor - By Bathrooms Outside of Gym (Right)	First Draw	ND
1st Floor - By Bathrooms Outside of Gym (Bottle Filler)	First Draw	ND
1st Floor - By Bathrooms Outside of Gym (Right)	Flush	ND
1st Floor - Hallway by Room 121 (Left Sink)	First Draw	ND
1st Floor - Hallway by Room 121 (Left Sink)	Flush	ND
1st Floor - Hallway by Room 121 (Right Sink)	First Draw	2.42
1st Floor - Hallway by Room 121 (Right Sink)	Flush	ND
1st Floor - Classroom 111	First Draw	ND
1st Floor - Classroom 111	Flush	ND
1st Floor - Hallway by Room 125 (Left Sink)	First Draw	ND
1st Floor - Hallway by Room 125 (Left Sink)	Flush	ND
1st Floor - Hallway by Room 125 (Right Sink)	First Draw	ND
1st Floor - Hallway by Room 125 (Right Sink)	Flush	ND
1st Floor - By Bathrooms and Room 149 (Left)	First Draw	ND
1st Floor - By Bathrooms and Room 149 (Left)	Flush	4.75
1st Floor - By Bathrooms and Room 149 (Right)	First Draw	ND
1st Floor - By Bathrooms and Room 149 (Bottle Filler)	First Draw	ND
1st Floor - By Bathrooms and Room 149 (Right)	Flush	ND
1st Floor - Room 125A - Water Main (Non-Potable Source)	First Draw	8.1
1st Floor - Room 125A - Water Main (Non-Potable Source)	Flush	ND
1st Floor - Room 145 - Nurse's Office	First Draw	ND
1st Floor - Room 145 - Nurse's Office	Flush	ND

IDPH requires school districts to notify parents of any water source that tests at 5 parts per billion (ppb) or above.

ND - None Detected

First Draw - First Sample Collected Before Use

Flush - Second Sample Collected After Flushing