

Brady Elementary School
600 Columbia Street
Aurora, IL 60505

Sample Location Description	Sample Type	Concentration (ug/L)
1st Floor-Entrance 4-Rms. 118-114 (Left)	First Draw	ND
1st Floor-Entrance 4-Rms. 118-114 (Left)	Flush	ND
1st Floor-Entrance 4-Rms. 118-114 (Right)	First Draw	ND
1st Floor-Entrance 4-Rms. 118-114 (Right)	Flush	ND
1st Floor-Rm. 118	First Draw	8.14
1st Floor-Rm. 118	Flush	ND
1st Floor-Rm. 114	First Draw	ND
1st Floor-Rm. 114	Flush	ND
1st Floor-Kitchen	First Draw	6.94
1st Floor-Kitchen	Flush	ND
1st Floor-Rm. 106	First Draw	ND
1st Floor-Rm. 106	Flush	ND
1st Floor-Water Line-Behind Rm. 108 (Non-Potable Source)	First Draw	ND
1st Floor-Water Line-Behind Rm. 108 (Non-Potable Source)	Flush	2.33
Basement Floor-Outside of Gym By Stairs	First Draw	ND
Basement Floor-Outside of Gym By Stairs	Flush	ND
1st Floor-Rm. 102	First Draw	ND
1st Floor-Rm. 102	Flush	ND
2nd Floor-Exit 7	First Draw	ND
2nd Floor-Exit 7	Flush	ND
2nd Floor-Nurse Office	First Draw	ND
2nd Floor- Nurse Office	Flush	ND
2nd Floor-Exit 4	First Draw	ND
2nd Floor-Exit 4	Flush	ND
2nd Floor-Downstairs-Rm. 218/220 (Left)	First Draw	ND
2nd Floor-Downstairs-Rm. 218/220 (Left)	Flush	ND
2nd Floor-Downstairs-Rm. 218/220 (Right)	First Draw	ND
2nd Floor-Downstairs-Rm. 218/220 (Right)	Flush	ND
2nd Floor-Downstairs-Rm. 220	First Draw	ND
2nd Floor-Downstairs-Rm. 220	Flush	ND
2nd Floor-Downstairs-Rm. 218/220	First Draw	ND
2nd Floor-Downstairs-Rm. 218/220	Flush	3.18
2nd Floor-Downstairs-Rm. 224	First Draw	ND
2nd Floor-Downstairs-Rm. 224	Flush	ND
2nd Floor-Rm. 222	First Draw	3.97
2nd Floor-Rm. 222	Flush	3.56
3rd Floor-By Rm. 219	First Draw	ND
3rd Floor-By Rm. 219	Flush	ND
3rd Floor-Conference Room	First Draw	ND
3rd Floor-Conference Room	Flush	ND
3rd Floor-Teacher Lounge	First Draw	ND
3rd Floor-Teacher Lounge	Flush	ND
3rd Floor-Exit 7 by Rm. 302	First Draw	ND
3rd Floor-Exit 7 by Rm. 302	Flush	ND

ND - None Detected

First Draw - First Sample Collected Before Use

Flush - Second Sample Collected After Flushing

IDPH requires school districts to notify parents of any water source that tests at 5 parts per billion (ppb) or above.