

Building and Grounds Center  
411 Hill Avenue  
Aurora, IL 60505

Sample Location Description	Sample Type	Concentration (ug/L)
1st Floor- Closet In Kitchen (Non-Potable Source)	First Draw	12.7
1st Floor- Closet In Kitchen (Non-Potable Source)	Flush	5.74
1st Floor- Lunch Area	First Draw	ND
1st Floor- Lunch Area	Flush	ND

IDPH requires school districts to notify parents of any water source that tests at 5 parts per billion (ppb) or above.

ND - None Detected

First Draw - First Sample Collected Before Use

Flush - Second Sample Collected After Flushing