

Child Service Center
1480 Reckinger Road
Aurora, IL 60505

Sample Location Description	Sample Type	Concentration (ug/L)
1st Floor - By Women's Bathroom and Big Cabinets (Left)	First Draw	ND
1st Floor - By Women's Bathroom and Big Cabinets (Left)	Flush	ND
1st Floor - By Women's Bathroom and Big Cabinets (Right)	First Draw	ND
1st Floor - By Women's Bathroom and Big Cabinets (Right)	Flush	ND
1st Floor - Water Main (Non-Potable Source)	First Draw	137
1st Floor - Water Main (Non-Potable Source)	Flush	6.13
1st Floor - By Room S103	First Draw	ND
1st Floor - By Room S103	Flush	ND
1st Floor - By Nurse Office (Left)	First Draw	ND
1st Floor by Nurse Office (Left)	Flush	ND
1st Floor by Nurse Office (Right)	First Draw	ND
1st Floor by Nurse Office (Right)	Flush	ND
1st Floor - Teachers' Lounge	First Draw	ND
1st Floor - Teachers' Lounge	Flush	ND
1St Floor - Room E130	First Draw	ND
1St Floor - Room E130	Flush	ND
1st Floor - Nurse's Office	First Draw	ND
1st Floor - Nurse's Office	Flush	ND
1st Floor - Room N133 (Left Sink)	First Draw	ND
1st Floor - Room N133 (Left Sink)	Flush	ND
1st Floor - Room N133 (Right Sink)	First Draw	ND
1st Floor - Room N133 (Right Sink)	Flush	ND
1st Floor - Room N136 (Left Sink)	First Draw	ND
1st Floor - Room N136 (Left Sink)	Flush	ND
1st Floor - Room N136 (Right Sink)	First Draw	ND
1st Floor - Room N136 (Right Sink)	Flush	ND
1st Floor - Room N134 (Left Sink)	First Draw	ND
1st Floor - Room N134 (Left Sink)	Flush	ND
1st Floor - Room N134 (Right Sink)	First Draw	ND
1st Floor - Room N134 (Right Sink)	Flush	ND
1st Floor - Room N135 (Left Sink)	First Draw	ND
1st Floor - Room N135 (Left Sink)	Flush	ND
1st Floor - Room N135 (Right Sink)	First Draw	ND
1st Floor - Room N135 (Right Sink)	Flush	ND
1st Floor - Room W137 (Left Sink)	First Draw	ND
1st Floor - Room W137 (Left Sink)	Flush	ND
1st Floor - Room W137 (Right Sink)	First Draw	ND
1st Floor - Room W137 (Right Sink)	Flush	ND
1st Floor - Room W147 (Left Sink)	First Draw	ND
1st Floor - Room W147 (Left Sink)	Flush	ND
1st Floor - Room W147 (Right Sink)	First Draw	ND
1st Floor - Room W147 (Right Sink)	Flush	ND
1st Floor - Room W138 (Left Sink)	First Draw	ND
1st Floor - Room W138 (Left Sink)	Flush	ND

Child Service Center
1480 Reckinger Road
Aurora, IL 60505

Sample Location Description	Sample Type	Concentration (ug/L)
1st Floor - Room W138 (Right Sink)	First Draw	ND
1st Floor - Room W138 (Right Sink)	Flush	ND
1st Floor - Room W146 (Left Sink)	First Draw	ND
1st Floor - Room W146 (Left Sink)	Flush	ND
1st Floor - Room W146 (Right Sink)	First Draw	ND
1st Floor - Room W146 (Right Sink)	Flush	ND

IDPH requires school districts to notify parents of any water source that tests at 5 parts per billion (ppb) or above.

ND - None Detected

First Draw - First Sample Collected Before Use

Flush - Second Sample Collected After Flushing