

Cowherd Middle School
441 Farnsworth Avenue
Aurora, IL 60505

Sample Location Description	Sample Type	Concentration (ug/L)
1st Floor - By Entrance 8 and Men's Bathroom (Left)	First Draw	ND
1st Floor - By Entrance 8 and Men's Bathroom (Left)	Flush	ND
1st Floor - By Entrance 8 and Men's Bathroom (Right)	First Draw	ND
1st Floor - By Entrance 8 and Men's Bathroom (Right)	Flush	ND
1st Floor - By Elevator (Left)	First Draw	ND
1st Floor - By Elevator (Left)	Flush	ND
1st Floor - By Elevator (Right)	First Draw	ND
1st Floor - By Elevator (Right)	Flush	ND
1st Floor - By Café Back Hallway (Left)	First Draw	ND
1st Floor - By Café Back Hallway (Left)	Flush	ND
1st Floor - By Café Back Hallway (Right)	First Draw	ND
1st Floor - By Café Back Hallway (Right)	Flush	ND
1st Floor - Room 903 - By Fabric Cabinet	First Draw	ND
1st Floor - Room 903 - By Fabric Cabinet	Flush	ND
1st Floor - Room 903 - By "Our School" Poster	First Draw	ND
1st Floor - Room 903 - By "Our School" Poster	Flush	ND
1st Floor - Room 903 - By "Be Polite" Poster	First Draw	ND
1st Floor - Room 903 - By "Be Polite" Poster	Flush	ND
1st Floor - Room 903 - By 009 Curtains	First Draw	ND
1st Floor - Room 903 - By 009 Curtains	Flush	ND
1st Floor - Room 903 - By Cook Sign	First Draw	ND
1st Floor - Room 903 - By Cook Sign	Flush	ND
1st Floor - Room 903 - By Pink Flower	First Draw	ND
1st Floor - Room 903 - By Pink Flower	Flush	ND
1st Floor - Room 903 - By Thermostat	First Draw	ND
1st Floor - Room 903 - By Thermostat	Flush	ND
1st Floor - Lounge (washer/dryer)	First Draw	ND
1st Floor - Lounge (washer/dryer)	Flush	ND
1st Floor - By Entrance 21 - Left Set (Left)	First Draw	ND
1st Floor - By Entrance 21 - Left Set (Left)	Flush	ND
1st Floor - By Entrance 21 - Left Set (Right)	First Draw	ND
1st Floor - By Entrance 21 - Left Set (Right)	Flush	ND
1st Floor - By Entrance 21 - Right Set (Left)	First Draw	ND
1st Floor - By Entrance 21 - Right Set (Left)	Flush	ND
1st Floor - By Entrance 21 - Right Set (Right)	First Draw	ND
1st Floor - By Entrance 21 - Right Set (Right)	Flush	ND
1st Floor - By "THINK" Sign (Left)	First Draw	ND
1st Floor - By "THINK" Sign (Left)	Flush	ND
1st Floor - By "THINK" Sign (Right)	First Draw	ND
1st Floor - By "THINK" Sign (Right)	Flush	ND
1st Floor - Lunchroom Line	First Draw	ND
1st Floor - Lunchroom Line	Flush	ND
1st Floor - Kitchen (Left Spout, 2-Basin)	First Draw	ND
1st Floor - Kitchen (Left Spout, 2-Basin)	Flush	ND

Cowherd Middle School
441 Farnsworth Avenue
Aurora, IL 60505

Sample Location Description	Sample Type	Concentration (ug/L)
1st Floor - Kitchen (Right Spout, 2-Basin)	First Draw	ND
1st Floor - Kitchen (Right Spout, 2-Basin)	Flush	ND
1st Floor - Kitchen (Left Spout, 3-Basin)	First Draw	ND
1st Floor - Kitchen (Left Spout, 3-Basin)	Flush	ND
1st Floor - Kitchen (Right Spout, 3-Basin)	First Draw	ND
1st Floor - Kitchen (Right Spout, 3-Basin)	Flush	ND
Basement - By Gym	First Draw	ND
Basement - By Gym	Flush	ND
1st Floor - Water Main (Non-Potable Source)	First Draw	45.5
1st Floor - Water Main (Non-Potable Source)	Flush	ND

IDPH requires school districts to notify parents of any water source that tests at 5 parts per billion (ppb) or above.

ND - None Detected

First Draw - First Sample Collected Before Use

Flush - Second Sample Collected After Flushing