

Dieterich Elementary School
1141 Jackson Street
Aurora, IL 60505

Sample Location Description	Sample Type	Concentration (ug/L)
Kitchen (1-Basin)	First Draw	ND
Kitchen (1-Basin)	Flush	ND
Kitchen (Left Faucet)	First Draw	5.14
Kitchen (Left Faucet)	Flush	ND
Kitchen (Right Faucet)	First Draw	ND
Kitchen (Right Faucet)	Flush	ND
Multipurpose Room (Left)	First Draw	ND
Multipurpose Room (Left)	Flush	ND
Multipurpose Room (Right)	First Draw	ND
Multipurpose Room (Right)	Flush	ND
Classroom 27	First Draw	ND
Classroom 27	Flush	ND
Classroom 28	First Draw	ND
Classroom 28	Flush	ND
Classroom 29	First Draw	ND
Classroom 29	Flush	ND
Classroom 30	First Draw	ND
Classroom 30	Flush	ND
Hallway by Bathroom (27A) (Left)	First Draw	ND
Hallway by Bathroom (27A) (Left)	Flush	ND
Hallway by Bathroom (27A) (Right)	First Draw	ND
Hallway by Bathroom (27A) (Right)	Flush	ND
Classroom 17	First Draw	ND
Classroom 17	Flush	ND
Classroom 19	First Draw	ND
Classroom 19	Flush	ND
Classroom 20	First Draw	ND
Classroom 20	Flush	ND
Classroom 35	First Draw	ND
Classroom 35	Flush	ND
Classroom 36	First Draw	ND
Classroom 36	Flush	ND
Classroom 38	First Draw	ND
Classroom 38	Flush	ND
Classroom 37	First Draw	2.03
Classroom 37	Flush	ND
Hallway by Bathroom (35A) (Left)	First Draw	ND
Hallway by Bathroom (35A) (Left)	Flush	ND
Hallway by Bathroom (35A) (Right)	First Draw	ND
Hallway by Bathroom (35A) (Right)	Flush	ND
Classroom 8	First Draw	3.95
Classroom 8	Flush	ND
Classroom 7	First Draw	ND
Classroom 7	Flush	ND

Dieterich Elementary School
1141 Jackson Street
Aurora, IL 60505

Sample Location Description	Sample Type	Concentration (ug/L)
Room 28 - Staff Lounge	First Draw	ND
Room 28 - Staff Lounge	Flush	ND
Classroom 10	First Draw	ND
Classroom 10	Flush	ND
Classroom 11	First Draw	24.9
Classroom 11	Flush	ND
Classroom 12	First Draw	6.76
Classroom 12	Flush	ND
Classroom 13	First Draw	ND
Classroom 13	Flush	ND
Hallway by Room 14B (Left)	First Draw	ND
Hallway by Room 14B (Left)	Flush	ND
Hallway by Room 14B (Right)	First Draw	ND
Hallway by Room 14B (Right)	Flush	ND
Room 25D - Nurse's Office Bathroom	First Draw	ND
Room 25D - Nurse's Office Bathroom	Flush	ND
Hallway by Room 25C (Left)	First Draw	ND
Hallway by Room 25C (Left)	Flush	ND
Hallway by Room 25C (Right)	First Draw	ND
Hallway by Room 25C (Right)	Flush	ND
Classroom 1	First Draw	4.46
Classroom 1	Flush	ND
Classroom 1	First Draw	ND
Classroom 1	Flush	ND
Classroom 2	First Draw	ND
Classroom 2	Flush	ND
Classroom 2	First Draw	ND
Classroom 2	Flush	ND
Hallway by Front Office (Left)	First Draw	ND
Hallway by Front Office (Left)	Flush	ND
Hallway by Front Office (Right)	First Draw	ND
Hallway by Front Office (Right)	Flush	ND
Main Line (Non-Potable Source)	First Draw	202

IDPH requires school districts to notify parents of any water source that tests at 5 parts per billion (ppb) or above.

ND - None Detected

First Draw - First Sample Collected Before Use

Flush - Second Sample Collected After Flushing