

Aurora East Extension High School
1685 Farnsworth Avenue
Aurora, IL 60505

Sample Location Description	Sample Type	Concentration (ug/L)
1st Floor - Kitchen Area	First Draw	ND
1st Floor - Kitchen Area	Flush	ND
2nd Floor - Between Bathrooms by Room 208 (Left)	First Draw	ND
2nd Floor - Between Bathrooms by Room 208 (Left)	Flush	ND
2nd Floor - Between Bathrooms by Room 208 (Right)	First Draw	ND
2nd Floor - Between Bathrooms by Room 208 (Right)	Flush	ND
1st Floor- Between Bathrooms by Room 131 (Left)	First Draw	ND
1st Floor- Between Bathrooms by Room 131 (Left)	Flush	ND
1st Floor- Between Bathrooms by Room 131 (Right)	First Draw	ND
1st Floor- Between Bathrooms by Room 131 (Right)	Flush	ND
Water Main Faucet (Non-Potable Source)	First Draw	111
Water Main Faucet (Non-Potable Source)	Flush	31.4

IDPH requires school districts to notify parents of any water source that tests at 5 parts per billion (ppb) or above.

ND - None Detected

First Draw - First Sample Collected Before Use

Flush - Second Sample Collected After Flushing