

Fred Rogers Magnet Academy
157 North Root Street
Aurora, IL 60505

Sample Location Description	Sample Type	Concentration (ug/L)
4th Floor-Tropy Case (Left)	First Draw	ND
4th Floor-Tropy Case (Bottle Filler)	First Draw	ND
4th Floor-Tropy Case (Left)	Flush	ND
4th Floor-Tropy Case (Right)	First Draw	ND
4th Floor-Tropy Case (Right)	Flush	ND
3rd Floor- Rm.313 (Left)	First Draw	ND
3rd Floor- Rm.313 (Bottle Filler)	First Draw	ND
3rd Floor- Rm.313 (Left)	Flush	ND
3rd Floor- Rm.313 (Right)	First Draw	ND
3rd Floor- Rm.313 (Right)	Flush	ND
2nd Floor-Main Office (Left)	First Draw	ND
2nd Floor-Main Office (Bottle Filler)	First Draw	ND
2nd Floor-Main Office (Left)	Flush	ND
2nd Floor-Main Office (Right)	First Draw	ND
2nd Floor-Main Office (Right)	Flush	ND
2nd Floor-Nurse Office	First Draw	ND
2nd Floor-Nurse Office	Flush	ND
2nd Floor-Main Office-Rm.202	First Draw	ND
2nd Floor-Main Office-Rm.202	Flush	ND
2nd Floor-Facility Lounge	First Draw	ND
2nd Floor-Facility Lounge	Flush	ND
2nd Floor-Boys Bathroom	First Draw	ND
2nd Floor-Boys Bathroom (Bottle Filler)	First Draw	ND
2nd Floor-Boys Bathroom	Flush	ND
1st Floor-By Rm. 122	First Draw	ND
1st Floor-By Rm. 122	Flush	ND
1st Floor-By janitor Closet 103 (Left)	First Draw	ND
1st Floor-By janitor Closet 103 (Bottle Filler)	First Draw	ND
1st Floor-By janitor Closet 103 (Left)	Flush	ND
1st Floor-By janitor Closet 103 (Right)	First Draw	ND
1st Floor-By janitor Closet 103 (Right)	Flush	ND
1st Floor-Water Line (Non-Potable Source)	First Draw	10.5
1st Floor-Water Line (Non-Potable Source)	Flush	6.01
1st Floor-Kitchen -2 Spout (Left)	First Draw	ND
1st Floor-Kitchen -2 Spout (Left)	Flush	ND
1st Floor-Kitchen -2 Spout (Right)	First Draw	ND
1st Floor-Kitchen -2 Spout (Right)	Flush	ND
1st Floor-Kitchen Side Sink	First Draw	ND
1st Floor-Kitchen Side Sink	Flush	ND
1st Floor-Kitchen Hand Sink	First Draw	ND
1st Floor-Kitchen Hand Sink	Flush	ND
1st Floor-Entrance 7	First Draw	ND
1st Floor-Entrance 7	Flush	ND

ND - None Detected

First Draw - First Sample Collected Before Use

Flush - Second Sample Collected After Flushing

IDPH requires school districts to notify parents of any water source that tests at 5 parts per billion (ppb) or above.