

Hermes Elementary School
1000 Jungels Avenue
Aurora, IL 60505

Sample Location Description	Sample Type	Concentration (ug/L)
Classroom 101 (Stainless Steel)	First Draw	2.73
Classroom 101 (Stainless Steel)	Flush	ND
Classroom 101 (Porcelain)	First Draw	4.5
Classroom 101 (Porcelain)	Flush	2.04
Classroom 102	First Draw	2.47
Classroom 102	Flush	ND
Classroom 104	First Draw	3.39
Classroom 104	Flush	ND
Classroom 106	First Draw	3.77
Classroom 106	Flush	ND
Classroom 105	First Draw	4.59
Classroom 105	Flush	ND
Classroom 105 - Main Line (Non-Potable Source)	First Draw	192
Classroom 105 - Main Line (Non-Potable Source)	Flush	67.7
Classroom 108	First Draw	4.37
Classroom 108	Flush	ND
Corridor by Room 108	First Draw	4.49
Corridor by Room 108	Flush	10.8
Corridor by Office	First Draw	ND
Corridor by Office	Flush	ND
Main Office Storage	First Draw	7.06
Main Office Storage	Flush	ND
Classroom 112	First Draw	10.3
Classroom 112	Flush	9.06
Classroom 113	First Draw	32.8
Classroom 113	Flush	ND
Classroom 114	First Draw	10.9
Classroom 114	Flush	ND
Corridor by (2028) Girl's Bathroom	First Draw	ND
Corridor by (2028) Girl's Bathroom	Flush	ND
Room 204A - Nurse's Office	First Draw	16.7
Room 204A - Nurse's Office	Flush	ND
Room 206	First Draw	11.3
Room 206	Flush	ND
Room 203	First Draw	6.18
Room 203	Flush	ND
Room 208	First Draw	7.57
Room 208	Flush	2.66
Room 205	First Draw	5.65
Room 205	Flush	ND
Corridor by Mechanical Room	First Draw	ND
Corridor by Mechanical Room	Flush	4.44
Room 308	First Draw	173
Room 308	Flush	ND

Hermes Elementary School
1000 Jungels Avenue
Aurora, IL 60505

Sample Location Description	Sample Type	Concentration (ug/L)
Room 309	First Draw	32
Room 309	Flush	5.17
Room 310	First Draw	61.1
Room 310	Flush	30.3
Classroom 311	First Draw	66.6
Classroom 311	Flush	56.5
Corridor by Room 312	First Draw	ND
Corridor by Room 312	Flush	ND
Classroom 312	First Draw	56.8
Classroom 312	Flush	34.7
Corridor by (503A) Boy's Bathroom (Stainless Steel)	First Draw	ND
Corridor by (503A) Boy's Bathroom (Stainless Steel)	Flush	ND
Corridor by (503A) Boy's Bathroom (Painted Face)	First Draw	ND
Corridor by (503A) Boy's Bathroom (Painted Face)	Flush	ND
Room 504 - Staff Lounge	First Draw	ND
Room 504 - Staff Lounge	Flush	ND
Classroom 506	First Draw	ND
Classroom 506	Flush	ND
Classroom 505	First Draw	ND
Classroom 505	Flush	ND
Classroom 507	First Draw	29.2
Classroom 507	Flush	ND
Classroom 508	First Draw	ND
Classroom 508	Flush	ND
Classroom 509	First Draw	9.23
Classroom 509	Flush	5.76
Classroom 510	First Draw	4.56
Classroom 510	Flush	2.24
Classroom 306	First Draw	28.8
Classroom 306	Flush	3.22
Classroom 304	First Draw	7.63
Classroom 304	Flush	ND
Corridor by Rooms 302B/302C (Higher)	First Draw	ND
Corridor by Rooms 302B/302C (Higher)	Flush	ND
Corridor by Rooms 302B/302C (Lower)	First Draw	ND
Corridor by Rooms 302B/302C (Lower)	Flush	ND
Room 301 - Gymnaisum (Higher)	First Draw	ND
Room 301 - Gymnaisum (Higher)	Flush	ND
Room 301 - Gymnaisum (Lower)	First Draw	ND
Room 301 - Gymnaisum (Lower)	Flush	ND
Room 301A - Kitchen (Right Faucet)	First Draw	ND
Room 301A - Kitchen (Right Faucet)	Flush	ND
Room 301A - Kitchen (Left Faucet)	First Draw	2.51
Room 301A - Kitchen (Left Faucet)	Flush	2.3

Hermes Elementary School
1000 Jungels Avenue
Aurora, IL 60505

Sample Location Description	Sample Type	Concentration (ug/L)
Classroom 401	First Draw	ND
Classroom 401	Flush	ND
Classroom 402	First Draw	ND
Classroom 402	Flush	ND
Classroom 403	First Draw	ND
Classroom 403	Flush	ND
Classroom 404	First Draw	ND
Classroom 404	Flush	ND
Classroom 405	First Draw	ND
Classroom 405	Flush	ND
Classroom 406	First Draw	ND
Classroom 406	Flush	ND
Classroom 407	First Draw	ND
Classroom 407	Flush	ND
Classroom 408	First Draw	ND
Classroom 408	Flush	ND

IDPH requires school districts to notify parents of any water source that tests at 5 parts per billion (ppb) or above.

ND - None Detected

First Draw - First Sample Collected Before Use

Flush - Second Sample Collected After Flushing