

Gates Elementary School
800 Seventh Avenue
Aurora, IL 60505

Sample Location Description	Sample Type	Concentration (ug/L)
Room 2	First Draw	6.96
Room 2	Flush	ND
Room 3	First Draw	ND
Room 3	Flush	ND
Room 11	First Draw	19.4
Room 11	Flush	2.47
Room 13	First Draw	49.5
Room 13	Flush	11.4
Room 15	First Draw	7.12
Room 15	Flush	ND
Corridor by Room 12	First Draw	ND
Corridor by Room 12 (Bottle Filler)	First Draw	ND
Corridor by Room 12	Flush	ND
Room 17	First Draw	2.42
Room 17	Flush	15.1
Room 21	First Draw	4.53
Room 21	Flush	ND
Room 23	First Draw	ND
Room 23	Flush	5.2
Room 25	First Draw	22.9
Room 25	Flush	2.07
Room 27	First Draw	56.4
Room 27	Flush	ND
Room 22	First Draw	2.71
Room 22	Flush	ND
Across from Room 23	First Draw	ND
Across from Room 23	Flush	ND
Room 30	First Draw	41.4
Room 30	Flush	2.87
Room 31	First Draw	29.4
Room 31	Flush	4.92
Room 32	First Draw	744
Room 32	Flush	116
Room 33	First Draw	32
Room 33	Flush	15.1
Room 47	First Draw	43.6
Room 47	Flush	26.2
Room 46	First Draw	67.7
Room 46	Flush	44.5
Corridor in Front of Room 48	First Draw	4.45
Corridor in Front of Room 48	Flush	14.4
Room 49	First Draw	266
Room 49	Flush	4.51
Teachers' Lounge	First Draw	15.3

Gates Elementary School
800 Seventh Avenue
Aurora, IL 60505

Sample Location Description	Sample Type	Concentration (ug/L)
Teachers' Lounge	Flush	10.5
Corridor Across from Kitchen	First Draw	ND
Corridor Across from Kitchen	Flush	2.02
Room 45	First Draw	50.8
Room 45	Flush	14.6
Across from Room 41	First Draw	6.88
Across from Room 41	Flush	9.66
Room 41	First Draw	59.6
Room 41	Flush	14.1
Room 42	First Draw	16.4
Room 42	Flush	4.21
Small Sink by Door	First Draw	ND
Small Sink by Door	Flush	ND
Main Kitchen (Right Spout)	First Draw	ND
Main Kitchen (Left Spout)	First Draw	ND
Main Kitchen	Flush	ND
Nurse's Office	First Draw	ND
Nurse's Office	Flush	ND
Main Office - Kitchen	First Draw	ND
Main Office - Kitchen	Flush	ND
Room 51J	First Draw	2.72
Room 51J	Flush	ND
Corridor by Room 51J (Left)	First Draw	ND
Corridor by Room 51J (Left)	Flush	ND
Corridor by Room 51J (Right)	First Draw	ND
Corridor by Room 51J (Right)	Flush	ND
Boiler Room	First Draw	47.2
Boiler Room	Flush	14
Corridor Between Room 65/64 and Library (Left)	First Draw	ND
Corridor Between Room 65/64 and Library (Left)	Flush	ND
Corridor Between Room 65/64 and Library (Right)	First Draw	ND
Corridor Between Room 65/64 and Library (Right)	Flush	ND
Room 65	First Draw	ND
Room 65	Flush	ND
Room 64	First Draw	ND
Room 64	Flush	ND
Room 63	First Draw	ND
Room 63	Flush	ND
Room 62	First Draw	ND
Room 62	Flush	ND
Room 61	First Draw	ND
Room 61	Flush	ND
Room 60	First Draw	ND
Room 60	Flush	ND

Gates Elementary School
800 Seventh Avenue
Aurora, IL 60505

Sample Location Description	Sample Type	Concentration (ug/L)
Room 66	First Draw	ND
Room 66	Flush	ND
Room 69	First Draw	2.62
Room 69	Flush	ND
Room 68	First Draw	ND
Room 68	Flush	ND
Room 71	First Draw	ND
Room 71	Flush	ND

IDPH requires school districts to notify parents of any water source that tests at 5 parts per billion (ppb) or above.

ND - None Detected

First Draw - First Sample Collected Before Use

Flush - Second Sample Collected After Flushing