

Johnson Elementary School
1934 Liberty Street
Aurora, IL 60502

Sample Location Description	Sample Type	Concentration (ug/L)
Kitchen 112	First Draw	ND
Kitchen 112	Flush	ND
Hallway Outside Room 105 (Right)	First Draw	5.17
Hallway Outside Room 105 (Right)	Flush	9.04
Nurse's Office	First Draw	ND
Nurse's Office	Flush	ND
Teachers' Lounge	First Draw	ND
Teachers' Lounge	Flush	ND
Room 200	First Draw	4.68
Room 200	Flush	ND
Room 200 (Drinking Spout)	First Draw	ND
Room 201 - Kindergarten	First Draw	21.7
Room 201 - Kindergarten	Flush	ND
Room 203 - Kindergarten	First Draw	ND
Room 203 - Kindergarten	Flush	ND
Room 204 - Kindergarten	First Draw	ND
Room 204 - Kindergarten	Flush	ND
Hallway Outside Boy's (205C) Bathroom (Left)	First Draw	ND
Hallway Outside Boy's (205C) Bathroom (Left)	Flush	ND
Hallway Outside Boy's (205C) Bathroom (Right)	First Draw	ND
Room 205	First Draw	2.26
Room 205	Flush	ND
Room 205 (Drinking Spout)	First Draw	5.14
Room 206	First Draw	7.32
Room 206	Flush	16.8
Room 207	First Draw	5.72
Room 207	Flush	ND
Room 207 (Drinking Spout)	First Draw	ND
Room 208	First Draw	ND
Room 208	Flush	ND
Room 208 (Drinking Spout)	First Draw	ND
Hallway Outside Girl's (107A) Bathroom (Right)	First Draw	ND
Hallway Outside Girl's (107A) Bathroom (Right)	Flush	ND
Room 107 - Teachers' Lounge	First Draw	ND
Room 107 - Teachers' Lounge	Flush	ND
Room 311	First Draw	3.26
Room 311	Flush	ND
Room 311 (Drinking Spout)	First Draw	ND
Room 300	First Draw	7.66
Room 300	Flush	ND
Room 300 (Drinking Spout)	First Draw	4.04
Room 301	First Draw	5.2
Room 301	Flush	ND
Room 301 (Drinking Spout)	First Draw	ND

Johnson Elementary School
1934 Liberty Street
Aurora, IL 60502

Sample Location Description	Sample Type	Concentration (ug/L)
Room 310	First Draw	9
Room 310	Flush	ND
Room 310 (Drinking Spout)	First Draw	2.25
Room 302	First Draw	2.6
Room 302	Flush	ND
Room 309	First Draw	5.79
Room 309	Flush	ND
Room 309 (Drinking Spout)	First Draw	2.11
Room 410	First Draw	43
Room 410	Flush	ND
Hallway Near Room 410 (Left)	First Draw	ND
Hallway Near Room 410 (Left)	Flush	ND
Hallway Near Room 410 (Right)	First Draw	ND
Hallway Near Room 410 (Right)	Flush	ND
Room 409	First Draw	ND
Room 409	Flush	ND
Room 408	First Draw	3.61
Room 408	Flush	ND
Room 402	First Draw	ND
Room 402	Flush	ND
Room 403	First Draw	ND
Room 403	Flush	ND
Room 404	First Draw	ND
Room 404	Flush	ND
Room 405	First Draw	ND
Room 405	Flush	ND
Room 407	First Draw	ND
Room 407	Flush	ND
Room 406	First Draw	ND
Room 406	Flush	ND
Water Main - Intake (Non-Potable Source)	First Draw	197
Water Main - Intake (Non-Potable Source)	Flush	67.3

IDPH requires school districts to notify parents of any water source that tests at 5 parts per billion (ppb) or above.

ND - None Detected

First Draw - First Sample Collected Before Use

Flush - Second Sample Collected After Flushing