

Krug Elementary School
240 Melrose Avenue
Aurora, IL 60505

Sample Location Description	Sample Type	Concentration (ug/L)
Classroom 21	First Draw	2.59
Classroom 21	Flush	3.84
Classroom 20	First Draw	2.23
Classroom 20	Flush	ND
Corridor Between 19A and 18B	First Draw	ND
Corridor Between 19A and 18B	Flush	ND
Classroom 19	First Draw	ND
Classroom 19	Flush	ND
Classroom 18	First Draw	ND
Classroom 18	Flush	ND
Classroom 17	First Draw	2.45
Classroom 17	Flush	ND
Classroom 16	First Draw	2.82
Classroom 16	Flush	ND
Room 7A - Lounge/Workroom	First Draw	ND
Room 7A - Lounge/Workroom	Flush	ND
Room 10	First Draw	ND
Room 10	Flush	ND
Corridor Opposite Room 8C (Higher)	First Draw	ND
Corridor Opposite Room 8C (Higher)	Flush	ND
Corridor Opposite Room 8C (Lower)	First Draw	ND
Corridor Opposite Room 8C (Lower)	Flush	ND
Classroom 9	First Draw	ND
Classroom 9	Flush	ND
Classroom 11	First Draw	ND
Classroom 11	Flush	ND
Classroom 12	First Draw	ND
Classroom 12	Flush	ND
Classroom 7	First Draw	3.98
Classroom 7	Flush	2.67
Classroom 6	First Draw	ND
Classroom 6	Flush	ND
Classroom 5	First Draw	2.03
Classroom 5	Flush	ND
Classroom 4	First Draw	ND
Classroom 4	Flush	ND
Classroom 3	First Draw	2.16
Classroom 3	Flush	6.19
Classroom 2	First Draw	2.27
Classroom 2	Flush	32
Corridor Opposite Room 312	First Draw	ND
Corridor Opposite Room 312	Flush	ND
Classroom 1	First Draw	3.94
Classroom 1	Flush	ND
Gymnasium Room 23 - Kitchen	First Draw	ND

Krug Elementary School
240 Melrose Avenue
Aurora, IL 60505

Sample Location Description	Sample Type	Concentration (ug/L)
Gymnasium Room 23 - Kitchen	Flush	ND

IDPH requires school districts to notify parents of any water source that tests at 5 parts per billion (ppb) or above.

ND - None Detected

First Draw - First Sample Collected Before Use

Flush - Second Sample Collected After Flushing