

School Service Center
417 Fifth Street
Aurora, IL 60505

Sample Location Description	Sample Type	Concentration (ug/L)
1st Floor - Staff Lounge	First Draw	7.22
1st Floor - Staff Lounge	Flush	6.51
1st Floor - By Benefits/Facilities Room	First Draw	ND
1st Floor - By Benefits/Facilities Room	Flush	ND
Basement - Water Main (Non Potable Source)	First Draw	1,390
Basement - Water Main (Non Potable Source)	Flush	364

IDPH requires school districts to notify parents of any water source that tests at 5 parts per billion (ppb) or above.

ND - None Detected

First Draw - First Sample Collected Before Use

Flush - Second Sample Collected After Flushing