

O'Donnell Elementary School
1640 Reckinger Road
Aurora, IL 60505

Sample Location Description	Sample Type	Concentration (ug/L)
1st Floor - Entrance by Door 5 (Left)	First Draw	ND
1st Floor - Entrance by Door 5 (Left)	Flush	ND
1st Floor - Entrance by Door 5 (Right)	First Draw	ND
1st Floor - Entrance by Door 5 (Right)	Flush	ND
1st Floor - Room 304 - Preschool	First Draw	ND
1st Floor - Room 304 - Preschool	Flush	ND
1st Floor - Room 301 - Preschool	First Draw	ND
1st Floor - Room 301 - Preschool	Flush	ND
1st Floor - Room 302 - Preschool	First Draw	ND
1st Floor - Room 302 - Preschool	Flush	ND
1st Floor - Room 303 - Preschool	First Draw	ND
1st Floor - Room 303 - Preschool	Flush	ND
1st Floor - Room 115	First Draw	12.8
1st Floor - Room 115	Flush	2.33
1st Floor - Room 113	First Draw	5.06
1st Floor - Room 113	Flush	ND
1st Floor - Room 112	First Draw	6.3
1st Floor - Room 112	Flush	ND
1st Floor - Across from Room 111 (Left)	First Draw	ND
1st Floor - Across from Room 111 (Left)	Flush	ND
1st Floor - Across from Room 111 (Right)	First Draw	ND
1st Floor - Across from Room 111 (Right)	Flush	ND
1st Floor - Room 111	First Draw	31.6
1st Floor - Room 111	Flush	2.87
1st Floor - Room 110	First Draw	3.49
1st Floor - Room 110	Flush	2.27
1st Floor - Room 109	First Draw	9.6
1st Floor - Room 109	Flush	8.01
1st Floor - Room 108	First Draw	6.92
1st Floor - Room 108	Flush	4.6
1st Floor - Room 205	First Draw	ND
1st Floor - Room 205	Flush	ND
1st Floor - Room 206	First Draw	ND
1st Floor - Room 206	Flush	ND
1st Floor - Room 207	First Draw	ND
1st Floor - Room 207	Flush	ND
1st Floor - Room 208	First Draw	ND
1st Floor - Room 208	Flush	ND
1st Floor - Outside Room 212 (Left)	First Draw	ND
1st Floor - Outside Room 212 (Left)	Flush	ND
1st Floor - Outside Room 212 (Right)	First Draw	ND
1st Floor - Outside Room 212 (Bottle Filler)	First Draw	ND
1st Floor - Outside Room 212 (Right)	Flush	ND

O'Donnell Elementary School
1640 Reckinger Road
Aurora, IL 60505

Sample Location Description	Sample Type	Concentration (ug/L)
1st Floor - Room 204	First Draw	ND
1st Floor - Room 204	Flush	ND
1st Floor - Room 203	First Draw	ND
1st Floor - Room 203	Flush	ND
1st Floor - Room 202	First Draw	ND
1st Floor - Room 202	Flush	ND
1st Floor - Room 201	First Draw	ND
1st Floor - Room 201	Flush	ND
1st Floor - Staff Lounge	First Draw	ND
1st Floor - Staff Lounge	Flush	ND
1st Floor - Room 107	First Draw	9.35
1st Floor - Room 107	Flush	2.33
1st Floor - Room 106	First Draw	4.52
1st Floor - Room 106	Flush	ND
1st Floor - Room 105	First Draw	6.16
1st Floor - Room 105	Flush	4.38
1st Floor - Room 104	First Draw	3.78
1st Floor - Room 104	Flush	ND
1st Floor - Room 103	First Draw	15.3
1st Floor - Room 103	Flush	2.76
1st Floor - Room 102	First Draw	9.09
1st Floor - Room 102	Flush	4.55
1st Floor - Next to C146 (Left)	First Draw	ND
1st Floor - Next to C146 (Left)	Flush	ND
1st Floor - Next to C146 (Right)	First Draw	ND
1st Floor - Next to C146 (Right)	Flush	ND
1st Floor - Room 101	First Draw	11.3
1st Floor - Room 101 (Sprayer)	First Draw	25.8
1st Floor - Room 101	Flush	9.55
1st Floor - Room 130A - Main Intake (Non-Potable Source)	First Draw	532
1st Floor - Room 130A - Main Intake (Non-Potable Source)	Flush	78.9
1st Floor - Gym - Kitchen	First Draw	3.48
1st Floor - Gym - Kitchen	Flush	2.69
1st Floor - Room 124A - Nurse's Office Bathroom	First Draw	6.01
1st Floor - Room 124A - Nurse's Office Bathroom	Flush	2.66

IDPH requires school districts to notify parents of any water source that tests at 5 parts per billion (ppb) or above.

ND - None Detected

First Draw - First Sample Collected Before Use

Flush - Second Sample Collected After Flushing