

Oak Park Elementary School
1200 Front Street
Aurora, IL 60505

Sample Location Description	Sample Type	Concentration (ug/L)
3rd Floor - Outside Room 302	First Draw	ND
3rd Floor - Outside Room 302	Flush	ND
3rd Floor - Outside Room 303 - Social Worker's Bathroom	First Draw	ND
3rd Floor - Outside Room 303 - Social Worker's Bathroom	Flush	ND
3rd Floor - Outside Room 307	First Draw	ND
3rd Floor - Outside Room 307	Flush	ND
2nd Floor - Outside Room 203 - Nurse's Office	First Draw	ND
2nd Floor - Outside Room 203 - Nurse's Office	Flush	ND
2nd Floor - Room 203 - Nurse's Office Bathroom	First Draw	ND
2nd Floor - Room 203 - Nurse's Office Bathroom	Flush	2.65
2nd Floor - Outside Room 208	First Draw	ND
2nd Floor - Outside Room 208	Flush	ND
1st Floor - Outside Boy's Bathroom	First Draw	ND
1st Floor - Outside Boy's Bathroom	Flush	ND
1st Floor - Kitchen	First Draw	5.3
1st Floor - Kitchen	Flush	ND
1st Floor - Room 30 - Main Line (Non-Potable Source)	First Draw	ND
1st Floor - Room 30 - Main Line (Non-Potable Source)	Flush	ND
1st Floor - Across from Girl's Bathroom (34)	First Draw	ND
1st Floor - Across from Girl's Bathroom (34)	Flush	ND
1st Floor - Library Entryway (Left)	First Draw	ND
1st Floor - Library Entryway (Left)	Flush	ND
1st Floor - Library Entryway (Right)	First Draw	ND
1st Floor - Library Entryway (Right)	Flush	ND
1st Floor - Room 19 - Classroom	First Draw	ND
1st Floor - Room 19 - Classroom	Flush	ND
1st Floor - Room 18 - Teachers' Lounge	First Draw	ND
1st Floor - Room 18 - Teachers' Lounge	Flush	ND
1st Floor - Room 17 - 1st Grade Classroom	First Draw	ND
1st Floor - Room 17 - 1st Grade Classroom	Flush	ND
1st Floor - Room 16 - Reading Interventionist	First Draw	ND
1st Floor - Room 16 - Reading Interventionist	Flush	ND
1st Floor - Room 15 - Speech Pathologist	First Draw	11.4
1st Floor - Room 15 - Speech Pathologist	Flush	ND
1st Floor - Room 14 - 2nd Grade Classroom	First Draw	4.05
1st Floor - Room 14 - 2nd Grade Classroom	Flush	ND
1st Floor - Room 12 - 2nd Grade Classroom	First Draw	12.5
1st Floor - Room 12 - 2nd Grade Classroom	Flush	8.81
1st Floor - Outside Room 11 - Occupational and Physical Therapy (Left)	First Draw	ND
1st Floor - Outside Room 11 - Occupational and Physical Therapy (Left)	Flush	ND
1st Floor - Outside Room 11 - Occupational and Physical Therapy (Right)	First Draw	ND
1st Floor - Outside Room 11 - Occupational and Physical Therapy (Right)	Flush	ND
1st Floor - Room 10 - 2nd Grade Classroom	First Draw	ND
1st Floor - Room 10 - 2nd Grade Classroom	Flush	ND
1st Floor - Between Boy's (9C) and Girl's (9D) Bathrooms (Left)	First Draw	ND

Oak Park Elementary School
1200 Front Street
Aurora, IL 60505

Sample Location Description	Sample Type	Concentration (ug/L)
1st Floor - Between Boy's (9C) and Girl's (9D) Bathrooms (Left)	Flush	ND
1st Floor - Between Boy's (9C) and Girl's (9D) Bathrooms (Right)	First Draw	ND
1st Floor - Between Boy's (9C) and Girl's (9D) Bathrooms (Right)	Flush	ND
1st Floor - Room 9 - Kindergarten Classroom	First Draw	ND
1st Floor - Room 9 - Kindergarten Classroom	Flush	ND
1st Floor - Room 8 - Kindergarten Classroom	First Draw	ND
1st Floor - Room 8 - Kindergarten Classroom	Flush	ND
1st Floor - Room 7 - Preschool Classroom	First Draw	ND
1st Floor - Room 7 - Preschool Classroom	Flush	ND
1st Floor - Room 6 - Kindergarten Classroom	First Draw	ND
1st Floor - Room 6 - Kindergarten Classroom	Flush	ND
1st Floor - Room 5 - Preschool Classroom	First Draw	ND
1st Floor - Room 5 - Preschool Classroom	Flush	ND
1st Floor - Room 4 - Classroom Used for Storage	First Draw	ND
1st Floor - Room 4 - Classroom Used for Storage	Flush	ND
1st Floor - Room 3 - Preschool Classroom	First Draw	ND
1st Floor - Room 3 - Preschool Classroom	Flush	ND
1st Floor - Room 2 - Preschool Classroom	First Draw	ND
1st Floor - Room 2 - Preschool Classroom	Flush	ND
1st Floor - Room 1 - Preschool Classroom	First Draw	6.04
1st Floor - Room 1 - Preschool Classroom	Flush	ND
1st Floor - Room 22 - Teachers' Work Room	First Draw	ND
1st Floor - Room 22 - Teachers' Work Room	Flush	ND

IDPH requires school districts to notify parents of any water source that tests at 5 parts per billion (ppb) or above.

ND - None Detected

First Draw - First Sample Collected Before Use

Flush - Second Sample Collected After Flushing