

Simmons Middle School

1130 Sheffer Road

Aurora, IL 60505

Sample Location Description	Sample Type	Concentration (ug/L)
Corridor Opposite Nurse's Office (Tall)	First Draw	ND
Corridor Opposite Nurse's Office (Tall)	Flush	ND
Corridor Opposite Nurse's Office (Short)	First Draw	ND
Corridor Opposite Nurse's Office (Short)	Flush	ND
Nurse's Office	First Draw	ND
Nurse's Office (Sprayer)	Flush	6.92
Nurse's Office	First Draw	ND
Room 460 - Cabinet Station 1	Flush	ND
Room 460 - Cabinet Station 1	First Draw	ND
Room 460 - Cabinet Station 2	Flush	ND
Room 460 - Cabinet Station 2	First Draw	ND
Room 460 - Cabinet Station 3	Flush	ND
Room 460 - Cabinet Station 3	First Draw	ND
Room 460 - Cabinet Station 4	Flush	ND
Room 460 - Cabinet Station 4	First Draw	ND
Room 460 - Cabinet Station 5	Flush	ND
Room 460 - Cabinet Station 5	First Draw	ND
Room 460 - Cabinet Station 6	Flush	ND
Room 460 - Cabinet Station 6	First Draw	ND
Cafeteria (From Left to Right) - Fountain 1	Flush	ND
Cafeteria (From Left to Right) - Fountain 1	First Draw	ND
Cafeteria (From Left to Right) - Fountain 2	Flush	ND
Cafeteria (From Left to Right) - Fountain 2	First Draw	ND
Cafeteria (From Left to Right) - Fountain 3	Flush	ND
Cafeteria (From Left to Right) - Fountain 3	First Draw	ND
Cafeteria (From Left to Right) - Fountain 4	Flush	ND
Cafeteria (From Left to Right) - Fountain 4	First Draw	ND
Kitchen - By Office (Large Basin)	Flush	3.44
Kitchen - By Office (Large Basin)	First Draw	ND
Kitchen - By Office (Small Basin - Left Spout)	Flush	ND
Kitchen - By Office (Small Basin - Right Spout)	First Draw	ND
Kitchen - By Office (Small Basin - Right Spout)	Flush	ND
Kitchen - Near End of Wall (Left Spout)	First Draw	ND
Kitchen - Near End of Wall (Left Spout)	Flush	ND
Kitchen - Near End of Wall (Right Spout)	First Draw	ND
Kitchen - Near End of Wall (Right Spout)	Flush	ND
Kitchen - By Stove	First Draw	2.05
Kitchen - By Stove	Flush	ND
Boiler Room (Non-Potable Source)	First Draw	196
Boiler Room (Non-Potable Source)	Flush	3.21
Corridor by Room 360 (Left)	First Draw	ND
Corridor by Room 360 (Left)	Flush	ND
Corridor by Room 360 (Right)	First Draw	ND
Corridor by Room 360 (Right)	Flush	ND

Simmons Middle School
1130 Sheffer Road
Aurora, IL 60505

Sample Location Description	Sample Type	Concentration (ug/L)
Girl's Bathroom - Inside Gym	First Draw	ND
Girl's Bathroom - Inside Gym	Flush	ND
Inside Gym (Right)	First Draw	ND
Inside Gym (Right)	Flush	ND
Inside Gym (Left)	First Draw	ND
Inside Gym (Left)	Flush	ND
Outside Gym by Room 685 (Tall)	First Draw	ND
Outside Gym by Room 685 (Tall)	Flush	ND
Outside Gym by Room 685 (Short)	First Draw	ND
Outside Gym by Room 685 (Short)	Flush	ND
Corridor by 235 (Tall)	First Draw	ND
Corridor by 235 (Tall)	Flush	ND
Corridor by 235 (Short)	First Draw	ND
Corridor by 235 (Short)	Flush	ND
Corridor by 210 (Tall)	First Draw	ND
Corridor by 210 (Tall)	Flush	ND
Corridor by 210 (Short)	First Draw	ND
Corridor by 210 (Short)	Flush	ND

IDPH requires school districts to notify parents of any water source that tests at 5 parts per billion (ppb) or above.

ND - None Detected

First Draw - First Sample Collected Before Use

Flush - Second Sample Collected After Flushing