

## Waldo Middle School

56 Jackson Street

Aurora, IL 60505

Sample Location Description	Sample Type	Concentration (ug/L)
Lunchroom	First Draw	ND
Lunchroom	Flush	ND
Kitchen - At Smoothie Station	First Draw	ND
Kitchen - At Smoothie Station	Flush	ND
Kitchen - Near Office	First Draw	ND
Kitchen - Near Office	Flush	ND
Kitchen - Prep Area	First Draw	2.38
Kitchen - Prep Area	Flush	ND
Kitchen - Dish Washing Sink (Left Spout)	First Draw	ND
Kitchen - Dish Washing Sink (Left Spout)	Flush	ND
Kitchen - Dish Washing Sink (Right Spout)	First Draw	ND
Teachers' Lounge	First Draw	ND
Teachers' Lounge	Flush	ND
Room 115A - Sink 1	First Draw	ND
Room 115A - Sink 1	Flush	ND
Room 115A - Sink 2	First Draw	ND
Room 115A - Sink 2	Flush	ND
Room 115A - Sink 3	First Draw	ND
Room 115A - Sink 3	Flush	ND
Room 115A - Sink 4	First Draw	ND
Room 115A - Sink 4	Flush	ND
Room 115A - Sink 5	First Draw	ND
Room 115A - Sink 5	Flush	ND
Room 115A - Sink 6	First Draw	ND
Room 115A - Sink 6	Flush	ND
Room 115A - Sink 7	First Draw	ND
Room 115A - Sink 7	Flush	ND
Room 115A - Sink 8	First Draw	ND
Room 115A - Sink 8	Flush	ND
Hallway Near Room 110	First Draw	ND
Hallway Near Room 110	Flush	ND
Hallway Near Room 104	First Draw	ND
Hallway Near Room 104	Flush	ND
Band Room 401	First Draw	ND
Band Room 401	Flush	ND
Hallway Near Room 312	First Draw	ND
Hallway Near Room 312	Flush	ND
Hallway Near Room 306	First Draw	ND
Hallway Near Room 306	Flush	ND
Hallway Near Room 214	First Draw	ND
Hallway Near Room 214	Flush	ND
Hallway Near Room 205	First Draw	ND
Hallway Near Room 205	Flush	ND
Room 204K - Nurse's Office	First Draw	ND
Room 204K - Nurse's Office	Flush	ND

Waldo Middle School  
56 Jackson Street  
Aurora, IL 60505

Sample Location Description	Sample Type	Concentration (ug/L)
Room 204L - Nurse's Office	First Draw	ND
Room 204L - Nurse's Office	Flush	ND
Electrical Room (Non-Potable Source)	First Draw	153
Electrical Room (Non-Potable Source)	Flush	3.59
Boy's Locker Room	First Draw	ND
Boy's Locker Room	Flush	ND

IDPH requires school districts to notify parents of any water source that tests at 5 parts per billion (ppb) or above.

ND - None Detected

First Draw - First Sample Collected Before Use

Flush - Second Sample Collected After Flushing